

MIMER MEDICAL COLLEGE, TALEGAON (D)

Index For Log Books of maintenance

Name of Department	Page No
Ground Maintenance	2-72
Electrical Department	73-94
Biomedical	95-136
ICT	137-139

MIMER MEDICAL COLLEGE , TALEGAON (D)

Log Book - Ground Maintenance

2016 to 2021

ऑगस्ट - 2020

दिनांक	विभागाचे नाव	सफारीचे प्रकार
12/08/20	Casualty	spray pump विडोसनेस टोना नो ड्रुव्ह 060 मिनामा
17/08/20	मेडीक इलेक्ट्रिक	1) परिभा मजला वेसींग वायव्या मोबॅटी पद्वि वनराक साठवत आहे. 2) मिनामा मजला वायव्याम ऑनर कॅबल डिरेक्ट आहे. 3) रिडिंग कॅबल वायव्यामकमा नकासा रगुप पाणी तारिठ येत आहे.
17/8/20	मेडीक सेलेंड	1) परिभा मजला इगरी साठि वायव्याम नकासा पाणी कमी येते
19/08/20	इलेक्ट्रिक	महाक wash basin मोठमप मोलेले आहे.
24/08/20	posts OFD	मिनामा मजले मोबॅटी फवाशगी करव्याम नकासा

दिनांक	काम पुर्व वेळापत्र तपरीक	नाम	रुमा
13/08/20	pump ड्रुव्ह करव्याम नकासा	मुसावर	88
19/08/20	काम पुर्व मोलेले आहे	साठि	88
19/08/20	शॉर कॅबल ड्रुव्ह करव्याम नकासा	-	88
19/08/20	नळ ड्रुव्ह करव्याम नकासा	-	88
19/08/20	नळ ड्रुव्ह करव्याम नकासा	-	88
19/08/20	मोठमप कारव्याम नकासा	बुराड	88
24/08/20	मोबॅटी फवाशगी करव्याम नकासा	पुसावर	88

सप्टेंबर - 2020

दिनांक	विभागाचे नाव	कार्य तक्रारीची स्वभाव
2/09/20	Exam Hall	MUHS theory examination in the collage. 5th sept. to 21st sept. 20. Depute one worker for cleaning & sanitization all exam Hall & strong room.
2/09/20	मेडीस हॉस्टेल	उजवी बाजू फ्लोअरची पाण्याची टाकी घुडून खरब करून घ्यावी.
3/09/20	physiotherapy collage	theory Exam of final year B.P.T. 5th sept - 15th sept. arrange the sanitization of examination hall twice a day.
4/09/20	Operation theatre	Changing Room मधील टॉयलेट नोकराचे धारेचे नोकराचे मरुत घ्यावे.
14/09/20	ODDy Ward No. 108	वॉर्ड मधील Labour Room मधील फ्लोर टॉयलेट सिनिंग मरुत (LORD ICD) घानी लीकेज होत आहे.
15/09/20	Boys Hostel	टॉयलेट मध्ये सांडपाण्या साठवण मशिनारीचे पेटि मरुत घ्यावे.

दिनांक	काम संपादनपूर्वी केलेल्या मरुतीक	मास	मती
4/09/20	सर्व हॉटेलचे फ्लोरची स्वच्छता घ्यावी.	सप्टेंबर	23
10/09/20	पाण्याची टाकी घुडून खरब करून घ्यावी.		24
11/09/20	पाण्याची फ्लोअरची कामास नेमकात घ्यावी.	सप्टेंबर	25
17/09/20	चोकराचा कारखाना मरुत.	ऑक्टोबर	26
15/09/20	सर्व हॉटेलचे फ्लोरची स्वच्छता घ्यावी.		27
18/09/20	मशिनारीचे पेटि मरुत घ्यावे.	नोव्हेंबर	28

17/09/20

COVID
IPL

IPL मधील पेटोर टॉपलेटचे बेसीनचे पाईप लोखणप खालेक आहे. दुकाने कळत मिळाले.

19/09/20

काम पुर्त करवून घेतले.

संभव/अधीक

११

18/09/20

लोडिंग
होस्टेल

मधील-सोकार्तीक मेसन्ना बाजूचे पात्र-बांधवा बाजुला पिटोचे बांधकाम कळत आहे तसेच पात्रांकरा खाली पाणी नाळ्यासाठी जाळी लागून दुर्भंग झाली.

24/09/20

पात्रांकरा खाली बांधकाम करवून घेतले.

बाजुला/अधीक

११

21/09/20

लोडिंग
होस्टेल

- 1) दुसरा मजला खाली खोदणे टॉपलेटची काम पुढेकाली आहे.
- 2) डावी बाजु बांधकामा होमी लोखणी स्थितीला येऊनलेला कारेत. व पुढेकाली आहे.
- 3) बेसीनच्या वरीक खोदणीला खोदणीकाली काम व बांधणी-सोकार्तीक मिळालेली आहे. पात्रांकरा पाणी पात्रांकरा येत आहे. हे काम त्वरित करत मिळाले.

23/09/20

काम त्वरित-त्रात झाली

सुधे

११

सदचे काम हे आरिष्ट मिळाले आहे.

सदचे काम हे कारपेकी विभागाचे आहे. नांवाचे कामेकाली व लागलेल्या कामेकाली आहे.

23/09/20

लोडिंग
होस्टेल

- 1) होस्टेल सोकार्तीक बाजुला कामेकाली R.O. तंत्र नष्ट पिलेक आहे. तो त्वरित
- 2) पहिला मजलावरीक बांधकामा सुधीक पाईप खोदणे करवून घेतले आहे तो त्वरित

25/09/20

नविन जळ त्वरित-त्रात झाली

सविता

११

25/09/20

सुधीक पाईप त्वरित-त्रात झाली

सविता

११

सितंबर 2020

2/10/20	राजेश कोलेक	बहाल काठमाडौं विभागीय तहसीला नयाँ पुरानाका पाठशाला पढाई हुनेछ भएर	2/10/20	काठमाडौं कक्षागत बाले	राजेश कोलेक	२९
3/10/20	नेर्मि कोलेक	भद्रको डोरि राम्रो भएर उदरको बाधन नैरुवाग भएर	4/10/20	उदरको बाधन नैरुवाग भएर	-	२९
6/10/20	O.T.	CSSD मध्ये R.O. ले पाणी घेन गरी जेसरीको पाणी घेने R.O. पाणी खाएर हि. सिरोनी खण्ड मन्त्रीको लेखन कक्षा नैरुवा	7/10/20	नेर्मि कोलेक पाणी घेनु र उदरको बाधन नैरुवाग भएर	समिरा	२९
8/10/20	समिरा कोलेक	पिप्लाको पाठशाला टाकी खुकुट भएर	11/10/20	काठमाडौं कक्षागत		२९
8/10/20	pharmaceutical Dept.	Leakage of water at 4/48h tank in ladies toilet	13/10/20	काठमाडौं कक्षागत बाले	समिरा	२९
8/10/20	नेर्मि कोलेक	1) परिसर सफाई दिउने काम भएर 2) काठमाडौं कक्षागत भएर साहेब 2) परिसर सफाई हुने काम भएर 2) काठमाडौं कक्षागत भएर	13/10/20	काठमाडौं कक्षागत भएर	सुरेष्	२९

07/10/20	मेडीक रोलर	ड्रॉकर मरम्मतकारीक 2 खंडहरूमा मरम्मतको लागि	15/10/20	खिचोला काटा मरम्मतको लागि	कुवेर	रु
12/10/20	Resp. Wood-	Kindly repair flush of Dr's room & Nurses Room.	15/10/20	Flsh ड्रॉकर मरम्मतको लागि	कुवेर रु	रु
14/10/20	DBGY Wood-106	1) ड्रॉकर खिचोला काटा फ्लशको लागि 2) एक गार्ड वरिष्ठ फोलेनी काटेरी बसुने मरम्मत	17/10/20	काटा मरम्मतको लागि	कुवेर	रु
15/10/20	मेडीक रोलर	1) ड्रॉकर मरम्मत 2 काटा फ्लशको काटेरी 2) मरु. 301, 324 मा काटा फ्लशको काटेरी	20/10/20	काटा मरम्मतको लागि	कुवेर	रु
20/10/20	मेडीक रोलर	1) काटेरी फ्लशको मरम्मतको लागि फ्लशको मरम्मत	20/10/20	मरम्मतको लागि		रु
25/10/20	मेडीक रोलर	मरु. 301 व 324 दोनो काटेरी काटा फ्लशको मरम्मत	20/10/20	काटा मरम्मतको लागि	कुवेर	रु
		2) ड्रॉकर 2 काटा फ्लशको लागि	26/10/20	काटा मरम्मतको लागि	कुवेर	रु

27/10/20.	रक्षा नवार्दर	A मधील कारेरीन वायुचे प्रोजेक्ट पावले पुणेला गाव ते पुणेला १००० मिमी	28/10/20	प्रेम पाद्रीला सिमेंट लागू प्रोजेक्ट बांधे	काठगाव	२३
२६/१०/२०.	Casualty.	मशीन Labour Room मधील टॉमलेट रवा केली नवे रबीचे मिश्रणचे बांधले ते लसवुड मिश्रण	२९/१०/२०	वेलीन फिर काढत प्रोजेक्ट बांधे	सावित्री ३/१/१९	२४
२६/१०/२०.	CAP.	दि २६/१०/२० ते २७/१०/२० रवा कामावली मध्ये CAP बांधे. टॉमलेट रवा, वेडबाई ३० मजला करवाय जाय.	२६/१०/२०	टॉमलेट रवा, वेडबाई लागू प्रोजेक्ट बांधे.		२५.

नोव्हेंबर - 2020.

दिनांक	विभाग/वेळ	तारीखेचे प्रकार
4/11/20	मेडीस वॉरल्ड	1) टेरिसवर्क पाठ्याच्या हाती जवळ सधे आलेली साई से काढून मिळवणे 2) मेसच्या पाठ्याच्या हाती सधे वाढवणे साई. 3) टारनेस पॅसेज टेरिसवर्क साई वाढवणे साईत काढून मिळवणे.
9/11/20	CBGY Wood - 106.	अनुसंधान व क्वेरीस नोकसप साई.
17/11/20	गर्भस वॉरल्ड	कम सं. 013 किडनीच्या काच फुटकेली साई. 325, 309 मिम कम 2 काच
18/11/20	CCL	मधे काचक्रम नोकसप साई साई.
20/11/20	Resident 6103	कम सं. 06 मधे काचक्रम साई साई.
26/11/20	Microbiology	Wash basin व Tap in washing room.

दिनांक	काम पूर्ण केव्हाचा तारीख	साई	सही
11/11/20	डोळेक वरील टेरिस वरील सधे साई काढवून आणणे.		218.
	—		
	—		
18/11/20	नोकसप काढवून आणे.	गर्भस	219
17/11/20	काच पूर्ण झालेले साई.	सुनेसा	215
20/11/20	नोकसप काढवून आणे	गर्भस	215
20/11/20	नविन वॉरल्ड वसतुन केव्हात आणणे	सालीस 210/11/20	215
20/11/20	नविन मेडीक अस्पतालचे कॅन्सक काढवून आणे.		215

डिसेंबर - २०२०

दिनांक	विभागाचे नाव	कार्याची स्थिति
३/१२/२०	F psy ward	रिपोर्टिंग काम पूर्ण केला आहे.
५/१२/२०	Exam Hall	३०th Dec. १०th मंडळीचे Exam संपादन आणि वारंवारता व सॉफ्टवेअरची परीक्षा.
६/१२/२०	MMW-16	वेबसाइट व सामग्रीचे नाव मिळवणे आणि दुर्लक्ष करणे आणि.
७/१२/२०	F. psy ward	प्युअर रजिस्ट्रार पडवि मिशन आहे.
९/१२/२०	वेबसाइट	१) परिष्कार मजाली टॉयलेट कोठमय आहे. २) कुसरा मजाली बायको कोठमय आहे.
९/१२/२०	वेबसाइट F. PSY	रिपोर्टिंग काम पूर्ण केला आहे.
९/१२/२०	वॉर्ड नं २५	वॉर्ड कुकर मिशन आहे.
९/१२/२०	OPD-19	वेबसाइट व वॉर्ड साफ करणे आहे.

दिनांक	काम पूर्ण केला आहे स्थिति	गति	स्थिति
६/१२/२०	फायरिंग करीता कामासाठी रिपोर्टिंग करणे आणि.	परमेश्वर	२४
११/१२/२०	गळ दुर्लक्ष करणे आणि.	सविना मजाली	२४
६/१२/२०	नविन पडवि मजाली मजाली आणि.	सविना मजाली	२४
७/१२/२०	वेबसाइट कोठमय बायको कोठमय आणि.	धराली, मजाली	२५
१०/१२/२०	कार्य प्रसंगी मजाली आणि.	सुनेश	२४
१३/१२/२०	काम पूर्ण केला आहे आणि.	सविना + मजाली	२५
१५/१२/२०	नविन वळ प्रसंगी मजाली आणि.	सविना मजाली	२५

11/12/20	F.P.S.Y. Ward	परिसराली काच पुनःकोमी बांध	12/12/20	काच बसतुन ठेवाम बांध	सुखा	सु.
12/12/20	F.P.S.Y. Ward	पेवरे बांधाम - नोकसप बांध	16/12/20	नोकसप बांधाम बांध	सुखा	सु.
11/12/20	Feeds STD	नव वराम बांधाम बांध	16/12/20	नव वराम बांधाम बांध	सुखा	सु.
11/12/20	B-16	नव वराम बांधाम बांध	14/12/20	नव वराम बांधाम बांध	सुखा	सु.
14/12/20	Optical EPD	प्लेन्स चेंज बांधाम बांध	14/12/20	New pipe fit in Basin	सुखा	सु.
15/12/20	वेरिफेरेट	पारिना मजमा रिडिंग होल मधील बांधाम नव रिडिंग बांध	20/12/20	नव वराम बांधाम बांध	सुखा	सु.
		रिडिंग कम वराम रिडिंग बांध काम पुनःकोमी बांध		नव वराम ठेवाम बांध	सुखा	सु.
14/12/20	Blood Bank	कोसमोच कम मधील बांधाम बांध रिडिंग बांध	17/12/20	सिमेंट बांध ठेवाम बांध	सुखा	सु.
12/12/20	Resident Gas	नव वराम बांधाम बांध बांध	17/12/20	नव वराम बांधाम बांध	सुखा	सु.
12/12/20	वेरिफेरेट	कम वराम बांधाम बांध बांध	19/12/20	काच बसतुन ठेवाम बांध	सुखा	सु.

17/12/20 लेडीज बोर्डिंग मिथला मजला मरु लेडीज बोर्डिंग साईट बाई

18/12/20 microbiology मध्ये नव खराब साईट बाई

19/12/20 Respiratory Word Window Glass Bookan

21/12/20 Wood No. 106. Wash Basin Pipe नोक मरु साईट बाई

23/12/20 M.R.D. नोंडा लेडीजचा नव खराब साईट बाई

23/12/20 Ortho CPD खोशीचा लेडीज हॉबलर मरु नव लेडीज साईट

23/12/20 PSY CPD पॅला खेडीचा नव लेडीज साईट

24/12/20 लेडीज बोर्डिंग पदिला मजला रिडिंग कम मरु नोंडा लेडीजचे नोक मरु साईट

29/12/20 NDCU मध्ये सुरवे व मुळा साईट बाई

17/12/20 नोक मरु काळ्यात मरु मरु PL

20/12/20 नव डुकल मरु देवात मरु Satish Bhagwan SL

21/12/20 मरु काळ्यात मरु मरु मरु SL

21/12/20 नोक मरु काळ्यात मरु मरु SL

22/12/20 मरु नव मरु देवात मरु Satish Bhagwan SL

24/12/20 मरु नव मरु देवात मरु Satish Bhagwan SL

24/12/20 नव डुकल मरु देवात मरु Satish SL

24/12/20 नोक मरु काळ्यात मरु पाईप मरु देवात मरु मरु SL

29/12/20 मुंमरु मरु देवात मरु (coney line chok) मरु SL

दिनांक	क्र.सं.	कार्योत्तर	विभागाचे नाव	दिनांक	काम पूर्ण केव्हाचा तपशील	नाम व सही	स्थ.
1/01/21	1	अपघात विभागा मॉडेल वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक पाईप वॉल्वरीक वॉल्वरीक	अपघात विभाग	1/01/21	वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक काम पूर्ण झाले आहे.	अपघात वॉल्वरीक अपघात वॉल्वरीक	स्थ.
2/01/21	1)	वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक (13 फॉल्वरीक)	वॉल्वरीक वॉल्वरीक	28/01/21	वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक	वॉल्वरीक वॉल्वरीक	स्थ.
	2)	R.G. Hosten वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक कॉल्वरीक वॉल्वरीक	R.G. Hosten	3/01/21	वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक काम पूर्ण झाले आहे.	अपघात वॉल्वरीक Athirath 3/01/2021	स्थ.
4/01/21	1)	वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक	Central Research lab.	5/01/21	वॉल्वरीक वॉल्वरीक वॉल्वरीक	अपघात वॉल्वरीक Athirath	स्थ.
5/01/21	1)	R.H.T.C वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक	R.H.T.C Sudumbour.	6/01/21	वॉल्वरीक वॉल्वरीक वॉल्वरीक काम पूर्ण झाले आहे.	अपघात वॉल्वरीक वॉल्वरीक वॉल्वरीक	स्थ.
				9/01/21	वॉल्वरीक वॉल्वरीक वॉल्वरीक काम पूर्ण झाले आहे.	अपघात वॉल्वरीक	स्थ.
6/01/21	1)	वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक वॉल्वरीक	Electric Dept.	3/01/21	वॉल्वरीक वॉल्वरीक वॉल्वरीक काम पूर्ण झाले आहे.	अपघात वॉल्वरीक	स्थ.

Dr. Sitashwat Banerjee
Head, Central Research Laboratory
JNMER Medical College

15/01/21	1) वेसिमिन्स पद्विप दुकान बंद पाठनी कमी जेव लागे.	Radiology Dept	25/01/21	नमिल पार्व वसुधुम देवनात कामा	भागवत गोळे लामाजी शिकीपत्र	SLB
	2) पाठ्याची सुधुम वरच बका येणे.	Radiology Dept.	22/01/21	पाठ्याची रकी सुधुम वरच वरचाम रामाजी.	लामाजी, रामेश रिवाजे	SLB
	3) Room No. 215 मध्ये फिंगरस झोके साहे चवामीन ककात मिवाके	Girls Hostel				
	4) Room No. 201 मध्ये फ्रीडकीची ककात ठेस किने.	Girls Hostel	16/01/21	काम पुलां सामोरे.	शुभेला गारे	SLB
16/01/21	1) डॉल्फिन्स इन्फर्नरीयरीय विपकीने शके काणे	हॉस्पिटल	19/01/21	काम पुलां सामोरे बाहे	लामाजी, रिवाजे	SLB
20/01/21	1) री. रडीगा/21 दोनी pharmane मय का रिवाजे न वरचोय जामि 10 टेबल व 50 सुची नावरो नवेम रवध वरचोय दि 12/02/21 दोनी नवरी करा.	pharmal. Rm	दि 23/01/21	10 टेबल व 50 सुची नावरो देवनात कामा	राशि गाराव न मेवेला रवध	SLB
22/01/21	1) R.C. हॉस्पिटल टिक वरच वरच देवनात मधी.	गॉर्ग हॉस्पिटल	4/02/21	R.C. हॉस्पिटल वरच देवनात सामी.	रिवाजे, रामेश, नजामी	SLB
	2) वॉय सुभर के कनेक्शन जोडुन देणे		6/02/21	नमिल प्रवाळ PIPE वसुधुम देवनात बाले.	भागवत गोळे लामाजी	SLB
	3) वॉय सुभर के वॉम वरच वसुधुम					

दिनांक	विद्यार्थी नाम	तकालीन अवस्था
1/02/21	अपत्याक विभाग	1) संपादन विभागातील वेळीस चौकसपणे होते. 2) संपादन विभाग मधील विद्यार्थी काम फुलवणी करीत होते.
2/02/21	PNC ward No-5-106	विद्यार्थी काम फुलवणी होती. बसणी करवून आली.
3/02/21	Girls Hostel	पवित्रा मजमा उतरी वजु वेळीसचा नकाशा पारत नसत नाही.
4/02/21	Central Council Lab. (कॉन्सिल)	मुलीमम वॉट चौकसपणे झालेले आहे.
5/02/21	PNC ward No-5-106	पेन्सिल वॉटचे व संपादन वॉटचे वेळीस चौकसपणे झाले.
9/02/21	Girls Hostel	1) इतर मजमा, पवित्रा मजमा, विविध वॉट मधील काम फुलवणी झाले. एकरा व कामा वामनिचे आहे. 2) पवित्रा मजमा उतरी व पवित्रा वेळीसचा नकाशा निवेद्य आहे. 3) गेल मजमा वॉटचे PNC चौकसपणे झालेले आहे. 4) मजमा मजमा वॉटचे मधील वॉट नकाशा वामनिचे आहे.

दिनांक	काम पूर्ण होण्याचा तपार्थीम	भाव (बांधणी)	सही
1/02/21	चौकसपणे करवून आणणे	अजून वेळीस	28
2/02/21	विद्यार्थी काम वसविण्यात आली	सुध्दा जाणे	28
3/02/21	काम पूर्ण झाले आहे	सुध्दा जाणे	28
4/02/21	काम पूर्ण झाले आहे. नकाशा विपरीत केला.	संपादन वॉट व पवित्रा मजमा	28
5/02/21	काम पूर्ण झालेले आहे.	विद्यार्थी काम	28
9/02/21	काम पूर्ण झालेले आहे.	अजून वेळीस	28
11/02/21	नविन Aluminium window नमविणार असताना सुद्धे वसवणे काम केलेले नाही (काचा मारणी केलेली नाही)		28
11/02/21	नविन मजमा वसवणे संपादन मजमा	Sutish + Bhagwan	28
9/02/21	मजमा चौकसपणे करवून आणणे	सुध्दा, विद्यार्थी	28
11/02/21	नविन मजमा वसवणे संपादन मजमा	Sutish + Bhagwan	28

10/02/21 Ophthalmology
 1) वैश्विक रोग को दस्तावेजीय
 - वास्तव में है।
 2) ग्लॉबल जेट (पोस्टर) का काम चलाना है
 से निश्चित करना है।

16/02/21 ophthalmology
 2/20/21-20/2/21
 विशेष रूप से ग्लॉबल रोगों की जांच
 सुनिश्चित करें।

16/02/21 female surgery
 ward B-15
 1) पैरेंट रोगियों की जांच करना है।
 2) वास्तव में नोटबुक है।

23/02/21 B-20
 male medicine
 ward.
 1) Bathroom Toilet Floor Net
 working
 2) Bathroom checkup
 3) Window Glass Brackets.

15/02/21 वैश्विक रोग को दस्तावेजीय
 वास्तव में है। 23

16/02/21 ग्लॉबल जेट (पोस्टर) का काम चलाना है
 से निश्चित करना है। 26.

17/02/21 काम पूर्ण करने का है
 सुनिश्चित करें। 25

18/02/21 काम पूर्ण करने का है
 सुनिश्चित करें। 25

18/02/21 नोटबुक वास्तव में है।
 सुनिश्चित करें। 25

24/02/21 ग्लॉबल रोगों को दस्तावेजीय
 सुनिश्चित करें। 23

24/02/21 वास्तव में नोटबुक वास्तव में है।
 सुनिश्चित करें। 25

25/02/21 काम पूर्ण करने का है
 सुनिश्चित करें। 28

3/3/21	Boys Hostel	1) A.C. Water Tank need to be checked.	11/03/21	work done	Maintenance Dept. Ganesh, Suresh	SL
4/03/21	NBCU	2) NCU Changing room window glass broken	1/03/21	Window Glass fixing work done	Suresh Gode	SL
5/03/21	Pathology Dept.	1) There is leakage of tap water in demonstration room	9/03/21	work done	Bluejean Hande	SL
5/03/21	Genwaree Blood Bank	Leakage of wash basin pipe (नियंत्रण)	6/03/21	check-up removed	Adhik	SL
6/03/21	Anatomy Department	Window Glass repair 1) Museum - 02 Nos 2) Histology - 01 Nos	5/03/21	दवा सुंघी केनेली नरि (Aluminum window glass repair)		SL
6/03/21	College Building	Sanitisation & cleanliness of 4th storey room lectare for 4th Maths Exam	6/03/21	work done	Prakash Shinde	SL
6/03/21	Hospital ward 6/18	patients toilet flush is not working small side ward		flush work done	Satish and Bhawan	

6/3/21	girl Hostel	1) First floor tap is leakage 2) reverse water tank needs to be cleaned	7) work done 8) water tank cleaned	Bhagesan Kande Sawaji Sunadi	SL	
10/3/21	Hospital Canteen	in canteen out side of miner of wash basin is check up so be fire needful	11/3/21	wash basin check up done	11/3/21 Kisan Tak Ashok	SL
19/3/21	Boys (Common Room)	work shop from 24 to 26	23/3/21	All arrangement done.	All worked maintenance	SL
22/3/21	Hospital Staff Rom female ortho ward	Staff toilet flush is not working please do the needful	26/3/21	work done.	23/3/21 Bhagesan Kande	SL
24/3/21	College Microbiology DEPT	Leakage from water pipe line	25/3/21	work Done	25/3/21 Sutishu Bhagwan	SL
26/3/21	Staff Rom	B18 Peri Toilet Block check	26/3/21	done for thank	26/3/21 Ashok Walmiki	SL
27/3/21	Girls Hostel	Room No. 307 - ceiling has fallen walls got cracked. need to be repair. Room No - 215 - fungus on wall	27/3/21	This complaint transfer to construction dept for repair		SL

2/04/21	Boys Hostel	Auro plant water tank need to be cleaned.	2/4/21	water tank clean work done	rajasthan harsika	RS
12/04/21	Girls Hostel	Outside of Hostel toilet cleanup	16/04/21	work done	Kishan Tok Ashak	RS
20/4/21	Central Research Lab	Toilet not be cleaned. from few days	21/04/21	work done	Kishan Tok	RS
20/4/21	Central Research Lab.	Near CRL. stacked old files & papers kindly so do useful	22/04/21	files & papers are removed	Maintenance workers.	RS
23/4/21	physiotherapy catage.	New punching machine is provided. is required to be installed to on the wall	23/4/21	this complaint transfer to Carpentry dept.	Satish Mittal	RS
23/4/21	Boys Hostel	Auro water tank to be cleaned	4/5/21	water tank cleaned	All workers	RS
28/4/21	physiotherapy catage.	water bath tap not working properly	28/4/21	work done	Pragyan & Satish	RS

14/5/21	Boys Hostel	Water tank (auto plant) needs to be repaired	work done	14/5/21		
2/5/21	CPG-4 Ward No 10	Window Glass Broken needs to be replaced	Window Glass Not purchased by college order so work Not done			
11/05/21	Girls Hostel	first floor right side passage Reading hall bathroom chulupis water is not coming in tap	17/05/21 work done		Bhagwan Grewal & Satish	AS
12/05/21	Casualty	① Wash basin sink Chockups ② Liquid Soap container Broken	14/05/21 work done 13/05/21 Soap container replace New one		Ashok Wadhai Mahender Charne	AS
18/05/21	C.T.	Hand spray Broken in Staff Toilet = A. e. D.	19/05/21 Hand spray replaced		Bhagwan & Satish	AS
21/05/21	SKM O.P.D.	Demonstration room Basin pipe is expirable	21/05/21 Basin pipe replace New		Bhagwan Grewal & Satish	AS

24/05/21	Gird's Hostel	① Left side toilet flush is not working (1st & 2nd No. toilet)	27/05/21	Call Jaipur Company technician to repair flush & work done.	Satish Sawadkar	SS
		② Room No. 314, water leakage through ceiling.	27/05/21	This complaint transfer to construction dept.		
1/06/21	MHS Exam. College.	Sanitizer & Cleanlines of Lecture Hall & storage room.	8/06/21	work done.	Kisan Raj Parmathkar Shinde	PS
5/06/21	CCL	Patient side toilets check up do need fix.	7/06/21	work done.	Ashok & Kishor	PS
15/06/21	physiology dept.	06 window glass broken. fit new window glass.	21/06/21	Window Glass Not purchased by dept. work Not done.		PS
21/06/21	Room No. B-24	1) Staff Toilet flush is not working. 2) window glass broken do need fix.	28/06/21	work done change all spare in flush. Window Glass Not purchased work Not done.	Satish Sawadkar	PS

25/06/21	Work No. 106	1) Wash Basin pipes needs to be repaired or replaced 2) Electric switch Board not working properly	25/06/21	Basin trap checkup work done	Ashok	AS
25/06/21	Biochemistry Dept	There are lot of red ants in HOD Room.	25/06/21	This complaint transfer to Electric Dept.		SL
25/06/21	Casualty.	minor a.t. outside chik is checkup. do needful		Spraying done in HOD Room (Pest Control)	P.C.L.	SL
			30/06/21	work done	Ashok walmiki	SL

03/07/21	Ward No. 108.	Wash basin tap leakage in patient Toilet)	10/07/21	work done.	Satish Kumar	PS.
1/07/21	Central Research Lab.	Kindly check the tap in Ladies Toilet.	5/7/21	work done.	Ashwan e Sathish.	PS.
5/07/21	Boys Hostel	1) water tank of Auto plant & utility water tank need to be cleaned.	15/07/21	work done.	M. Sathish	PS.
8/07/21	0804/10/108	Patient's toilet tap is leaking	8/7/21	There No tap leakage now	Sathish	PS.
20/07/21	Casualty	Mirror o.f. Basin is broken	24/07/21	work done	Ashak Keshavki	PS.
20/07/21	Casualty	Three liquid containers not working	24/07/21	work done	Madhavi Chaitre	PS.
20/07/21	Medicine Dept.	Dialysis machine & R.O. plant Not functioning will be stop.		R.O. plant ^{mem} membrane replaced work done	Green Enviro	PS.

6/08/21	Anatomy Dept.	Repairing of wash Basin tap in Histo lab. (02 wash Basin tap)	7/08/21	work done.	Shigwan & Satish	SL
3/08/21	Days Hotel	Urine pot is checked up.	10/08/21	check-up removed	Kisan	SL
11/08/21	Food OPD-40	Wash Basin tap is not working properly.	11/08/21	work done.	Shigwan & Satish.	SL
30/08/21	OBG OPD-44	Wash Basin pipe is broken and need to be repaired or replaced	31/08/21	New basin pipe fit in OPD.	Satish	SL
21/08/21	OBG - Ward-108	1) In the labour room and side room ceiling fungus needs to be repaired 2) Wall tiles are broken and need to be repaired or replaced.		This complaint transfer to construction Dept.		SL
				This complaint transfer to construction Dept.		SL

जुलै 2020

8/07/2020 माथको बायो लॉजिस्टिक्स कं.प्राइभेट मध्ये हाथपान वनस्पतिगुण्यी कावापानी कापडोको आदि.

06/07/2020 OBS. W.B. 108 Clinic Room मधुन बाथरूम मधुन पाणी निकाले होने, ते निकाले काढ्नुन दिने.

7/07/2020 का.मा.का.ला.जि. कं.प्राइभेट मध्ये अगिड लड्का दिने.

10/07/2020 PNC work मध्ये अि.मि.मि. स्टाफि लभकुन दिने.

13/07/2020 OT मध्ये स्टाफ अचानक राम बुकको कोने

15/07/2020 MSW का work लभकुन पडिप बढ्नुन दिने

16/07/2020 PNC - 106 मध्ये ले.सि.मि.को चोकरण काढ्नुन दिने

16/07/2020 work बिचमा नो डिफेन्स काढ्नुन दिने.

17/07/2020 सी.सी.एन मधील बाथरूम ले.सि.मि.को चोकर अण काढ्नुन आदि.

17/07/2020 PST work मधील बाथरूम ले.सि.मि.को का.डि.

20/07/2020 लेडीज हास्बेन को रिडकोमि, क.का.प, ल.सि.मि.मि.

23/07/2020 लेडीज हास्बेन 2 मडा का.प.को मधमा.का.प, पा.के का.डि.के

27/07/2020 रेसिडन्ट का.डि.के (हा.मि.के) मधमा.का.प.को का.डि.के

24/06/2020	OBS ward નીચીની બાજુ મધ્યે સર્જિકલ ડિવિઝન બાંધે
24/06/2020	ગાલિ હોસ્પિટલ રૂ. નં. 124 મધ્યે કોમ્પ્યુટર બાંધવાની બાંધ
25/06/2020	OBS - 108 clinic Room મધ્યે ક્લિનિકલ ડિવિઝન બાંધે
25/06/2020	OBS ward નં-108 મધ્યે નવું બંધાવવાનું કિલ્ડા.
26/06/2020	MMW-16 મધ્યે નોન-સ્ટ્રીક બાંધવાનું કિલ્ડા.
29/06/2020	ગાલિ હોસ્પિટલ નિમજી મજાલાલ જુલુકની ડાકી બંધાવવાનું કિલ્ડા.
29/06/2020	કાર્ડિયો હોસ્પિટલ રેપીડ સર્જિકલ ડાકી બંધાવવાનું કિલ્ડા.
30/06/2020	PNC ward - 106 મધ્યે ડાકી નં-2 નોન-સ્ટ્રીક બંધાવવાનું કિલ્ડા. વોશ બેસીન બાંધવાનું વાટિયું વ ડ્રેસિંગ ભાગિયું બંધાવવાનું કિલ્ડા.
30/06/2020	RHTC સ્ટુડન્ટો ચેમ્બર બાંધવાનું ડાકી સ્વચ્છ બાંધવાનું કિલ્ડા.
30/06/2020	PNC ward મધ્યે નોન-સ્ટ્રીક બંધાવવાનું કિલ્ડા.

05/05/2020 लेबर रुम मध्ये सिडफिकेशन धार लाडलु दिने.

28/5/2020 कॅन्सलरी (B.1) मध्ये फोल्ड कोशक लाडले.

01/06/2020 जून 2020 मरवाते रानलेडीक (लाडलीक) पेपर शालेण.

1/06/2020 PNC-106 मधील टोयलेट कोशकय लाडलु दिने.

04/06/2020 ICU मधील रिसलरी लाडलु वसवुन दिने.

4/06/2020 OBGY OPD मधील रिसलरी लाडलु वसवुन दिने.

04/06/2020 अयथान विभागातिले X-RAY मध्ये रिकेड शालेण दिने. रिकेड लाडलु दिने.

02/06/2020 PNC WARD-106 मध्ये रिसलरी लाडलु वसवुन दिने.

06/06/2020 OBC WARD मध्ये वॉश बेसीणय पडिय वसवुन दिने.

07/06/2020 RHTC सुवर्णे येथील मेथरिड, वेरी, लाडलु दिने.

15/06/2020 मिडिल कोरी बाहेरीक बेसीणचे कोशकय लाडलु दिने.

15/06/2020 रिकेड टोयलेट रिकेड टोयलेट मध्ये वसवुन दिने.

16/06/2020 PNC-106 मधील 2 रिसलरी लाडलु वसवुन दिने.

16/06/2020 PNC-106 मधील बेसीण पडिय व कोशकय लाडले.

24/06/2020 OBG WARD-108 मधील 2 मळ वसवुन दिने.

मे 2020

1/5/2020	PSY wafar मधील स्टाफ रायलेरचे नोकरीतून काढणे विवि.
4/5/2020	FMW ऑडि मधील स्टाफ रायलेरचे नोकरीतून काढणे विवि.
8/5/2020	MMW wafar बाथरूम नोकरीतून काढणे विवि.
12/5/2020	ICU मधील डॉक्टर कम रायलेरचे नोकरीतून काढणे विवि.
12/5/2020	MMW वरि क. B. 20 मध्ये वेसिगनचे पडिय बदलणे.
14/05/2020	सेक्टर 2 मधील टिकेस काढणे विवि.
15/05/2020	लेडीज हॉस्टेल मध्ये रंग वाटणे होऊ लागणे विवि.
15/5/2020	आयडान किबागा मध्ये बाथरूम वुनने व नोकरीतून काढणे विवि.
15/05/2020	लेडीज हॉस्टेल कम नं. 225 मधील काढणे वसतिग.
15/05/2020	ICU मधील डॉक्टर कम मधील नोकरीतून काढणे
18/05/2020	अनाथालय किबागा मधील म्युझिक मधील 2 नोकरी वसतिग दिव्य.
21/5/2020	OBS-108 मधील वेरि 2 बाथरूमचे नोकरीतून काढणे.
21/05/2020	TimeL PSY मधील नोकरीतून काढणे विवि.
21/05/2020	लेडीज हॉस्टेल किबागा मधील वेसिगन, बाथरूम मंडास व्हेरि 2 मध्ये काढणे विवि.
22/05/2020	लेडीज हॉस्टेल मध्ये गवडी काढणे वसतिग विवि.

10/4/2020	केडीएस हासिल मस.म. 307 मध्ये काढावसुक्त दिले
18/4/2020	केडीएस हासिल मध्ये मध्य मंत्रालये पाठव काढले.
20/4/2020	MSW वॉर्ड नं. B.20 मध्ये रिजल्टिंग काढा वसुक्त
26/4/2020	0BS-108 Doctors-Room मध्ये रिजल्टिंग पाठव वसुक्त काढले दिले.
23/4/2020	MMW वॉर्ड मध्ये काढा वसुक्त काढले काढले.
23/4/2020	FMW वॉर्ड मध्ये केसीएम कोलकात्या काढले.
23/4/2020	B.207- काढा मध्ये कोलकात्या काढले दिले
24/4/2020	केडीएस हासिल मध्ये काढा मिळाल्या पाठवले 21का दुरु कर दिले.
25/4/2020	22का काढले मिळाल्या पाठवले 21का दुरु कर दिले
27/4/2020	FMW - B.15 केसीएम हून कोलकात्या काढले
28/4/2020	male psy ward मध्ये काढा काढले काढले
28/4/2020	केडीएस हासिल केसीएम काढा काढले वसुक्त दिले

27/3/2020 ICU मधील काऊन्सिलिंग लिकेड/ काढून दिले

27/3/2020 लॅडीज हॉस्टेल येथे वेसीनग/ एक बसवणूक दिली

27/3/2020 MMW वॉर्ड मध्ये 2 नऊ बसवणूक दिली

30/3/2020 लॅडीज हॉस्टेल रं. म. 307 मध्ये सिगरेटचे लोअर काढून दिले

30/3/2020 ICU मधील वॉर्ड वेसीनगचे काढून काढून दिले

एप्रिल - 2020

1/4/2020 OBS लॉवर - 108 मधील कोणत्या काढून दिले

1/4/2020 FMW वॉर्ड मधील फ्लोअर काढून काढून दिले

4/4/2020 MSW वॉर्ड मधील कोणत्या काढून दिले

6/4/2020 106 PNC ward मधील हॉस्टेल कोणत्या काढून दिले

7/4/2020 FMW वॉर्ड मध्ये सिगरेट पाडिय बसवणूक दिली

7/4/2020 लॅडीज हॉस्टेल बुकरन/ नविक पाडिय बसवणूक दिली

7/4/2020 लॅडीज हॉस्टेल एक बसवणूक दिली

8/4/2020 FMW वॉर्ड वेसीनग कोणत्या काढून दिले

10/4/2020 लॅडीज हॉस्टेल माण्यार/ शाकीय काढून दिले

मार्च 2020

- 2/3/2020 कोडिंग एंसेबल मध्ये कोडिंगचे वेगवेगळे मॉडेलिंग करणे व सर्वोत्तम काम काढणे दिवस
- 3/3/2020 ICG मधील कोडिंगचा परिपक्व बनवणे व सर्वोत्तम दिवस.
- 4/3/2020 कोडिंग एंसेबल क. नं. 307 मध्ये रिडबिलिटी, व्याख्या व सर्वोत्तम दिवस.
- 4/3/2020 0B67-188 मध्ये कायदा मधील कोडिंग परिपक्व करणे
- 4/3/2020 कोडिंग एंसेबल मेम (कोडिंग) चाकी घुमणे दिवस.
- 4/3/2020 PAC मधील दरवाजा रेजिस्ट्रार कारणी व सर्वोत्तम दिवस.
- 4/3/2020 कोडिंग एंसेबल मेम (कोडिंग) चाकी घुमणे दिवस.
- 5/3/2020 PAC वॉर्ड मधील रिडबिलिटी व्याख्या व सर्वोत्तम दिवस
- 5/3/2020 कोडिंग एंसेबल मेम (कोडिंग) चाकी घुमणे दिवस.
- 6/3/2020 कोडिंग एंसेबल कायदा कोडिंग काढणे दिवस.
- 6/3/2020 कोडिंग एंसेबल कोडिंगचा नव्व व सर्वोत्तम दिवस
- 7/3/2020 कोडिंग एंसेबल मधील कोडिंगचा नव्व व सर्वोत्तम दिवस.
- 9/3/2020 FMW - B.22 मधील रिडबिलिटी व्याख्या व सर्वोत्तम दिवस
- 9/3/2020 07 मध्ये कुादी सुट्यामुळे कोडिंगचा नव्व व सर्वोत्तम दिवस
- 9/3/2020 कोडिंग एंसेबल मध्ये उद्योग होऊ व सर्वोत्तम दिवस

फरवरी 2020

- 13/2/20 वि. वि. एन. मेमोरिअल आडिवर फरवरी के दि.
- 13/2/20 फोरमेटो मेडिसिन वॉर्ड मधिल रायलेट नोकशप काइंग दिदि.
- 13/2/20 ICU मधिल डॉ. बेसिंगन्या नोक बदलुग दिदि.
- 14/2/20 T.B. वॉर्ड मधिल लेबररी कॅन्टिन व गार्डि कॅन्टिन PSY वॉर्ड मधिल लावुग दिदि.
- 17/2/20 काइंग हास्पिटल कावर के काम परीक्षा काइंग व बेसिंगन्या नोक बदलुग.
- 17/2/20 लेबररी मधिल रायलेट नोकशप काइंग नोक दुकली काइंग दिदि.
- 18/2/20 FMB 221 मधिल रायलेट मधिल नोकशप काइंग दिदि.
- 18/2/20 लेडीज हास्पिटल मधिल काइंग लावुग दिदि.
- 19/2/20 लेडीज हास्पिटल मधिल मेस मधिल उदिर धुआंका मावमिण डाल, होला न्याकावर उपय आडिवर के ली आदि.
- 20/2/20 MAMW वॉर्ड मधिल नोकशप काइंग मिताव
- 20/2/20 OT न. 11 मधिल वॉर्ड बेसिंगन्या नोक बदलुग
- 20/2/20 22/ नारवका रजामि डिपार्टमेन्ट काइंग के दि.
- 22/2/20 लेबररी मधिल बेसिंगन्या पाइंग बदलुग दिदि.
- 24/2/20 ① OBS - B - 108 नोक नोक बदलुग दिदि.

21/1/20 ICU मधील मॉनिटरिंग चोकरे उपरो
ने काढून दिले

21/1/20 डॉक्टर डॉक्टर मधील पोथी जोडाय
लोने ने काढून दिले

21/1/20 ICU मधील वेसीगना तळ रिकेज लोना
ने सुरवात करून दिले

27/1/20 ICU मधील डॉक्टर जोडाय काढून
दिले.

26/1/20 डॉक्टर डॉक्टर मधील कम व 7 मध्ये
कपात करून वाकवी होनी न्यायन डॉक्टर माकन दिले

24/1/20 डॉक्टर डॉक्टर 20 लकी साफ करून
दिले

23/1/20 ICU मधील मॉनिटरिंग जोडाय लोने ने काढून
दिले

28/1/20 डॉक्टर डॉक्टर सर्व मेन्टल करून दिले

30/20 डॉक्टर डॉक्टर मधील पाइप मधील
पाणी रिकेज लोने ने काढून दिले.

15/1/20 लडोग होस्टेल लॉन्गवेर बायकम मध्याह्न पाणी
लिकेन होमो ने दुसरा ककन दिसे

13/1/20 लडोग होस्टेल मध्याह्न कम नं 115 कपाटीचे
काम ककन दिसे

15/1/20 लडोग होस्टेल मध्याह्न बायकम 110/111/
112/113 लिकेन होमो ने काढून दिसे.

16/1/20 28 जानेवारीला स्टेडो वदन केले

17/1/20 लडोग होस्टेल नमनगळ बायकम चोकडाय
होमो ने काढून दिसे

18/1/20 सर्व स्टाफांनी आरोग्य तपासणी ककन
होमो आहे.

18/1/20 हा मध्याह्न सर्वांनी विसात दिसे.

20/1/20 TCU बायकम चोकडाय काढून दिसे

21/1/20 लडोग होस्टेल चोकडाय काढून दिसे

22/1/20 लडोग होस्टेल 2 मजान वरील जॅल -
कसपा नीर होमो नी दुसरा ककन दिसे

21/1/20 PMW मध्याह्न बायकम चोकडाय
होमो ने काढून दिसे

21/1/20 वार्ड नं 108 मध्याह्न बेसिंग पाडय
खराब होना ने दुसरा ककन दिसे

21/1/20 रेसिडेंट डॉक्टर मध्याह्न कम नं 8
बायकमळ विमेट वगळून दिसे

1 जीववारी 2020

7/1/2020 - OPD मधील 108 नं मधील व्यायाम मधील वेसीन पाइय रुग्ण आहे ~~काम करत असून~~ काम करत आहे, नो डुरस करत दिव आहे,

7/1/2020 - NICU चा व्यायाम मधील वेसीन - पाइय रुग्ण होना नो. असून दिव आहे,

8/1/20 108 नं रबर कम मधील डॉक्टर रिजेज होना नो रुग्ण करत दिव आहे.

7/1/20 - मेडिकल कॉलेज - मधील वेसीन टॉप डुरस करत दिव

9/1/20 कॉलेज मधील वर्कशॉप कामकाज साठी टेलर रकमी करत दिव

10/1/20 Patil's ward मधील वॉयलेट चोकडाय होना नो काढून दिव आहे.

11/1/20 आश्रम मेडिकल कॉलेज वॉर्ड मधील व्यायाम चोकडाय काढून दिव .

12/1/20 Finlay ward मधील वॉयलेट चोकडाय काढून दिव

15/1/20 लेडीज हॉस्पिटल मधील गळमजान सोकर चोकडाय होना नो डुरस करत दिव

16/1/20 ICU मधील ब्रिडकीची काय रुग्ण होना नो असून दिव

14/1/20 NICU मधील वेसीन चोकडाय होना नो काढून दिव

19/9/19

रेसीडन्स. क्वार्टर. क्रम. नं. 2 मध्ये टॉयलेट, नळ. श्वाभ. आदि. होला. लेखक लावडतोष. वसकुन. होथाल. आदी -

23/9/19

कॉडिज. होस्टेल. 1) लिसरा भजवता. डिवी बापु - टॉयलेट, चोकअप होल ले चोकअप. लवकर किवा लावडतोष काडुन दिवो -

2) लिसरा भजवता. डिवी बापु 2 वेसिन चोक. चोकअप. आदि. होले काडुन दिवो.

3) पडिंका भजवता. डिवी बापु 3 न. टॉयलेट चोकअप. होल ले चोकअप. लावडतोष करणार आदि.

25/9/19

m. ophum s f. ophum (308 & 309). ward भित्तीचे होल. वेदकेशन. आदि.

28/9/19

कॉडिज. होस्टेल. रेडींग हॉल. रिपडकीची काय. फुटकी आदि ती लवरीत. काय. वसकुन. होथाल. आदी -

2) कुमरा भजवता. डिवी बापु. वेसिन. चोक होल ले चोकअप. काडुन होथाल. आदि -

9/9/19. वाइज. हेकरेक. मध्ये. एकठा. 15 मिडकीच्या. काचा. फुटकेल्या. होत्या. त्या. काचा. लावून. लोव वसतुन. देण्यात. आल्या किवा हिल्याजाई

9/9/19. C.C.B. मधील किवा. वाइजो. इ. मध्ये. चेवर. ठीकठाके अडे ते स्वरील. कामकरण. देण्यात. आले -

9/9/19. P.m.u. B. मधील मिडकीच्या. काचा. फुटकेले होत्या. त्या. लोवकराल. लोवकर किवा. लावडलाव वसतुन. देण्यात. आल्या - किवा दील्या.

10/9/19. Bochami st. मधील लोवरी. च्या स्वरील. च्याकाचा फुटकेली होती ती काचा. वसतुन. देण्यात आली -

10/9/19. गळ हेकरेक. मधील. पिण्याच्या. पाण्याच्या. - 3 टाक्या. लसच. वापरण्याच्या. पाण्याच्या. टाक्या. 1 टाकी स्वरीकरण. देण्या. आल्या -

10/9/19. वेडीज हेकरेक. मधील पिण्याच्या. पाण्याची. मशीन. मध्ये पाणी टाकून. सुरक्षित. लोवात. ती. मशीन. लावडलाव सुरक्षित. करण्यात आली.

11/9/19. Kobow Room. मधील. नळ. ठीकीज. होत. होत्या. ते लोवकर. काम करत. देण्यात आले.

16/8/19. 1) मथिला. स्वच्छता गुरु. दरवाजे बरबाद शब्दों
आमतौर पर व्यवस्थित बदलते हैं. ले
सावधानी. इसमें करण. देखा. आते.

~~17/8/19~~
17/8/19. Infront of gym of. wash बेसिन.
वदकाल. वदकाल वदकाल. देखा. आते.

17/8/19. windows. glasses फिरोज. करण देखा.
आव्या -

21/8/19. लेडिज. होस्टेल. मध्य लीसरा मजदूरी व.म.
309. समीर महाराज. पोली आते लीसरा.
लावडाली. लेमहाराज. पोली. काहुम.
देखा. आव्या -

22/8/19. Caswell. चा. एका. टॉयकेट मध्य -
आणि इसथा. टॉयकेट. गळ. वसतुम. देखा.
आव्या.

23/8/19. लेडिज. होस्टेल. लीसरा मजदूरी. पोली.
काहुम. देखा. आव्या -

23/8/19. कोलीनीक. व.म. वायव्य मध्य मळल होल
से पाणी लावडाली वदकाल. आते -

26/8/19. मो. उ.म. मथिल. टॉयकेट वलक.
काहुम. देखा. आवेक. आते किवा विले.

2) डावी वाड्डि वेसीन 2 काचा वसतुन
देव्याल आख्या -

3) उजवी वाड्डि वेसीन 4 काचा लुदेकर्या
दोया ल्यापण काचा तावडनी व वसतुन
देव्याल आख्या -

1218119 0 B-S 108 मधील लॅबेसम वसतुन
वेसीन पादि तावडनी व
वसतुन देव्याल आख्या आदि -

1218119 montho 302 मधील डिककोरीन वसतुन
मधील पावलाचा वसतुन देव्याल
कडून देव्याल आख्या -

1318119 गळ हाँक्रेट मधील जीम वसतुन
2 काचा वसतुन देव्याल आख्या
हाँक्रेट मध्ये 4 काचा वसतुन देव्याल आख्या
आदि.

4 कुंसा मजळ्यावर डावी वाड्डि - वेसीन
वसतुन 3 काचा उजवी वाड्डि वेसीन
वसतुन 2 काचा आशा 11 वसतुन 5 काचा
वसतुन देव्याल आख्या आदि

141119 गळ हाँक्रेट लोसना मजळ्या डावी वाड्डि वेसीन
वसतुन 4 काचा आशि उजवी वाड्डि वेसीन
वसतुन 4 काचा आशा मजळ्या 8 काचा
वसतुन देव्याल आख्या -

29/7/19. Cosplay. X-RY Room. मध्ये पाणी-वाजो-
पावसातुळे पाणी साखले होते ते वासकरण
देण्यात आहे आहे

29/7/19. एकसेर. विमानातील. पाणी गळत होतं.
आत पळवले पाणी बाहेर काढून. ते काम
कश्या. आहे

30/7/19. Masw B-204 मध्ये पेशेचे. टॉयकोट. लसख.
बेसीन. चकपप. साखले. होतं.
ते वासकरण. देण्यात. आतं.

31/7/19. बेसीन. बेसीन. टॉयकोट चकपप. साखले.
ते वासकरण. देण्यात. आतं.

2/8/19. kindly arrange for their replacement
office. (HODS). window glass in. pham
log 7. Depchamru.

3/8/19. 1) कॅडीन. होस्टेल. रूम: न. मध्ये कपाटमध्य.
पाणी गळत. होतं ते पाणी नावडनाव बंद.
करण. देण्यात. आहे -

2) दुसरी मजला. बाय रूम. पॅसेज. गळत आहे
तरी लगेच काम करून देण्यात.
आहे आहे

3) कॅडीन. होस्टेल. बाय रूम. पॅसेज. मध्ये गळत.
आतळ्या. पुढे ते पाणी नावडनाव बंद.
करून द्या

28/6/19. गश्तारे. वकसुपेडी मधील. स्टोअर रुम. मधील. पत्रावली पत्रकारिक. कागद टाळुन. दिली. आदि.

1/7/19. मिसु B-204. व्या. पाहो. टायलट. वरुम. मधील. वेसीन. पाडप. खराब झालेला. होला. ते ताबड ताब वसवीव्यात. आला. दिला.

2/7/19. वाई वेसीन. खचंवर पाण्याने लॅक झालेला. ते ताबड ताब वसवीव्यात. करून. देण्यात. आला.

2/7/19. मिसु no. B.206. मधील. गीशर बंद झाला. होला. ते लवकरात. लवक वसवुन. दिला.

3/7/19. ~~सख~~ सर्जरी ओपेडी वाई वेसीन. खराब. झाले. होला. ते काम. करून. देला.

3/7/19. लॅडिज. डोरहेल. पहिला. मजला. डावी बाजू. वेसीनच्या. नवा खाली पाडपचे पाणी टिपकास. आहे. ते काम. करून. देण्यात. आला.

2) टाकीपाडप. लकीच्या. पाडप. लकीज. होला. ते पाडप. बदलून. दिला.

4/7/19. रेवेन. वरुया. पाडपाला. एम सील लावून. देण्यात.

1) मुक्ति. मजला. वेसीन. पाडप. लकीज होला. ते पाडप. जोर करून. देण्यात. आला.

19/6/19. वेंडिज. हॉस्पिटल. 2 सुनरा मजदारी. 2 सुनरा मजदारी. वरतुन. दिला आहे

1. पीण्याच्या. माण्यासाठी नळ. वरतुन. देण्यात आला. किरा. दिला.

27. कामगार

3) गीशर. नळ. खराब झालेला. होला. पत्र. वरतुन. दिला आहे.

4) उजवी. भांडी. वापरून. 1 वेसा. नळ. वरतुन. दिला.

5) पायीमागे झड्डे वापरून पाणी पेटवत. खराब झालेला. होला. ते वाळ. वरतुन. लवरी दिला.

20/6/19. वेंडिज. हॉस्पिटल. निमरा. मजक्यावरील. 2 न. #37 मध्ये हेतुन. झाले आहे. लरी औषध. मासून. लावडतोव होयात. आलेले आहे

20/6/19. लॉन्ड्री यंत्रा दिनाच्या. कार्यक्रमासाठी लॉन्ड्री मधुन. पांढर्या. रंगाच्या. 30 वेडसा. र्या. जमाकरण. देण्यात आला.

20/6/19. योन. दिनाच्या. कार्यक्रमासाठी 10 न. सतरंजी नोन. वेडसा. कार्यक्रम. झाल्याने ल. लावडतोव जमा करण्यात आला. किरा. दिला. 4.

24/5/19 राजी वरवादे रमल पेदी येथे होल वॉशिंग
मळ वसतुन देण्यात आले.

25/5/19 Fmw B.m. मधील टॉयलेट मधील रमल
साप येवता तेथे खाडकीचा काचा लावून
व वसतुन देण्यात आला.

27/5/19 टॉयलेट मधील वॉशिंग मळ
होला ते वसतुन देण्यात आले.

27/5/19 ओरी लीक जॅक वसतुन देण्यात आले.
साप जॅक वसतुन देण्यात आले.

28/5/19 पर्सनल डोंड पर्सन वसतुन देण्यात आले.

29/5/19 Fmw B.m मधील टॉयलेट मधील
मळ वसतुन देण्यात आला तेथे खाडकीचा
वसतुन देण्यात आला.

30/5/19 Fmw B.m मधील टॉयलेट मधील
वसतुन देण्यात आला तेथे खाडकीचा
वसतुन देण्यात आला.

14/5/19 Bhat, अरी समरीत. नकी वसिम
स्वध करन देव्यात आता -

15/5/19 मेरु मेडीसिन वार्ड न: B20. मधील 2
मिडकीची काचा, लोवण्यात आल्या -
किवा. वसवुन दिला -

16/5/19 1) न: लील अरी समरीत. वार्ड वसिम
स्वध श्वेतरी पाइप. लीक होला हा -
पाइप लवकशाल लवकर ली वदत आल्या.
आता -

16/5/19 I: फोर B:307: वसिम. वेद आता होला.
ले लवकशाल लवकर चालु करून दिला -

16/5/19. लेडिज. हॉस्टेल. डार्विसाडि. टोकी वातवद
लेपण काम करून. देव्यात आता -

17/5/19 पहिल्या. मजलगावर डिजव्या. मीडि वसिम
मिशर्या. मळ लुलगा. होला ले लोडलेला
वसवीव्यात. किवा. लवकशाल लवकर वसवुन.
देव्यात. आता -

20/5/19 Reor गिज madam. फिरा B2 मधील.
हॉस्टेल मधील. मळ होला. ले का करून.
देव्यात. आता -

11/11/19. डॉकरीया. टॉयकोर मधील. रावलीकरना
होयान. आली किल. होयत.

11/11/19. Fm w विकडक्यांना. पाळ्या. वसुधुन. लाड
लाव. किल. लाकरान. वडाकरना
करन होयान. आले आहे-

12/11/19. टोवी वॉर्ड यःकिरेड पाणी येलना 1130
नगीशला. वॉर्ड मधुन. पाळीयेल. 2450
काम करण होयान. आले.

13/11/19. RT C.S.S. डॉ. मधील. र्वाडक्यांना निमंर.
या पाडीशलाला. मध्य मध्य पिरा पडक्याशोन.
मधुन. काम शारके आहे?

16/11/19. Ophthal. warral.
1) मधील नळ. आली बेसी न. पाडु, वसुधुन.
ल होयान आली. किल दिला

ग्रीष्मः. f. orthal. ... ये वसिष्ठ या चकार
आदि. होत ते कामकरण लावडलाव.
होयत. आले आहे.

ग्रीष्मः. आमिशाल. धुमि. मधुमि. वलशुभ.
मधुन. पाणी पुढीपणे. येत होत. पाणी
लावडलाव श्रवण. करण. होत.

ग्रीष्मः. लीण. टोंयला परीची कामकरण. होयत,
आक्याआहे.

ग्रीष्मः. Babroon. अर्धमधुमि. वसिष्ठ. नं. शरव.
आदि. होला-लकी लेखक.
लावडलाव. वदुम. होयत. आले. किया,
दिला.

ग्रीष्मः. लीण. होस्टेल. तिसरा. मजक्यावश्या.
टोंयले. चानल. वदुम. होयत. आले.

ग्रीष्मः. लीण. होस्टेल.
C.F. मजक्यावश्या. वलशुभ. मधुमी. आ.

2/4/19. अनासमी विभागाभयार्थ. सिडकीया. काच. वडुण. ह्यथल. आलेलेया. उाशे.

- 1) मुंशिबम. - 03. चवामकर ह्यथल. आले -
 - 2) कक्यर होत. - 1. लावडलाव केत.
 - 3) डि. 2. 2. क. 1. " " " "
 - 4) लोप्रो. ज. टॉयलेट. च चकाप. काडुन. ह्यथ.
- आले उाशे.

2/4/19. ज लीले. टॉयलेट. मधील. वाई. वेमीन. नलाया. पडिप. खराब आलेले होला ली. पडिप. लावडलाव. वडुण. ह्यथ.

4/4/19. म मस ड. वीलेयु. टॉयलेट. वेमीन. चकाप. आले होत ले वेमीन. चकाप. काडुन. ह्यथ.

4/4/19. मीले. मेडीसीन. वाई. मधील. नळ. खराब आलेला. होला. ले नळ. लावडलाव वडुण. ह्यथ. आशे. -

27/3/19

27/3/19 मूळ. लावडा व गोवर्धना - मीठ
येथील करीत कोरले. आले.

29/3/19

29/3/19 मूळ. B 205 . मधील. पीडी डिझीन .
करे आले ते येथील करीत. देणाल आले.

1/4/19

1/4/19 psy. ward. येथे येथील. लावडा व गोवर्धना
देणाल. आलेले आले.

1/4/19

1/4/19 गळी कोरले. लीसा. मूळ. डी. वी. साईड
येथील करीत. मधुम. पाणी टिपिलेले
ते लावडा व गोवर्धना वरून. देणाल आलेले
आले.

2/4/19

2/4/19 3rd वेरिन. या. पाईप. लावडा
येथील करीत. आलेले करीत
येथील.

19/2/19. D. wd. no-108. मधील वाड्यातील पेशे
 वाड्याचे भितीतून बुरशी आलेली आहे.
 लस काम व्यवस्थित पणे पुढे आलेले आहे.

20/2/19. मेल. मंडासान. वाड नं. व! 28 मधील
 'बायश्म' वळीक आली आहे लस ले.
 काम पुढे पणे करून देण्यात आले.

22/2/19. OBgy B/6 मध्य दोन खुवा लस ले.
 काम पुढे पणे केले.

22/2/19. RICUN चे 'रायलेट' चैकअप. आल्यामुळे
 ल काम लवळ तोव काम करून दिले.

27/2/19. ~~मंडासान~~ डायरी मे. 2
 वाळी होस्टेल. सुवात. ① पिण्याच्या पाण्याच्या
 वाळीत व वरील पाण्याच्या टाक्या
 स्वच्छ करून देण्यात आल्या.

12/2/19 MS R OPHW. wored. Hedi. Hedi.
 12/2/19 MS R OPHW. wored. Hedi. Hedi.
 12/2/19 MS R OPHW. wored. Hedi. Hedi.

15/2/19 Request to. entymg and diming farm.

16/2/19 im. Diet. w. 2019. we. are phamg. ta. yun.
 Ram 18'02'2019.

16/2/19. 16/2/19. 16/2/19. 16/2/19. 16/2/19.
 16/2/19. 16/2/19. 16/2/19. 16/2/19. 16/2/19.

18/2/19 male medicine. 18/2/19 male medicine.
 18/2/19 male medicine. 18/2/19 male medicine.
 18/2/19 male medicine. 18/2/19 male medicine.

18/2/19. 18/2/19. 18/2/19. 18/2/19. 18/2/19.
 18/2/19. 18/2/19. 18/2/19. 18/2/19. 18/2/19.

- 11/2/19. रीडिंग हॉस्टेल
1. लकड़मजदग. डुपवा साईट बेसींग शालया. पारि. शरारत साईटला आदि ले करीन ले काम करण दिवले
 2. पहिला मजदग. डुपवा साईट. शॉयलेट नळ. शरारत साळला होला लेपण. व्यवस्थापक दिवला.
 3. दुसरा म. बेसींग. मळ. शरारत होला. लेपण. कामकरण दिवले.
 4. रीडिंग हॉल. शॉयलेट. नळ. बेसींग व. ले आम्ही ले नळ बदळण दिवले

In the dept of Anaesthesia basin-
 leakage isolate. S Bathrooms tap is used
 leakage so pipe repair. yagamb
 लेकण. करण दिवले

11/2/19 NICU मधील wash Basin शरारत. साळला. होला. ले ताळतावे. बदळण दिवला -

2/2/19 B.S.N.R. h. wd. - 108 मधील पेशा. वायव्यम चौकअप. काडून मिळावे ले ले ताळ तावे कामकरणात आले.

22/11/19 Bathroom. Blockage removed. cleaned

22/11/19. Health inspection. visit to B. 20. Health
inspection. work done.

23/11/19. FmW B 2n. work. Health | cat. work.
work done. work done.

23/11/19. Female. Psy. ward. work.
work done. work done.

23/11/19. CmF. om. women's dat on 07 march
/2019.

24/11/19 of files All official procedure form
for files (year 2020-2011) was done.

दि 15/11/19

m.g. का.पु. 205. रॉबर्ट रीमिंग्टन का
अ हीरो

दि 16/11/19

ICU. मेडिकल. डिवी. फोरमलिन. चिकित्सा केंद्र
अच्छे रिपोर्ट. मरण. देते.

2. S पेक्षा जास्त. बाद रॉबर्ट रीमिंग्टन का
मरण दूसरे बेड लावसलो दिले.

दि 17/11/19

मेड. मेडिसीन. वॉर्ड मध्ये पेशेंट रूमा.
दौलती ये प. मेल. खराब झाले होते
ते लावड लाव लयाव मरण दिले.

दि 18/11/19

ome. Karthi Sem. in. ch. 1002 to amol
Ragh. Rine to the. ekedy, do. the
man. मरण. दिले.

दि 21/11/19

waich. basring. अशुभ. हेने आडे तर
लावड लाव बेसीन. लवकशाल लवकर
दिले.

31-08-18	बॉइज कॉरिडोर	Regarding The layout around basket ball Court for drainage of Water
31-08-18	बॉइज कॉरिडोर	Regarding the cleaning of basket ball ground Respected sir
31-08-18	बॉइज कॉरिडोर	Regarding the cleaning of Auditorium Respected sir
03-09-18	बॉइज कॉरिडोर	Regarding the borrow of Bamboo for making of football goal post
04-09-18	लेडीज कॉरिडोर	लेडीज कॉरिडोर रूफ क्वार्टर शर्ब बापुने ओषधाची फरमावणी करून मिळाले.
04-09-18	वॉर्ड नं 6	मधील पेशंट टायलेट चोकअप आठे कपरा चाकक्षप काढून मिळवा.
04-09-18	वॉर्ड नं 7	मधील पेशंट टायलेट चोकअप आठे लरी ले चोकअप काढून मिळवा की विनती
04-01-18	वॉर्ड नं 15	मधील Nurses Room मधील लावकरात गळ Leak आठे लरी कपरा लो लावकरात लवकर गिठ काढवा

1/06/18 मेडींग होस्टेल. देसवरीक R.O. ची टाकी घुपुत वरवीक कळत देखात यावी.

2/06/18 वॉर्ड नं. 7 मध्ये तखीड्यांच्या काचा व फुटकेच्या आंके वसयुत मिळावताना

4/06/18 मेडींग होस्टेल. पिण्याच्या पाण्याची टाकी घुपुत वरवीक कळत देखात यावी.

5/06/18 वॉर्ड नं. 7 मेडींग होस्टेल. तिसरा मजाना कमरं. 309 मध्ये दाना मधुन पाणी मिळत आहे.

5/6/18 वॉर्ड नं. 7 मधीक तखीड्यांच्या काचा फुटकेच्या आंके.

6/06/18 मेडींग होस्टेल. देसवरीक पिण्याच्या पाण्याच्या टाकीक लोखंडी खिडी व R.O. च्या टाकीक तुट्या खिडी वसयुत देखात यावी.

6/06/18 म. O. W प्रॅक्टिकल डॉक मधीक तखीड्यांच्या काचा फुटकी आहे. तसेच प्रवर्तका व्हाटी कचिच्या पट्या तयार करत देखात आहेत.

6/6/18 M.O.W 24 वॉर्ड नं. 24 Staff Railed ने वायकत चौकल्या हाकेचे आहे.

9/5/18 पॉलीग्रेड ॥ १२वीं कक्षाची काय - फुल्लेकी आहे. ती बसू देण्यात येणारी.

11/05/18 सुनिवृत्त डॉक्टर ॥ करिभट गायकुमर प्रोग्राम साठी एक मधीक 5. Lecture Hall देणे.

- 14/5/18 मेडीज डॉक्टर ॥
- 1) कम नं. 308 मध्ये - 1 काय
 - 2) निखरा मजमा बेसीक वरीक - 1 काय
 - 3) मजमा ठाकी बाडु बेसीक वर - 1 काय
 - 4) कम नं. 312 - 313 फरवी मिथानेच्या आरंभ बसवु मिनाळ्यात.

17/5/18 वॉर्ड ॥ पेवोट कायकम चोळमप झालेले आहे ते चोळमप काळु देण्यात येणे.

19/5/18 C.C.L. Dept ॥ विभागातील पाठ्याची टाकी स्वच्छ दुरु देण्यात येणे.

21/05/18 Blood Bank ॥ गरवाडे वसुपेठीचे inspection सवि रोज रव ते पिजने देणे.

22/5/18 Animal House ॥ वरीक पत्राचे कॉपीक कायद राबुठ देणे.

11/04/18

1) तानाजी खीकीमकर :- Bleaching powder चाळण्यासाठी
आम्ही पाठावेळाने आले.

2) तानाजी खीकीमकर :- गुलाब दिवाणे :-
psm dept. चा पोस्ट प्रदर्शनाचा कार्यक्रम होताना
त्यासाठी पंचरा स्टेज मावून घेण्यात आले. अचूकतेबाबत मध्ये
प्राधान्य देण्यात आले. त्याच्या अगोवत मध्ये keeping करून
Audit बाबत साफ करून घेण्यात आले.

3) गुलाब दिवाणे :- Sewage मोटार चालू होताना काला दिवाणी
यांचा Sewage हाताळणी वेळी.

12/04/18

1) तानाजी खीकीमकर :- Bleaching powder चाळण्यासाठी
पाठावेळाने आले.

2) बाकु जाधव :- रेवेन्यु :- पिछाडे, कुठेसा गळे.
1. MRF वरून नव्या Sewage मोटार आणणेची
होती ती नव्या मध्ये हातून वेपरीत होत जावत
मावून घेण्यात आली त्यासाठी कोषांत मर्यादा
वेळी वेळी. व मोटार कुठे करवात आली. परंतु मोटार
कुठे साळी नाही.

3) कुठेसा गळे :- कॅडेट 11 व्या होत याचा वसावेळाने आणत

4) तानाजी खीकीमकर :- मोटार वया वेचे योवत मोटारीमध्ये
याणी अकर मोटार कुठे करवात आली. व उभेले
कोषांत मर्यादा करून घेण्यात आले.

3/13/18 1) चंद्रकोन शिंदे :- Bleaching powder लावण्यासाठी पाठापिठ्यात आले.

2) तमाजी विक्रीमकर :- क्राफ्ट कार्ड्स मधील पिठ्याच्या पाठ्याची टाकी घुवून खवळ करून देण्यात आली (मेडीज डोस्ट्रेम जवळील)

3) बाकु जाधव :- PCR करून घुवळीचे सौंपण सादण्यासाठी किंवा लावण्यासाठी मागले आले होते त्याच्या सोबत बाकु जाधव यांनी पाठापिठ्यात आले.

4) चंद्रकोन शिंदे :- उपार गंतू PCR बरोबर पाठापिठ्यात आले. हॉस्पिटल व OPD फ्लोर ये काम पुर्ण करण्यात आले.

5) बाकु जाधव :- दिनांक 12/11/18 रोजी 22 मध्ये घुवला AK लावण्यात आला होता तो करण्यात आला आहे व त्यामुळे त्या होम मधुन उंडिर येत होते तेथे सिमेंट लावण्यात आले.

② Bleaching powder चे 25 कि.ग्रे.चे होत पाते आलेले हेमि ले OPD जवळ देण्यात आले हेमि ले मेकॅन्स डिपार्टमेंट मध्ये आणण्यात आले.

24/03/18

1) न्यूलॉन रिडि :- Bleaching powder काबजासाठी
पाठविण्यात आले. (1 day)

2) लानजी विधीमकर - गुलाब दिवडे :-
नविन सेडा काबजासाठी कट्टा तयार करवासाठीचे
उपर बाबु न लॉन मधील सेग जवळ टाळण्यात आली.

3) लानजी विधीमकर :- PCR कडून उतरासाठीचे BOX बसविण्या-
साठी आले होते त्यांच्या बरोबर एक लेटर देण्यात आला
व उतराची सादरसिग करण्यात आली. रकूण देणं BOX
बसविण्यात आले. ① CSSD मध्ये - 2, ② OT - 1
③ अन्वेषणीय डिपार्टमेंट - 2, ④ PACU - 2, ⑤ NCCU - 1
⑥ Anatomy Dept. - 02 Nos. हा (श्री. पदमकर 7040053973)

4) लानजी विधीमकर - गुलाब दिवडे :-
ऑडीटोरियम मध्ये Cratweaving साठी पडने मागले
होते ते काबजासाठी भिरकरी काबजावडीत होत लेटर व
मेमोरसचे दोन लेटर मिळून पडने काबजात आले.

21/03/18 1) चंद्रबोन शिड्डे - Bleaching powder टाळतासाठी पाठविण्यात आले. (पाठविण्या टाळतामळे)

2) लान्सी शिड्डे मंत्रालय :- PCR चे 4 पत्र सादर हे उदासाठीचे Audit करणासाठी जाणे हेम लोच्या सोबत एक हेमट्ट फ्रेमान आला. लान्सी गोपीडी, होल्पीटक व कोकोडी 20 दिवशी किफत सवळे करणान आला.

3) गुलाब दिवसे :- नवित्त दिवशी गार्डन स्टेट जाऊ सेंट वसाकिण्याचे कामासाठी पाठि लागत हेम व लान्सी जुने मेनेटस विद्याळा जेथे पाठि पाठि मसत 20 फुटीचे फीलाके नाही गंतद गर्भस होल्डेक गेट रोजडी. हेम रोवळेके पाठि होत ते उककत ठेवणान आले.

4) गुलाब दिवसे + 2 हेमट्ट :- गर्भस होल्डेक रोजडीक पाठि उककत ठेवळेचे हेम ते बडुक मी. मिळती थोचत लावणान देवणान आले.

22/03/18 1) चंद्रबोन शिड्डे :- Bleaching powder टाळतासाठी पाठविण्यात आले.

2) गुलाब दिवसे :- Casualty वर सांगचा पाना पाचोळणाची साफ सफाई करणान आली.

3) गुलाब दिवसे + चंद्रबोन शिड्डे :- दुपदीतंतद मडाविषाळभातीक कॅम्पस मधीक मोळट जुने कॅम्पस वाटेर धावामेणान आले. लान्सी दुकानपुन लावणान आले. रोजडीका गार्डन दिवडीमेळे जाणसे मसलीक देवणान आली. होली.

2/02/18

1) सुरक्षा गार्डे :- Breaching powder का उपयोग करने के लिए

2) रिपोर्ट :- अनुमानित

भारत विकास परिषद, पावसाइस, कोकोन शिवालय
 जयपुर फुट आकाशवाणी कार्यक्रम के लिए होने वाले कार्यक्रमों की
 तैयारी करवाया जाये, जैसे, रेडियो, युवा, समर्थ,
 लोक वान, मार्चिंग मेणबर्नी इ. आदि का अनुभव देखा जाये

3) सुरक्षा गार्डे + डिप्टी, जाइर :-

कार्यक्रम आयोजन के लिए 150 युवाओं को जोड़ा जाये
 मध्य प्रदेश शासन के माध्यम से, प्रो-ग्रेसिव रेडियो इ. आदि का
 उपयोग किया जाये परन्तु देखा जाये
 कोकोन मध्य प्रदेश युवा 10 आयोजन - होना व
 00000 देना. मध्य 10 युवा युवा देखा जाये आयोजन होना
 परन्तु देखा जाये

A) किरा + 2 :-

- 1) वॉल नं. 11 - वायकम
- 2) वॉल नं. 12 - एंजलर
- 3) वॉल नं. 6 वन - लेसीन
- 4) वॉल नं. 25 - वायकम

वरीक सर्व चोखमप काठगाम अके

5) CSSD मध्ये PCR कक्ष इत्यादीयें पेट देखा जाये
 आके होने काया इ उदिद चिखले होने से काठगाम अके

6) Army Dept. मध्ये Electronic Box मध्ये इदिद
 काठगाम अके

11/18 1) तामाजी त्रिठीमक :-

Bleaching powder टाळण्यासाठी पाठविण्यात

आले.

2) विद्यार्थी :-

सुरक्षासाठी pest control चे औषध जाणवताय

PCR कडून technician आले होते त्यांच्या सोबत

पाठविण्यात आले. डॉस्वीरक मधील वर्ड नं. 6 ते

वर्ड नं. 29 पर्यंत औषध जाणवत आले व कॉलेज

मधील 1) कम्प्युटरी मेडिसीन, 2) Biochemistry

3) Anatomy dept. वरून औषध जाणवू शकते आहे

3) किरात राऊ :-

वर्ड नं. 1 च्या मार्गीक वाजुस चेंबड मॉडेल

चौकळप झालेली होती ती काढण्यात आली.

11/18 1) तामाजी :-

Bleaching powder टाळण्यासाठी पाठविले-

वटुकादी पाळ्याचे 0.1 लिटर साठी सॉल्यूशन देण्यात आले

2) नातु जावप :- दिवसे दिवस :-

डॉस्वीरक, ओपीडी मधील, पुसदा मजकरी, पहिला

मजकरी तीठ पुढीलकऱा पहिली लागून सिमेंट लागुन देण्यात

आले. डॉस्वीरक मधील वर्ड नं. 24, वर्ड नं. 12

मध्ये वेसीनचे पहिली सिमेंट लागुन देण्यात आले.

3) किरात गाड :-

Microbiology मध्ये विद्यार्थ्यांची काच बसणुन

देण्यात आली. कपटाने काच बसविण्यासाठी त्या

काचेचे माप देण्यात आले. 2 लीटर कपटारची

काच शोधण्यात आली.

4) अशांत :- वर्ड नं. 4, वर्ड नं. 6, 7, 16 वापरून चौकळप

काढण्यात आले.

वर्ड नं. 18 मध्ये वर्ड नं. 24 वर्ड नं. 11 मध्ये

20/12/17 1) चंदावत शिडे + कुंभरागाडे, दिवळे, ताम्बाजी :-
 1MA च्या कार्याक्रमासाठी लागणारे टेबल
 कुठून घ्यावी व Lib. युवती वॉलंट्स् द्वारे सहित्या
 प्रत्येक विभागासकरीब देण्यात यावे.

2) चंदावत शिडे :-
 Bleaching powder लावण्यासाठी
 पाठाविभाग आम्हाला व कुंभरागाडे, पाठ्याच्या बरोबर
 0.1. रक्कम लावण्यासाठी C.M. विभागामा
 देण्यात यावे.

3) कुंभरागाडे :-
 P.C.D कडून सांख्यिकीसाठी सी.एम. विभागामा
 देणे आम्हाला होणे त्याच्या बरोबर गाडे आम्हाला
 पाठाविभाग आम्हाला उदराचे सांख्यिकी देण्यात
 यावे.

4) दिवळे - ताम्बाजी :-
 * मध्य उपा. च्या वरीक हेरिसण
 (समाज-समाधान) साठीचा पाठ्या सांख्यिकी होणे
 नेत्रे सांख्यिकीसाठी लावण्यासाठी पाठाविभाग आम्हाला
 देणे व हेरिसणच्या पाठ्या सांख्यिकीचा काम घुर्वा
 सांख्यिकी घ्यावे.

5) विभाग टाळ :-
 1) वॉलंट्स् 15 मध्ये टॉपलेट कोळमण
 2) वॉलंट्स् 07 मध्ये टॉपलेट व वायकक
 3) वॉलंट्स् 17 मध्ये टॉपलेट व वायकक
 4) वॉलंट्स् 05 टॉपलेट व वायकक कोळमण
 वरीक सर्वा कोळमण लावण्यात
 आम्हाला.

* 6) वॉलंट्स् होस्टेल, गर्मिस होस्टेल, ताराच न्वाहल, व्हा. विभागाती
 मध्यकाठीर Figgimay (धुळणी) करवतात आम्हाला.
 नगरपालिका मधुळ फवारणी मशीन आम्हाला होणे.

② सुनारी होत असत लॅबरील झोपडी वरील
 रूठ पाण्याची लकी जागी प्रसंगाने घेण्यासाठी
 होत हेल्थ अरि. मगानत जोडे जाण्याकडे
 पाठविण्यात आली. (वरील काम लॅबरीसाठी करित
 सोहळ्याची आदेशा विना होत)

४) सुट्टेस जाडे -
 वॉर्ड नं. ११ मध्ये खिडकीची दोन काचा
 बदलविण्यात आली.

५) अशोक वार्षादी :-

- ① वॉर्ड नं. १६ मध्ये लॅबरील चोळकप होणे ते
 काढण्यात आले.
- ② वॉर्ड नं. १७ मध्ये वायुमय व लॅबरील चोळकप
 होणे ते काढण्यात आले.
- ③ झोपडी लेडीज लॅबरील मध्ये वेदीक हॅण्ड
 चोळकप होत तो काढण्यात आला.

28/11/17 > पंधरात रिड्ड :-

bleaching powder टाळण्यासाठी पाठविण्यात
 आले.

१) गुनाक रिड्डिंगे लागली जीवनीमधूर :-

लागली biochemistry dept. मध्ये lab room
 मध्ये पाण्याचा (डिपेण्ड) चा वल्ल होत होत त्यासाठी
 मागील वायुमय outlet pipeline चेक करत
 दोषाई काढण्यात आली.

२) सुट्टेस जाडे :-

- ① खिडकीच्या काचा मायव्यासाठी मोठी नळती
 पंधरात वेळ १० रुग्णांनी वेदीक काढण्यात आली.
- ② pharmacology dept. - मध्ये रूठ काचा व
- ③ physiology dept. मध्ये होत खिडकीच्या काचा
 बदलविण्यात आली.

15/11/17

- 1) **विदे + लानाजी** :- medicine dept. वरुं c.m.E.
कार्यक्रमसाठी वरील दोघे हेपरुं कार्यक्रम सेपेपरुन
दुख्यान आणे.
- 2) **अमर + रिहामे** :- गर्भस होटेलेनच्या पाठीमागे टाळीच्या
ओवर फ्लोचे पाणी साचलेले होते त्या काळामासाठी
पाठविले होते परंतु तेथे रावत काळामागेतर त्या
डिवाणी चेवद सापडला व तो चेवद कोळमप झाला
होता. चेवद कोळमप काळामान आणे. व पुढे
नंतर त्या डिवाणी पाठविल्या व टाळीच्या वायुमा
पाइपमाईत मिळेत होती त्या साठी वेगवेगळे करणान
आणी. 2" पाइपमाईत काढलेली होती ती काढुन
टाळामान आणी.
- 3) **सुत्रेवा गाडे** :- Bleaching powder टाळामासाठी पाठ -
विल्यान आणे. व गर्भस होटेलेन टाळीमिळे संख्या
4.00 वा Bleaching powder टाळामान आणी.
- 4) **अशोक वाळमीची** :- 200 मध्ये चेवद टाळीचे कोळमप
सकिते होते ते काळामान आणे.

खोदाई करवाना आनी.

4) S.T.P. रोमरिंक चेंवड चोळमप सामा होमो तो
चेंवड चोळमप काळोवान आनी. (अरिंक,
किशक, अजम).

5) अमरु लोरगळे - सावंत सीरक इजिभिसर वोगी
सोपिनलेका पेरिंत वा कायासाव
पाडाकेला आर.

6) कुडरा गाडे - patho dept. मध्ये HOD Room
ची खिंडीची काच बसविण्यात आनी
दोठ खिंडी असकत होव्या त्या डिपेडिण
करवणात आनी.

3/11/19 1) जर्मन होस्टेल च्या मधीक वाजु कडिक उपाडुंची
तार कुळेमी - होमी लेकून वाहेरिंक माणसे येत
जान होती त्याकरिता तेथे जाळी लावून लावणी व
त्यामध्ये कटिरी कुडप लाववणात आणे - लानाजी, रिचोमे

2) S.T.P. रोमरिंक चेंवड पाडिं ताडिं शोधव्या.
साडी खोदाई करवणात आनी. पाडिं ताडिं
खोदन असमाना नगरपालिकेची पाडिं ताडिं
कुळेमी होती ती खोदाई करत सोकली
करत प्रेषणात आनी. - लानाजी, रिचोमे

3) B/salubg powder. हाळव्यासाठी व water sample
व्यवसायी - उडकोत हाडिं मोन पाडाकेवणात
आणे.

4) कुडरागाडे - वाडिं होस्टेल च्या दोठ काचा
व pharmacology dept. मधीक 2 काचा
बसविण्यात आनी.

दिनांक	काम केवनाचा तपशील	कामाचे जागे
3)	अपघात विभागाला वरीक हेदेसकट पाळापाचोळा सावलेका रोमा तो गोळा करुन उबारुन काढवतात आका दुपारवेर काम दिवणी काम खालात वाने	दिवाळे सायरे तामाजी
4)	अपघात विभागातील पाठीमागच्या बायुना (antenn) outlet पिपिंग फुलेकी रोमी तेथीक सर्व बाय सावलेकी रोमी तेथीक साफसफाई करवतात आका त्या दिवणी वेर बांधव्याची आवश्यकता नाहे.	दिवाळे सायरे
5)	वाडे व. 15 चा पाठीमागीक बायकमचा outlet pipe जोडवप सावलेका रोमा तो काढवतात आका. बांधाची बांधणी हीच बांधवतात आका रोमी.	दिवाळे

31/10/17

कर्मचारी संख्या - 02

1)	Girls Hostel मधील पिण्याच्या पात्राची हाकी मंडुल पाणी काडुम सुटुम वगळ करवतात आका. सेंकलेस विभागान 2 हेक्टर कामावर होत लोका साईट House Keeping करुन एक Helpers देवतात आका.	तामाजी चंद्रबोस
2)	Bleaching powder हाकीमळे हाकव्याकरिता एक हेक्टर पाठविले.	चंद्रबोस
3)	मराठ नवार्क A-5 मध्ये बायकम मध्ये शिफिंग ना पाणी Leakage होत आहे त्याकरिता वरील A-6 मध्ये बायकम मध्ये white cement व DO. fixit मिक्स करुन आर्तिक फासांमळे माववतात नाके.	सुबु पांडे तामाजी
4)	वाडे व. 15 व वाडे व. 01 मध्ये बायकम जोडवप रोमी से काढवतात नाके.	अजय




दिनांक	काठ जेम्माचा तपरीक	
दि. 28/10/17	वेणी जेम्मा कामाचा तपरीक.	
1)	bleaching powder हाळण्यासाठी सधुन campus मधील हाथ्यांमध्ये एक स कामगद ठेकी.	अमर
2)	जुर्मरुड कॉलेज वस्त्रागद काम करण्यासाठी पाईप लाईन हाळण्यासाठी जे सीबी घेण्यात आला व वस्त्रांमध्ये आडवे खोदून नेण्याची 8 इंची पाईप पाईप हाळण्यात आली व त्यामध्ये Sewage चे PVC पाईप जोडून देण्यात आले व त्यातून Sewage ची मोटार चालू करून वरतून करवात आले त्यानेतून JCB च्या सहाय्याने कुजवून घेण्यात आले.	अमर तामजी, दिशे जयक सुरेश गडे
3)	O.T. मधील रवीच्यामध्ये पमांची घरे केलेली होते ते पुनर्गठन करवात आले. पाईपमधील वायुस साईट असल्यामुळे होव शिबी राखवण्याकडून काम पुर्ण करवात आले.	तामजी, सुरेश दिशे

30/10/17.

बुधवारी सत्र्या - 04
(रजद)

1)	Grinds Hostel च्या Sewage Tank ची mud pump कुठ होत नव्हता त्यासाठी फुडवात व्यवस्थित करून मोटार कुठ करवात आली परंतु मोटार कुठ ज्ञानी नाही. मग इलेक्ट्रीयन बोलावून घेतले व मोटार - व्यवस्थित कुठ करवात आली.	गुलाक, जालु जात्र तामजी
2)	कॉलेज व हाँस्पिटल पाठ्याच्या हाथ्यांमध्ये bleaching powder हाळण्यासाठी एक कर्मचारी ठेकी. पुढील दुपारी O.T. वरत साठी वास्तव्यामध्ये पाठ्या घेवून पदन विभागात देण्यात आले.	चंद्रकोट

14-2-17	1)	पुं० वाडन 21 वांश वसति चौकप ट्रिप लावमार मालवा टाऊन टोकपकाळो	21 नं वाड	म. ल. ल.
14-2-17	2)	पुं० वाडन 15 कूलर चौकप आहे वाडन 18	15 नं वाड	म. ल. ल.
14-2-17	3)	कॉलेज कॅन्टीन समोरीत गटार पूर्ण साफ करणे	कॉलेज कॉम्प्लेक्स	म. ल. ल.
14-2-17	4)	OT मधील कामया आपण दर लावून देणे	OT	म. ल. ल.
14/02/17	5)	छिछ व माशांचे प्रमाण वाढले आहे. फवारणी करावी.	वाडन दोरळे	
16-2-17	1)	वाडन 6 मधील पेशंट वायसम चौकप आहे.	वाडन 6 वाडन 6	म. ल. ल.
16-2-17	2)	ICU कूलर चौकप आहे अडले नाहणे	ICU	म. ल. ल.
	3)	प्रभावक कर कॅलन पाशा आडले वायू वांछने पडले आहे त जाताना गज होकच्या मादी हातेडी नेणे)		
16/02/17	a)	proctorial माल मधील रबिडोव्हीच्या काशा पुढेमेण्या आहे.	micro	वाड
17/02/17		मि विंग डॉक्टर कॉटर मधील काच फुटला आहे लवकरात डॉक्टर फारक	मि विंग डॉक्टर मि विंग डॉक्टर	म. ल. ल.

3-12-16		दोपचा जागी वास्तुन देणे.	वॉर्ड नं 7	म.उ.छा
5-12-16		कारावरील चौकीच्या बाहेरील पट्या टाडलसकच्या पडद्या आहेत (स्वामावयूच्या आहेत)	वॉर्ड नं 25	म.उ.छा
5-12-16		वॉर्ड बाय, व सिस्टर जेव्हा चेंडींग सस वापरस मधील दोन लोक सीमेंट लावून पॅक करणे	OT	म.उ.छा
5/12/16	1)	B Block Dr. Cotrug. मध्ये शाळीय पुणे मधील चेंबर तोल्यची व्हाय आहे.	B Block	
7/12/16		अॅनेस्योरीया डिपार्टमेंट अंधाचे औषध देणे	OT	म.उ.छा
7/12/16		TB वॉर्डच्या बाहेरील कोट हळवणे लावून नववील पण कोट हाळवणे	TB वॉर्ड	म.उ.छा
8/12/16		वेडवती मॅरसटाको (कार्क मॅरस) डॉक्टरसम.	वॉर्ड नं 23	म.उ.छा
10/12/16	1)	लेडिज हॉस्टेल. मध्ये कॅन्सिनचा वेष्ट जाळण्याचा पाईप. व्हाय आहे त्या काढून मिळावे.	लेडिज हॉस्टेल	
21/12/16	1)	नॉडिज हॉस्टेल मधील सपुर्ण खिडकीच्या 20 ते 22 कोचा फुटलल्या आहेत त्या वेसडून मिळाल्यात हि विनंती	वॉर्ड हॉस्टेल	
23/12/16		टॉमलेर चेकप आहे	वॉर्ड नं 21	म.उ.छा
23/12/16		वेसीनच्या साहून पाणी बाहेर रोल व्हाय मधून	OT	म.उ.छा

15-11-16	1)	PICU मधून फॉट काढून पीडियाट्रीक मध्ये झिअर करणे.	PICU	म. ल. छत्र
15-11-16	2)	मध्यमशांचे पोळे काढणे	वॉर्ड नं-21	
16-11-16	1)	11 मधील टॉयलेट चोकरप झाले आहे.	वॉर्ड नं 11	
16/11/16	1.	वॉर्डज हॉस्टेल 99 मधील खिडकीची एक काच तुटली आहे ती वसकुन सिकवनी	वॉर्डज हॉस्टेल	(Amit)
	2.	लक मजला डावी बाजू बांध- कम मधील खिडकीची काच तुटली आहे ती वसकुन सिकवनी हो विजली		
21-11-16	1)	खिडकीच्या काचा फुटलेल्या आहेत ती वसकुन सिकव्यात.	वॉर्ड नं 7	म. ल. छत्र
	2)	बायरम मधील बेरीन चोकरप आहे.	mmw-1	म. ल. छत्र
	3)	PTS बायरम मधील बेरीन चोकरप आहे.	वॉर्ड नं 21	म. ल. छत्र
22/11/16	1)	लेडीज हॉस्टेल मधील 3 काच आहे त्या बदली करू देणे आहे त्या घेऊन येणे ही विजली	लेडीज हॉस्टेल	(Amit)
23/11/16		काच बसवणे कलरपरी काच आहे	वॉर्ड नं 1	म. ल. छत्र
23/11/16		अनेस्येशीया डीपार्टमेंट मध्ये उंदीर झाले आहेत अनेकदा सिकवणे	अनेस्येशीया	म. ल. छत्र
28-11-16		वोश बेरीन चोकरप आहे.	वॉर्ड नं 23	
28/11/16	1)	मेलची वॉर्डन चोकरप झाले आहे. तो जेवणाच्या वेळ झाले ती सिकव्यात करणे सिकवनी	लेडीज हॉस्टेल	(Amit)

दिनांक	क्र.	कामाचे स्वरूप	विभाग	सही
12/10/16	1)	कम नं. 3, 126, 221, 222 मध्ये खिळीची काचा फुटलेली आहे.	वॉर्डिंग होस्टेल	
14/10/16	1)	डासासाठी औषध फवारणी करणे वाटेकर व आनीस वाजुस	गर्भशाला होस्टेल	
17/10/16	1)	संगण व बायकम चोळमप झालेले आहे.	वॉर्डिंग नं. 24 भागे	म.उ.का
	2)	कम नं. 16 व 111 ते 113 मध्ये उदिर झालेले आहे.	वॉर्डिंग होस्टेल	
20-10-16		वॉर्डिंग 11 - उदराचे औषध देणे P.T.I	वॉर्डिंग 11	म.उ.का
21/10/16	1)	जी.पी.बी. पहिल्या मजल्यावर बायकम चोळमप झालेले आहे.	OPD.	
	2)	वांवा बेसीन ट्रेप चोळमप झालेले आहे.	वॉर्डिंग 16.	
25-10-16	1)	11 वॉर्डिंग 2 काचा फुटलेल्या आहेत	वॉर्डिंग 11	म.उ.का

28/8/15 → एक बेसीमते कलिंग समर प्रेम्यात
आले ..

Qu → Auditorium मध्ये USA कोसोमासात
एक इमारत प्रेम्यात आहे .

→ Cymal opd मध्ये लवाळी करवणाऱ्या बाबत साक्षी,

29/8/15 → होन्डी कंपनी साफ सफाई करवणाऱ्या बाबत साक्षी, 01/2/2015
दिनांक

→ होन्डी कंपनी साफ सफाई करवणाऱ्या
आली .

→ बाहेरक रजप खोबूत लोकमप
करवणाऱ्या बाबत साक्षी.

Logbook - Electrical department

2016 -2021

DATE	No of Iwarded LED Tubes	From	No of outwards LED Tubes	Department	Remarks	Name of sing
26/08/20	-	-	08 New LED fixed	Collage Building 2nd floor & 3rd floor Tidet & Bath Room LED fixed	old chok need to Replace by New one	Nandkishor Shinde Avinash
27/08/20	-	-	04 New LED fixed	PSM Examination Hall = 1 Ward - 17 = 02 GYNDPT = 01		Ranjit Avinash
28/08/20	-	-	02 New LED fixed	Microbiology - (D) le girls Hostel (D)	old chok need to Replace by New one	Avinash, Pradip Ranjit
28/08/20	-	-	02 New LED (9watt) fixed	New Hospital Lift		Ranjit
31/08/20	-	-	02 New LED fixed	store = 01 02 Room = 01	old chok need to Replace by New one	Ranjit Avinash
02/09/20	-	-	02 New LED fixed	Diyasis = 02		Avinash Ranjit
03/09/20	-	-	05 New LED fixed	Covid ICU = 04 Girls Hostel = 01 Boys	old chok need to Replace by New one	Pradip Avinash, Nitin
05/09/20	-	-	01 New LED fixed	R.A. Room No - 08		Kiran Ranjit
07/09/20	-	-	01 New LED fixed	Girls Hostel - 01	old chok	Nandkishor
08/09/20	-	-	06 New LED fixed	Labour Room = 02 Girls Hostel & Passage = 02 R.Q. = 06 = 02		

DATE	No of Inwarded LED tube	From	No of Outwards LED tube	Department	Remark	Name + Sing
10/09/20	-	-	05 New LED Fixed	OBG dept = 01 Cash counter = 01 Pediatric OPD = 01 OPD Passage Lift = 01 TB OPD Passage = 01	old chok need to replace by New one	Avinash Kiran Pradip
14/09/20	-	-	01 New LED Fixed	Labour Room = 01	old chok	Pradip Kiran
			04 LED Box Completed which was inwarded on 11/08/20 + 18/08/20 + 24/09 (30 LED Nos completed)			
X						
14/09/20	01 LED Box inwarded (20 Nos)	Central Store Dept				
28/09/20	01 LED Box inwarded QTY (20 Nos)	Central Store Dept				
09/10/20	01 LED Box inwarded QTY 20 Nos	Central Store Dept				
14/09/20	-	-	09 New LED Fixed	Girls Hostel Canteen	old chok need to replace by New one	Kiran Avinash Tukaram
15/09/20	-	-	02 New LED Fixed	Central Store = 01 R.Q. 6 = 01	old chok	Pradip Kiran
17/09/20	-	-	03 New LED Fixed			Pradip Kiran

Date	No of Inwarded LED Tube	From	No of Outwards LED Tube	Department	Remark	Name of sing
19/09/20	-	-	03 New LED fixed	Kondke office = 01 Blood Bank = 01 River = 01	old Chok need to Replace by New one	Pradip Kiran, Nith Nandkishor
22/09/20	-	-	01 New LED fixed	Mansapchar = 01	————— —————	Ranjit
25/09/20	-	-	03 New LED fixed	Microbiology	old Chok need to Replace by New one	Tukaram Ranjit Avinash
28/09/20	-	-	01 New LED fixed	X-Ray	————— —————	Ranjit
29/09/20	-	-	01 New LED fixed	Cash counter	old Chok	Avinash Ranjit
01/10/20	-	-	04 New LED fixed		old Chok need to Replace by New one	Ranjit Tukaram
05/10/20	-	-	04 New LED fixed	Boys Hostel	————— —————	Kiran Tukaram
06/10/20	-	-	04 New LED fixed	Central store (1) obs ward - (1) ward 13+16 = (2)	old Chok need to Replace by New one	Kiran, Tukaram Nith
07/10/20	-	-	02 New LED fixed	HPP	old Chok	Nandkishor Nith, Kiran
08/10/20	-	-	03 New LED fixed	covid ICU	old Chok need to	Ranjit Nith

DATE	No of Inwarded LED Tube	From	No of Outwards LED Tube	Department	Remarks	Name of Staff
09/10/20	-	-	02 New LED Fixed	OT No 208 = ① GYN OPD = ①	old chok	Kiran Avinash
10/10/20	-	-	02 New LED Fixed	108 ward = ① L. Hostel = ①	old chok need to Replace by New one	Ranshi Avinash Waringe
12/10/20	-	-	01 New LED Fixed	L. Hostel 123 = ①	old chok	Avinash Kiran
14/10/20	-	-	05 New LED Fixed	Anatomy lecture Hall - 05 Pathology = 03	old chok need to Replace by New one	Ranshi Kiran
15/10/20	-	-	02 New LED Fixed	admin office - ① microbiology - ①		Avinash
16/10/20	-	-	02 New LED Fixed	Anatomy - ① casulary - ①	old Chok need to Replace by New one	Nandkishor Avinash
17/10/20	-	-	02 New LED Fixed	Pediatric HOD office = ① Medical store = ①		Kiran Avinash
19/10/20	-	-	01 New LED Fixed 03 LED Box Completed (60 NOS LED Completed)	GYN OPD = ①	old chok	Pradip Nandkishor
23/10/20	01 (half Box) inwarded	Central Store	Qty 2 12 NOS			
23/10/20	01 LED Box inwarded	Central Store	Qty 2 20 NOS			
05/11/20	01 LED Box inwarded	Central Store	Qty 2 20 NOS			

Date	No of Incorporated LED Tubes	From	No of Outwards LED Tubes	Department	Remark	Name of sing
20/10/20	-	-	08 New LED Tube fixed	Psy ward - 01 Sadumbare Hospital - 07	Old Chok need to Replace by New one	Waringe Pradip Avinash
22/10/20	-	-	06 New LED Tube fixed	C.S.T.	old Chok	Waringe
23/10/20	-	-	05 New LED fixed	ENTOPD = 01, TBOPD = 01 Psy ward = 03	old Chok need to Replace by New one	Kiran Avinash
24/10/20	-	-	02 New LED fixed	Security office = 01 Admin Hall = 01		Ranjit Tukaram Avinash
28/10/20	-	-	01 New LED fixed	Ladies Hostel = 01	old Chok	Tukaram
29/10/20	-	-	01 New LED fixed	ENT OPD = 01	old Chok	Kiran
05/11/20	-	-	02 New LED fixed	Library = 02	old Chok need to Replace by New one	Tukaram Ranjit
06/11/20	-	-	01 New LED fixed	GYN Dept. = 01		Tukaram Avinash
07/11/20	-	-	01 New LED fixed	B 108 = 01	old Chok	Ganesh
09/11/20	-	-	01 New LED fixed	Operator Room = 01		Pradip Tukaram
11/11/20	-	-	01 New LED fixed	Microbiology = 01	old Chok	Ranjit Avinash
17/11/20	-	-	01 New LED fixed	Ladies Hostel	old Chok need to	Waringe

DATE	NO OF Inwarded LED Tubes	From	No of Outwards LED Tubes	Department	Remark	Name & Sing
18/11/20	-	-	04 New LED fixed	Collage. B. 1st floor = 03 PSM Dept = 01	old chok need to Replace by New one	Nandkishor Tukaram Waringe
19/11/20	-	-	02 New LED fixed	ortho OPD = 01 Library = 01		Tukaram Waringe
20/11/20	-	-	03 New LED fixed	casualty = 02 Staff QW02 = 01	old chok	Ranjit Nandkishor
21/11/20	-	-	05 New LED fixed	Ladies Hostel = 02 Collage. B. PSM = 03	old chok need to Replace by New one	Nandkishor Nitin
23/11/20	-	-	03 New LED fixed	Medicine OPD = 01 Blood Bank = 01, Ladies Hostel = 01		Avinash Ranjit
25/11/20	-	-	03 New LED fixed	Phyiology = 03	old chok	Nitin Ranjit
26/11/20	-	-	01 New LED fixed	Boys Hostel Room No-216	old chok need to Replace by New one	Pradip
16/12/20	-	-	01 New LED fixed	Boys Hostel Room No-18		Avinash obh
			* 52 Nos LED Completed *			
02/12/20	-	-	01 New LED fixed (10 watt)	SKIN OPD	old chok	Pradip Kiran
07/12/20	-	-	03 New LED fixed (10 watt)	TCU		Pradip Tukaram

DATE	No of Inwarded LED Tubes	from	No of Outwards LED Tubes	Department	Remark	Name of Sing
10/12/20	-	-	2 New LED Fixed (10 watt)	ICU	old chok need to Replace by new one	Ranjit Kiran
06/01/21	01 LED Box inwarded (central store) Qty = 20 NOS (20 watt)					<i>only</i>
08/01/21	01 LED Box inwarded (central store) Qty = 20 NOS (20 watt)					
11/01/21	LED Tube 9 watt Qty = 10 NOS Inwarded (2 feet)					
18/01/21	01 LED Box inwarded (central store) Qty = 20 NOS					
06/01/21	-	-	07 New LED fixed	OPD - 01 casualty = 05 Library = 01	old chok need to Replace by new one	Nandkishore Nitin, Kiran Avinash
07/01/21	-	-	05 New LED fixed	central store = 03 OPD 47 = 01 Ladies Hostel = 01	old chok	Nitin, Kiran Nandkishore Avinash
08/01/21	-	-	14 New LED fixed	casualty = 03 Boys Hostel = 11	old chok need to Replace by New one	Pradip Nandkishore Avinash, Ranjit
09/01/21	-	-	05 New LED fixed	Collage Building porch = 03 Electrical dept = 01 Staff Q. = 01		Kiran, Pradip Avinash Nandkishore
12/01/21	-	-	01 New LED fixed	Phyckbrick OPD = 01	old chok	Kiran, Pradip

DATE	NO OF Inwarded LED Tubes	From	No OF Outwards LED Tubes	Department	Remark	Name of sing
13/01/21	-	-	01 New LED fixed	Girls Hostel = 01	Old chok need to Replace by New one	Waringe Ransit
14/01/21	-	-	02 New LED fixed	OB&T 4th ward = 01 Ladies Hostel 306 = 01		Avinash Ransit
16/01/21	-	-	01 New LED fixed	Girls Hostel = 01	old chok	Kiran, Avinash
18/01/21	-	-	04 New LED fixed 02 New LED fixed (quadr)	Coastal Rd = 02 (quadr) Girls Hostel = 01 NICU, PECU = 03	old chok need to Replace by New one	Ransit, Kiran Tukaram, Nandk Pradip, Munde
19/01/21	-	-	02 New LED fixed	Ladies Hostel = 01 ENT OPD = 01		Kiran Baliram
20/01/21	-	-	04 New LED fixed (18) 01 New LED (9 watt)	Physicstic ward = 02	old chok	Waringe Nandkishor
23/01/21	-	-	02 New LED fixed	Ladies Hostel = 01 karnel office = 01	old chok need to Replace by New one	Pradip Ransit
27/01/21	-	-	→ Ramchandra incoorndgr New LED fixed	(Ladies Hostel, Bath = 12)		Munde, Pradip Ransit
27/01/21	-	-	01 New LED fixed	Blood Bank = 01		
30/01/21	-	-	03 New LED Fixed	PNC Ward = 02 Girls Hostel = 01	old chok	Kiran, Baliram Nitin, Avinash
01/02/21	-	-	01 New LED Fixed	Skin OPD = 01	old chok need to Replace by New one	Pradip Tukaram

DATE	No of Inwarded LED Tubes	From	No of Outwards LED Tubes	Department	Remarks	Name of Sing
02/02/21	-	-	03 New LED fixed	OPD No 38 = 01 Physiotherapy ward = 02	old chok need to Replace by new one	Pradip, Kiran Avinash, Nidhi
28/01/21	-	-	03 New LED fixed	Pharmacology = 03	4	Ranjit Shinde
03/02/21	-	-	03 New LED fixed	Principal office = 01 Library = 01, Riding Room = 01 (Hostel ladies)	old chok	Kiran, Avinash Tukaram
04/02/21	-	-	01 New LED fixed	Ladies Host Room No 2 = 01 Room No 4 = 01	old chok need to Replace by new one	Tukaram Avinash Ranjit Shinde 20/2
3 LED Box Completed (60 NOS completed)						
03/02/21	01 LED Box inwarded	Central Store (20 NOS)				
10/02/21	01 LED Box inwarded	Central Store (20 NOS)				
22/02/21	01 LED Box inwarded	Central Store (20 NOS)				
03/03/21	01 LED Box inwarded (8 watt)	Central Store (20 NOS)				
04/02/21	-	-	02 New LED fixed 01 New LED (10 watt)	Ladies Hostel Room No 4 = 01 Electrical dept = 01 OBG ward = 01 (10 watt)	old chok need to Replace by new one	Baliram Kiran, Pradip Nandkishore
04/02/21	-	-	01 New LED fixed	Ladies Hostel Room No 116 = 01	11	Pradip Tukaram Ranjit
28/01/21	-	-	02 New LED fixed			

DATE	No OF Inwarded LED Tubes	From	No OF Outwards LED Tubes	Department	Remark	Name of Sing
05/02/24	-	-	01 LED fixed	College Building = 01	old Chok	Nandkishore
06/02/24	-	-	07 New LED fixed	Electrical dept = 02 Boys Hostel = 02 Security office = 02 OPP = 01	old Chok need to Replace by New one	Baliram Avinash Ranjit Pradip Kiran
08/02/24	-	-	04 New LED fixed	Girls Hostel = 03 Skin opp = 01	old Chok	Avinash Pradip
09/02/24	-	-	03 New LED fixed	Blood Bank = 02 Electric dept = 01	old Chok need to Replace by New one	Kiran, Baliram Ranjit, Pradip
10/02/24	-	-	09 New LED fixed	Physiology dept 2 09		Baliram, Nihin Avinash, Kiran Pradip
11/02/24	-	-	01 New LED fixed	PICU = 01	old Chok	Pradip Baliram
12/02/24	-	-	01 New LED fixed	Admin office = 01		Waringe
13/02/24	-	-	02 New LED fixed	Physicist ward = 02	old Chok need to Replace by New one	Baliram, Kiran Ranjit, Nihin Avinash
15/02/24	-	-	01 New LED fixed	Boys Hostel = 01	old Chok	Pradip
18/02/24	-	-	01 New LED fixed	eyes opp = 01		Ranjit Baliram
20/02/24	-	-	01 New LED fixed	Boys Hostel = 01	old Chok need to	Avinash

DATE	No OF Inwarded LED Tubes	From	No OF Outwards LED Tubes	Department	Remark	Name of Sirs
22/02/24	-	-	05 New LED Fixed	OPHthl OPD = 01, ENT OPD = 01 Dialysis = 01, OPHthl OPD = 02	Old Chok need to Replace by New one	Kiran, Baliram Avinash, Ranjit Nandkisan
24/02/24	-	-	02 New LED Fixed	Medicine dept = 02	-	Kiran, Ranjit Baliram
26/02/24	-	-	11 New LED Fixed	Dr Ghanu Sir House = 10 Ganesh sir (Staff) = 01	Old Chok	Pradip, Avinash Ranjit, Kiran Shinde
03/03/24	-	-	01 New LED Fixed	OPD Building 1st floor Lif side = 01	old Chok	Tukaram Pradip, Avinash
05/03/24	-	-	09 New LED Fixed	Physiotherapy collage = 09	Old Chok need to Replace by New one	Pradip, Kiran Ranjit, Avinash Baliram
06/03/24	-	-	01 New LED Fixed	Boys Hostel = 01 (Room No - 302)	old Chok	Kiran Baliram
08/03/24	-	-	02 New LED Fixed	OPD Toilet (Gents & Ladies)	-	Ranjit, Pradip Nitin
09/03/24	-	-	06 New LED Fixed	Girls Hostel Ground floor (Toilet) = 06 LED	Old Chok need to Replace by New one	Baliram Kiran
09/03/24	-	-	05 New LED Fixed	Girls Hostel 1st floor = 05 LED	-	Kiran Baliram
* 04 LED Box Completed (18 watt) * 80 Nos Completed						

DATE	No of Inwarded LED Tubes	From	No of outwards LED Tubes	Department	Remarks	Name & size
08/03/24	01 LED Box inwarded (20 Nos)	central store				
09/03/24	-	-	02 LED new fixed	Girls Hostel first floor (Toilet) = 01 female surgery ward = 01	old chok	Kiran Baliram
10/03/24	-	-	01 LED New fixed	Girls Hostel = 01	old chok need to Replace by New one	Kiran, Nitin Baliram Waringe
11/03/24	-	-	03 New LED fixed	Physiotherapy dept = 02 B-18 ward = 01		Waringe Baliram Pradip, Avinash
13/03/24	-	-	02 New LED fixed	Psychiatric dept = 02	old chok	Pradip, Ranjit Avinash
15/03/24	-	-	07 New LED fixed	X-Ray = 02, Girls Hostel = 02 Recovery = 03	old chok need to Replace by New one	Pradip, Ranjit Tukaram Baliram, Avinash
16/03/24	-	-	05 New LED fixed	Boys Hostel GYM = 02 Girls Hostel = 03		Kiran, Avinash Nitin, Baliram Tukaram Avinash
	* 01 LED Box Completed (20 Nos) Completed					

DATE	No OF Inwarded LED Tubes	from	No OF Outwards LED Tubes	Department	Remark	Name & Sing
17/03/24	01 LED Box inwarded (20 NOS)	to central store				
17/03/24	-	-	02 New LED fixed	Seaver Room = 02	old chok need to Replace by New one	Pradip Ranjit, Tukam
18/03/24	-	-	02 New LED fixed	OT No 2 = 01 OT No 7 = 01	4	Avinash Baliram, Kiran
20/03/24	-	-	03 New LED fixed	Admin office = 02 Boys Hostel = 01	old chok	Avinash, Kiran, Baliram Nandkishor
22/03/24	-	-	01 New LED fixed	Pediatric dept = 01	4	Avinash Kiran, Ranjit
23/03/24	-	-	03 New LED fixed	Girls Hostel = 02 CCL = 01	old chok need to Replace by New one	Avinash, Kiran Baliram, Pradip Ranjit
25/03/24	-	-	02 New LED fixed	central store = 01 GYN ward = 01	4	Pradip, Kiran, Baliram, Ranjit Waringe
26/03/24	-	-	02 New LED fixed	B-18 = 01 OBST 43 = 01	old chok	Kiran, Baliram Nandkishor
31/03/24	-	-	02 New LED fixed	Surgey OPD & dept = 02	old chok need to Replace by New one	Avinash Kiran

DATE	No OF Incorporated LED Tubelight	From	No of Outwards LED Tubelight	Department	Remarks	Name of Sing
01/04/24	-	-	01 New LED fixed	Girls Hostel = 01	old chok	Baliram Kiran
03/04/24	-	-	01 New LED fixed	0B47 dept = 01	old chok need to Replace by new one	Kiran Baliram
05/04/24	-	-	01 New LED fixed	0B47 ward = 01		Baliram Kiran
			01 LED Box completed (20 Nos completed)			

DATE	No OF Inwarded LED Tubelight	From	No OF Outwards LED Tubelight	Department	Remark	Name of Staff
31/08/21	-	-	01 New LED fixed	Biochemistry Passage = 01	old chok	Avinash Tukaram
02/09/21	-	-	01 New LED fixed	Boys Hostel = 01 (Room No-204)	old chok need to Replace by New one	Nitin Avinash
04/09/21	-	-	01 New LED fixed	Girls Hostel = 01 (Room No 204)	old chok	Nitin Avinash
			40 LED Tubelight (2 Box LED completed)	Completed		
08/09/21	01 New LED Tubelight Box Inwarded (20 Qty) (Central Store)					
16/09/21	01 New LED Tubelight Box Inwarded (20 Qty) Central Store					
08/09/21	-	-	08 New LED fixed	7 floor New Hospital wing = 08 (Passage)	old chok need to Replace by New one	Tukaram Avinash
09/09/21	-	-	01 New LED fixed	Radiology = 01	//	Avinash
11/09/21	-	-	01 New LED fixed	RTPCR Lab = 01	old chok	Kiran, Nitin Ranjit, Pravin

DATE	NO OF INwanded LED Tubelight	From	No of Outwards LED Tubelight	Department	Remark	Name of Sirs
16/09/24	-	-	05 New LED fixed	IGU Passage = 05	old chok need to Replace by New one	Munde, Ranjit Nandkishor Waringe
16/09/24	-	-	12 New LED fixed	1) ENT OPD = 01 2) Physiology dept = 03 3) MRD Dept = 08	old chok old chok New Required	Nitin, Avinash Ranjit, Nitin Baliram Nandkishor
17/09/24	-	-	02 New LED fixed	ENT OPD = 01 Boys Hostel = 01	old chok need to Replace by New one	Avinash Baliram Pradip, Kiran
20/09/24	-	-	02 New LED fixed	PSM Lecture Hall = 02	old chok	Pradip Avinash
21/09/24	-	-	03 New LED fixed	Anatomy = 02 C.C.L = 01		Pradip, Kiran Nitin, Avinash
22/09/24	-	-	03 New LED fixed	RTPCR Lab = 01 Ladies Hostel = 01 (305) Ladies Hostel = 01 (Room No-13)	old chok	Waringe Munde Ranjit
24/09/24	-	-	01 New LED fixed	Surgery OPD = 01	old chok need to Replace by New one	Pradip Kiran
27/09/24	-	-	01 New LED fixed	adim office (Tandale sir cabin)	New Required	Avinash Kiran
			2 Boy LED Tubelight (complete)			

Sr No	DATE	Department	Major Breakdown of m/c & equipment	Breakdown Period	Action taken	Remarks
01.	02-02-20	Electrical Department (L.T. panel room)	1) maintenance work of L.T. panel room 2) changing of M.C.C.B 100A, 250A, 400A (01 nos) 01 nos / 03 nos 3) A.E.B = 1000A & 630A servicing work.	- 10 Hrs - FROM :- 10:00 AM TO :- 08:00 PM	- Preventive maintenance	maintenance work done on 02-02-20.
02.	07-06-2020	Electrical Dept (L.T. panel room)	maintenance work of Capacitor Bank.	10:00 AM TO 04:00 PM.	- Preventive maintenance -	Installation of Capacitor Bank at panel room (330 kVA system).
03.	05/07/20.	O.P.D. Building.	- preventive maintenance work	work-period 10:00 AM TO 12:00 PM.	70. kg. wire jointing kit used for cable jointing.	work done properly.

SR No	DATE	Department	Major Break down of m/c & equipment	Break down Period	Action taken	Remarks
01.	10-10-19	I.C.U. Hospital Bldg.	10 kVA ups Not working.	10:00 AM TO 01:00 PM.	1) ups- Bypassed. 2) All Batteries checked.	ups repaired by local party 2) Re-installed with new Batteries on 21-11-19.
02	13-02-19.	ICU (Hospital Building)	10 kVA ups Back-up problem	02:00 PM TO 07:00 PM	stand by ups used for Back-up. problem	After repairing of existing ups re-installed at I.C.U. and tested and now it operates properly. 12-3-19.
03.	13-02-19.	O.T. (Hospital Bldg)	20 kVA ups Automatically going to By-pass mode when No MIEB.	10:00 AM TO 10: AM 24 hrs.	ups taken on Rent Basis and old ups shifted for repairing on 14-2-2019.	After repairing of existing ups re-installed at ICU O.T. and tested Now it operating properly.

SR NO	DATE	Department	Major Breakdown & m/c & equipment	Breakdown Period	Action taken	Remarks
04.	23-09-19	Electrical	380 KVA DG set ; failed down	11:00 pm to 06:00 AM (07 hrs)	1) Reported to AML Agency 2) Went to servicing & re-programming.	After reprogramming work and servicing and replacement of necessary parts. It working properly.

SR NO	DATE	Department	Major Breakdown of m/c & equipment	Break down Period	Action Taken	Remarks
01.	15-02-18	S.T.P. plant.	S.T.P. plant Not working.	Frequently Not working	1) Reported to Amc Agency. 2) checked and tested. Need to servicing; Repairing work of Blowers and replacement	operating properly after servicing and repairing and replacement of parts.
02.	25-05-18	O.T. (Hospital Building)	20 kVA ups Back-up problem bypass mode	Frequently giving problem	ups. By-passed, Battery problem	1) Existing ups repaired by local party 2) Reinstalled with New Batteries dated on 06-06-2018.
03.	06-08-18	Laundry Department.	Troubler m/c Not working.	whole day.	1) Contactor problem. 2) Contactor By-passed,	New Contactor purchased and installed on 08-08-18

Sr No	DATE	Department	Major Break down & m/c of equipment	Break down period	Action taken	Remark
04.	10-10-2018	Electrical Department	380 kVA D/G set tripping problem.	whole day.	1) Reported to Aml Agency. 2) checking all parts 3) found out problem of control unit.	Control unit Replaced by new one dated on 11-10-2018 by Aml Agency.
05.	15-12-18	O.P.D. Building.	05 H.P. motor Not working.	whole day.	Stand by motor used instead of existing motor.	existing motor repaired by local party and re-installed on 18-12-18.

Sl. No.	DATE	Department	Major Breakdown of m/c & equipments.	Breakdown Period.	Action taken	Remarks.
01.	20-04-2017	Electrical	380 kVA DG. Set Back-up problem	Frequently giving problem city no m/s EB	1) Reported to Aune Agency checked out. 2) Found out problem of AVR kit.	AVR Kit changed by New emp.
02.	20-07-17	River-site	12.5 HP motor Not working	06 Hrs 07:00 AM TO 01:00 P.M.	checked: motor winding burnt out; stand by motor used instead of existing motor.	Existing motor repaired and installed on 23-07-2017.
03.	08-09-17	River-site	12.5 HP motor Not working.	02 hrs 10:00 AM TO 12:00 P.M.	-checked; find out problem of starter	New star-delta starter installed on urgent basis.

Biomedical maintenance -2021

Sr no.	Date	Department	Equipment name	Brakedown	Action taken (Inhouse/Outsource)	Remark
1	2/8/2021	NICU	Monitor	Not working	Inhouse	
2	2/8/2021	NICU	warmer	Not working	Outsource	
3	2/8/2021	OBS 108	BP App	Not working	Inhouse	
4	2/8/2021	ICU	Nebulizer	Not working	Inhouse	
5	2/8/2021	ENT OT	Drill	hand pice problem	Outsource	
6	4/8/2021	Casulty	BP App	Leakage	Inhouse	
7	7/8/2021	PICU	Syringe pump	Not working	not repairable	
8	9/8/2021	Physiotherapy	CPM M/C	Plug shocket broken	Outsource	
9	10/8/2021	Casulty	Monitor	Diplay not showing	Outsource	
10	11/8/2021	FMW	Nebulizer	Not working	not repairable	
11	10/8/2021	MMW	BP App	Mercury tube broken	not repairable	
12	13-8-21	NICU	warmer	not getting heat	Inhouse	
13	13-8-21	OBS 108	Monitor	Diplay not showing	Inhouse	
14	17-8-21	NICU	Monitor	charging problem	Inhouse	
15	17-8-21	OBS 108	NST	PPE Roll button faulty	Inhouse	
16	26-8-21	OBS 108	Monitor	Diplay not showing	not repaired	
17	27-8-21	NICU	warmer	Not working	Outsource	
18	30-8-21	ICU	BP App	Not working	Inhouse	
19	30-8-21	Pead ward	BP App	Not working	Inhouse	
20	2/7/2021	Peads OPD	BP APP	Not working	Inhouse	
21	2/7/2021	PNC	BP APP	Not working	Inhouse	
22	2/7/2021	obs 108	NST Machine	button broken	Inhouse	
23	2/7/2021	Physiotherapy	IFT	Broken	Inhouse	
24	5/7/2021	Covidwd	Monitor	Display problem	Not repairable	
25	7/7/2021	ECG OPD	ECG Machine	Button not working	Inhouse	
26	10/7/2021	Ophthal wd	BP APP	Not working	Inhouse	
27	12/7/2021	MSW 205	BP APP	Murcury tube broken	Inhouse	
28	13-7-21	Micro	Autoclave	Coil burnt	Outsource	
29	17-7-21	OT CSSD	ETO	Motar burnt	Outsource	
30	20-7-21	OT	Tourniquet	Display problem	Inhouse	

31	21-7-21	ENT OPD	Audiometer	Not working	Inhouse	
32	24-7-21	Casualty	Monitor	wire burnt	Inhouse	
33	26-7-21	NICU	Pulse oxymeter	Display problem	Outsource	
34	23-7-21	OBGY OPD	NST Machine	Not working	Outsource	
35	24-7-21	MMW	BP APP	LEAK	Inhouse	
36	27-7-21	PNC	BP APP	Not working	Inhouse	
37	28-7-21	NICU	Warmer	not getting heat	Inhouse	
38	29-7-21	OT	Drill machine	Not working	Outsource	
39	29-7-21	ENT OT	Debrider	Not working	Outsource	
40	1/6/2021	Physiotherapy	BP app	ballon torn	Inhouse	
41	3/6/2021	OT	endoscopy	Softwareproblem	Outsource	
42	3/6/2021	NICU	SPO2 probe	sensor faulty	Inhouse	
43	7/6/2021	Ophthal OPD	Vision drum	remot faulty	Inhouse	
44	7/6/2021	Casualty	Monitor	Display not working	Inhouse	
45	10/6/2021	Microbiology	Incubator	Not working	Inhouse	
46	11/6/2021	OT	Warmer	notgetting heat	Inhouse	
47	14-7-21	CSSD	Sealing machine	Not getting heat	Inhouse	
48	15-6-21	NICU	Syringe Pump	Not working	Inhouse	
49	18-6-21	NICU	Syringe Pump	Not working	Inhouse	
50	23-6-21	Microbiology	Autoclave	coil burnt	Inhouse	
51	23-6-21	MMW	BP app	Lekage	Inhouse	
52	23-6-21	FMW	BP app	Not working	Inhouse	
53	23-6-21	Physiotherapy	Ultrasound quality	connection broken	Inhouse	
54	24-6-21	OT	ETCO2 CABLE	Not working	Outsource	
55	25-6-21	PNC	Baby wt machine	Cable broken	Inhouse	
56	29-6-21	Physiology	ECG Cmachine	Battery faulty	new given	
57	30-6-21	OT	Bi-polaer cable	Not working	Inhouse	
58	4/5/2021	OBS 108	NST machine	button not working	Inhouse	
59	6/5/2021	NICU	Syringe pump	not working	Inhouse	
60	6/5/2021	OBS 108	SPO2 probe	broken	Not repairable	
61	7/5/2021	Dialysis	Dialysismachine	flow alarm	Outsource	
62	11/5/2021	MOW	BP app	not working	Inhouse	
63	15-5-21	Casualty	monitor	Display not showing	Inhouse	
64	17-5-21	PNC	Baby weight machine	not working	Inhouse	

65	21-5-21	mow mmw msw	BP app	not working	Inhouse	
66	21-5-21	Medicine OPD	BP app	Leakage	Inhouse	
67	24-5-21	OBS 108	NST machine	not working	Inhouse	
68	26-5-21	PNC	Pulse oxy	not working	Not repairable	
69	28-5-21	OT CSSD	Sealing machine	rubber damage	Inhouse	
70	1/4/2021	ENT OT	Microscope bean splitter	not visualize clear image	not repairable	
71	1/4/2021	OT CSSD	Ultrasonic machine	not working	Inhouse	
72	1/4/2021	Covid wd	O2 flow meter	leakage	Inhouse	
73	1/4/2021	NICU	Warmer	not getting heat	Inhouse	
74	2/4/2021	NICU/PICU	Central o2 line	leakage	Outsource	
75	5/4/2021	ICU	BP app	hinges broken	Inhouse	
76	9/4/2021	OT CSSD	C-arm	not working	Outsource	
77	14-4-21	Casualty	Pulse oxy	not working	Inhouse	
78	21-4-21	Biochem CCL	SEMI AUTO ANA	not working	Outsource	
79	22-4-21	Covid wd	Needle cutter	not working	not repairable	
80	23-4-21	OBS Wd	Pulse oxy	loose	Inhouse	
81	26-4-21	BLOOD BANK	Micropipets	callibration needed	Outsource	
82	27-4-21	BLOOD BANK	BP app	leakage	Inhouse	
83	29-4-21	OBS Wd	Weight machine	not working	not repairable	
84	1/3/2021	OBS 108	Central O2 line	LINE LEAK	outsource	
85	25-3-21	OT	Central Suction line	chocked	outsource	
86	25-3-21	OBS 108	stand lamp	broken	not repairable	
87	25-3-21	OBS 108	Pulse oxymeter	broken	Inhouse	
88	25-3-2	MOW	BP app	broken	Inhouse	
89	25-3-21	ICU	Suction machine	broken	Inhouse	
90	25-3-21	ENT OT	0 degree endoscope	broken	not repairable	
91	29-3-21	Casualty	BP app	broken	Inhouse	
92	29-3-21	COVID WD	Needle cutter	broken	Inhouse	
93	29-3-21	Psy	BP app	broken	Inhouse	
94	30-3-21	Casualty	Pulse oxymeter	broken	not repairable	
95	1/2/2021	mmw	BP App	Air leakage	Inhouse	
96	1/2/2021	OBG 108	NST Machine	record button problem	Inhouse	
97	2/2/2021	Blood bank	HB Meter	charger broken	given new	
98	3/2/2021	ENT OT	DEBRIDER	Not working	Outsource	

99	5/2/2021	Physiotherapy	EMG	Electrodes broken	Inhouse	
100	5/2/2021	Physiotherapy	IFT	DISPLAY not showing	Inhouse	
101	5/2/2021	NICU	WARMER	DISPLAY not showing	Inhouse	
102	5/2/2021	NICU	Ventillator	software problem	Outsource	
103	8/2/2021	Physiotherapy	stimulator-03	knob not working	Inhouse	
104	10/2/2021	NICU	central O2	leakage	Outsource	
105	10/2/2021	OBG 108	BP App	hinges broken	Inhouse	
106	12/2/2021	mmw b-20	BP App	rubber bag leakage	Inhouse	
107	15-2-21	NICU	compressor	rust and broken	not repairable	
108	17-2-21	OT	suction machine	needservicing	Outsource	
109	19-2-21	Radiology	x ray	not getting start	Outsource	
110	20-2-21	OT	CAUTERY	Foot switch not working	Inhouse	
111	22-2-21	Ophthal OPD	Slit lamp	lampfuse	Outsource	
112	25-2-21	Physiotherapy	stimulator	knob not working	Inhouse	
113	25-2-21	Physiotherapy	IFT	Output not showing	Inhouse	
114	25-2-21	DentalOPD	Sterlizer	not getting heat	not repairable	
115	1/1/2021	OT	Monitor	SPO2 not working	Inhouse	
116	2/1/2021	Physiotherapy	Stimulator	Shock	Outsource	
117	2/1/2021	Physiotherapy	Ultrasound	Head cable fulty	Inhouse	
118	2/1/2021	ICU	BP App	Bolloon leak	Inhouse	
119	5/1/2021	CCL	Vitros	Hange software	Inhouse	
120	5/1/2021	ICU	ECG Cable	Not working	Inhouse	
121	8/1/2021	Covid ICU	BP App	Rubber bag faulty	Inhouse	
122	8/1/2021	PNC	BP App	Bolloon leak	Inhouse	
123	13/1/2021	Casualty	O2 flow meter	leak	Inhouse	
124	13-1-2021	OBGY OPD	NST	Print door faulty	Outsource	
125	13-1-2021	Medicine OPD	BP App	Rubber bag faulty	Inhouse	
126	13-1-2021	Rediology	X-Ray	Not working	Outsource	
127	18-1-21	NICU	WARMER	Not getting heat	Outsource	
128	22-1-21	PICU	Infusion pump	Not working	Inhouse	
129	27-1-21	Skin OPD	Phototherapy	light fuse	Outsource	
130	29-1-21	Ortho OPD	Plaster cutter	Not working	Outsource	
131	2/11/2020	PNC 106	BP App-02	rubber bag ,balloon valve fa	Inhouse	
132	2/11/2020	Physiotherapy	BP App	cell dry	Inhouse	

133	2/11/2020	Physiotherapy	EMS	knob broken	Inhouse	
134	3/11/2020	Covid ICU	Ventillator	Battery not working	Outsource	
135	3/11/2020	NICU	Syringe pump-	knob broken	Inhouse	
136	6-11-202	Phathalogy CCL	REMI Centrifuge	not working	Inhouse	
137	7/11/2020	OT	Tornicate	Leakage	Inhouse	
138	10/11/2020	Covid 22	Monitor	on/off button problem	Inhouse	
139	3/11/2020	NICU	Redient warmer	coil faulty	Inhouse	
140	13/11/2020	OBS 108	monito-03r	not working	Inhouse	
141	10/10/2020	NICU	Laryngoscope-	not working	Inhouse	
142	2/11/2020	PNC 106	BP App-02	rubber bag ,balloon valve fa	Inhouse	
143	2/11/2020	Physiotherapy	BP App	cell dry	Inhouse	
144	2/11/2020	Physiotherapy	EMS	knob broken	Inhouse	
145	3/11/2020	Covid ICU	Ventillator	Battery not working	Outsource	
146	3/11/2020	NICU	Syringe pump-	knob broken	Inhouse	
147	6-11-202	Phathalogy CCL	REMI Centrifuge	not working	Inhouse	
148	7/11/2020	OT	Tornicate	Leakage	Inhouse	
149	10/11/2020	Covid 22	Monitor	on/off button problem	Inhouse	
150	3/11/2020	NICU	Redient warmer	coil faulty	Inhouse	
151	13/11/2020	OBS 108	monito-03r	not working	Inhouse	
152	10/10/2020	NICU	Laryngoscope-	not working	Inhouse	
153	12/10/2020	FMW	BP App	rubber bag faulty	Inhouse	
154	13/10/2020	FLU OPD	BP App	ballon ,valve faulty	Inhouse	
155	13/10/2020	PNC 106	BP App	ballon ,valve faulty	Inhouse	
156	15/10/2020	CCL Pathalogy	Microscope	bulbe and holder not workir	Outsource	
157	15-10-2020	Covid ICU	Pulse Oxymeter	not working	Inhouse	
158	16-10-2020	Non Covid icu	Defebb	not charging	Inhouse	
159	17-10-2020	CSSD	Autoclave	RESET problem	Inhouse	
160	21-10-2020	PSM	BP App-03	ballon ,valve faulty	Inhouse	
161	21-10-2020	Casualty	Pulse Oxymeter	not working	Inhouse	
162	21-10-2020	OT	Endoscopy processor	not working	Outsource	
163	23-10-2020	Research center	CO2 PIPE	Leakage	Inhouse	
164	23-10-2020	NICU	Warmer	heater not working	Outsource	
165	22-10-2020	OT	Stryker trolley	not working	Outsource	

166	24-10-2020	Covid ward b22	Pulse Oxymeter	not working	Inhouse	
167	24-10-2020	Covid ward b22	ECG Machine	not working	Inhouse	
168	26-10-2020	OT	Ortho ot table	not working	Outsource	
169	28-10-2020	Physiotherapy	EMS, Stimulator	not working	Inhouse	
170	29-10-2020	Covid ICU 22	ECG Machine	not working	Inhouse	
171	29-10-2020	Covid ICU 22	Cardiac monitor	not working	Inhouse	
172	29-10-2020	Non Covid icu	o2 meter	broken	not repairable	
173	29-10-2020	Non Covid icu	Nebulizer	not working	inhouse	
174	30-10-2020	NICU	Syringe pump	knob broken	inhouse	
175	31-10-2020	Covid ward 309	o2 meter	not working	Inhouse	
176	1/10/2020	ECG OPD	ECG Machine	printer jamed and on/off iss	Inhouse	
177	1/10/2020	Non Covid icu	Laryngoscope-4	battery problem	Inhouse	
178	1/10/2020	OBS 108	NST	Recorder not working	Inhouse	
179	3/10/2020	NICU	BP App	not working	Inhouse	
180	3/10/2020	NICU	central Suction	not working	Inhouse	
181	3-10-202	Covid ICU	Syringe pump-2	not working	Inhouse	
182	5/10/2020	OBS 108	BP App	rubber bag faulty	Inhouse	
183	6/10/2020	OT	Baby weight m/c	not working	not repairable	
184	9/10/2020	Non Covid ICU	Monitor	display problem	Inhouse	
185	9/10/2020	OBS 108	BP App	hinges broken	Inhouse	
186	10/10/2020	NICU	Laryngoscope-	not working	Inhouse	
187	12/10/2020	FMW	BP App	rubber bag faulty	Inhouse	
188	13/10/2020	FLU OPD	BP App	ballon ,valve faulty	Inhouse	
189	13/10/2020	PNC 106	BP App	ballon ,valve faulty	Inhouse	
190	15/10/2020	CCL Pathalogy	Microscope	bulbe and holder not workin	Outsource	
191	15-10-2020	Covid ICU	Pulse Oxymeter	not working	Inhouse	
192	16-10-2020	Non Covid icu	Defebb	not charging	Inhouse	
193	17-10-2020	CSSD	Autoclave	RESET problem	Inhouse	
194	21-10-2020	PSM	BP App-03	ballon ,valve faulty	Inhouse	
195	21-10-2020	Casualty	Pulse Oxymeter	not working	Inhouse	
196	21-10-2020	OT	Endoscopy processor	not working	Outsource	
197	23-10-2020	Research center	CO2 PIPE	Leakage	Inhouse	
198	23-10-2020	NICU	Warmer	heater not working	Outsource	

199	22-10-2020	OT	Stryker trolley	not working	Outsource	
200	24-10-2020	Covid ward b22	Pulse Oxymeter	not working	Inhouse	
201	24-10-2020	Covid ward b22	ECG Machine	not working	Inhouse	
202	26-10-2020	OT	Ortho ot table	not working	Outsource	
203	28-10-2020	Physiotherapy	EMS, Stimulator	not working	Inhouse	
204	29-10-2020	Covid ICU 22	ECG Machine	not working	Inhouse	
205	29-10-2020	Covid ICU 22	Cardiac monitor	not working	Inhouse	
206	29-10-2020	Non Covid icu	o2 meter	broken	not repairable	
207	29-10-2020	Non Covid icu	Nebulizer	not working	inhouse	
208	30-10-2020	NICU	Syringe pump	knob broken	inhouse	
209	31-10-2020	Covid ward 309	o2 meter	not working	Inhouse	
210	1/9/2020	Casualty	SPO2 Probe	not working	Inhouse	
211	1/9/2020	FMW	BP App	not working	Inhouse	
212	1/9/2020	Covid ICU	Monitor-1	not working	Inhouse	
213	1/9/2020	Covid ICU	Flow meter-4	not working	Inhouse	
214	2/9/2020	Covid ICU	flow meter-5	not working	Inhouse	
215	2-9-202	Covid ICU	Ventillator	not working	Inhouse	
216	3/9/2020	NICU	Ventillator	O2 sensor problem	Outsource	
217	3/9/2020	Micro	Cooling Incubator	not working	Inhouse	
218	7/9/2020	Covid ICU	Ventillator	not working	Inhouse	
219	7/9/2020	Covid ICU	Monitor-1	not working	Inhouse	
220	7/9/2020	Covid ICU	Flow meter-8	not working	Inhouse	
221	7/9/2020	PNC 106	BP App	not working	Inhouse	
222	7/9/2020	OT	Warmer	cable not working	Inhouse	
223	9/9/2020	Covid ICU	Pulse Oxymeter	not working	Inhouse	
224	12/9/2020	Radiology	fuji film printer	not working	Outsource	
225	16-9-2020	Recovery ICU	BP App	ballon faulty	Inhouse	
226	16-9-2020	PNC 106	BP App	rubber bag faulty	Inhouse	
227	16-9-2020	Micro	weight machine	on/off button not working	Inhouse	
228	17-9-2020	Casualty labour room	Pulse Oxymeter	not working	not repairable	
229	18-9-2020	MSW/MMW/MOW	BP App	not working	Inhouse	
230	18-9-2020	MSW/MMW/MOW	Monitor-1	not working	Inhouse	
231	21-9-2020	Casualty labour room	Pulse Oxymeter	broken	not repairable	
232	19-9-2020	Covid ICU	Monitor-1	not working	Inhouse	

233	19-9-2020	Covid ICU	Suction Machine	not working	Outsource	
234	19-9-2020	Covid ICU	Ventillator	not working	Inhouse	
235	21-9-2020	OBGY OPD	BP App -2	not working	Inhouse	
236	22-9-2020	Non Covid icu	BP App	not working	Inhouse	
237	22-9-2020	Non Covid icu	Monitor-2	not working	Inhouse	
238	22-9-2020	Covid icu	Monitoe- 4	not working	Inhouse	
239	25-9-2020	Non Covid icu	Nebulizer	not working	Inhouse	
240	26-9-2020	Non Covid icu	BP App	rubber bag faulty	Inhouse	
241	28-9-2020	Covid icu	Ventillator	not working	inhouse	
242	26-9-2020	Ophthal OPD	Microscope	light not working	inhouse	
243	28-9-2020	Covid ICU	ventillator-5	not working	Inhouse	
244	28-9-2020	covid ICU	Monitor	not working	Inhouse	
245	29-9-2020	OBGY OPD	BP App	rubber bag faulty	Inhouse	
246	30-9-2020	Covid ICU	Syringe pump	not working	Inhouse	

Biomedical maintenance details for - 2020

Sr.no	Date	Department	Equipment name	Breakdown	Action taken (Inhouse/ Outsource)	Remark
1	31.8.2020	Covid ICU	monitor-4	not working, broken	Inhouse	
2	29.8.2020	Covid ICU	Ventillator	O2 leak	Inhouse	
3	28.8.2020	Covid ICU	BP App-1	Rubber bag faulty	Inhouse	
4	27.8.2020	Covid ICU	BP App-1	not working	Inhouse	
5	27.8.2020	Covid ICU	Syringe pump-1	not working	Inhouse	
6	27.8.2020	Covid ICU	monitor-5	not working	Inhouse	
7	27.8.2020	Covid ICU	Ventillator-3	not working	Inhouse	
8	24.8.2020	covid ICU	pulse oxymeter-3	not working	Inhouse	
9	24.8.2020	Casualty	BP App-3	mercury leak,tube .reubber bag faulty	Inhouse	
10	20.8.2020	Covid ICU	Ventillator	not working	Inhouse	
11	19.8.2020	CCL	Nyco-card reader	not working	Inhouse	
12	17.8.2020	Covid ICU	Ventillator	not working	Outsource	
13	17.8.2020	MMW	BP App	Hinges broken	Inhouse	
14	14.8.202	NICU	SPO2	Sensor not working	Inhouse	
15	12.8.2020	Covid ICU	3 Pulse oxymeter	not working	Inhouse	
16	7.8.2020	Casualty	Ventillator	FIO2 problem	Outsource	
17	7.8.2020	Microbiology	Cooling incubator	required fuse	Inhouse	
18	7.8.2020	NICU	pulse oxymeter	Exyention cable problem	Inhouse	
19	7.8.2020	NICU	Syringe pump	s/w faulty	Inhouse	
20			Minicentrifuge	UV Light	Inhouse	
21			Thermocycler	Display problem	Inhouse	
22	1.8.2020	Microbiology	Dry bath	Temp distrub	Inhouse	
23	30.7.2020	Covid icu	Pulse Oxymeter	Setting probem	Inhouse	
24	28.7.2020	covid ICU 22,24,206	Syringe pump	Setting probem	Inhouse	
25	27.7.2020	Medicine OPD	BP App	Rubber bag,valve,ballon,cuff faulty	Inhouse	
26	27.7.2020	Covid icu	Syringe pump	not working	inhouse	
27	27.7.2020	Covid icu	Pulse Oxymeter	not working	inhouse	
28	27.7.2020	Covid icu	Multipara monitor	hose pipe,spo2 probe,NIBP cuff faulty	Inhouse	
29	27.7.2020	Covid icu	Ventillator	FIO2 Problem	Outsource	

30	27.7.2020	Covid icu	Air Liquid	O2 sensor faulty	Outsource	
31	27.7.2020	Covid icu	Ventillator	FIO2 Problem	Outsource	
32	27.7.2020	Covid icu	Ventillator	FIO2 Problem	Outsource	
33	25.7.2020	ICU/OT	EMCO Monitor	SPO2 Probe faulty	Inhouse	
34	24.7.2020	Covid ICU	F/A Valve	not working	Inhouse	
35	22.7.2020	Covid ICU	Flow meter -03	not working	Inhouse	
36	21.7.2020	NICU	Warmer-2	Heater faulty	Inhouse	
37	20.7.2020	ECG OPD Medicine	ECG Machine	Printer problem	Inhouse	
38	20.7.2020	Medicine OPD	BP App	ballon faulty	Inhouse	
39	20.7.2020	Medicine OPD	BP App	rubber bag faulty	Inhouse	
40	18.7.2020	Covid ICU 206	BPC Flow meter	not working	Inhouse	
41	17.7.2020	NICU	Pulse Oxymeter	SPO2 Probe faulty	Inhouse	
42	16.7.2020	Casualty B-1	Multipara monitor	ECG Cable faulty	Inhouse	
43	16.7.2020	Casualty B-1	Multipara monitor	ECG Cable faulty	Inhouse	
44	15.7.2020	FMW B-15	Nebulizer m/c	vapour problem	Inhouse	
45	13.7.2020	OT CSSD	Autoclave machine	not working	Outsource	
46	9.7.2020	Casualty-B1	BP App	baloon faulty	Inhouse	
47	9.7.2020	ANC Ward-108	BP App	rubber bag faulty	Inhouse	
48	8.7.2020	Dialysis	RO Water plant	RO need to be servicing	Outsource	
49	1.7.2020	NICU	Syringe pump	plunger faulty	Inhouse	
50	4.7.2020	Casualty	OT Lamp	Transformer faulty	Outsource	
51	6.7.2020	ECG Room	ECG Machine	ON-OFF Switch problem	Inhouse	
52	6.7.2020	OT No 6	OT Table	not working	Outsource	
53	6.7.2020	OT No-4	OT Table	not working	Outsource	
54	3.7.2020	OT No-4	Celling lamp	not working	Outsource	
55	1.7.2020	OBS-108	NST Machine	not working	Inhouse	
56	1.7.2020	OBS-108	NST Machine	not working	Inhouse	
57	30.6.2020	Physiotherapy college	weighing scale	Not working	Inhouse	
58	29.6.2020	NICU	Syringe pump	Plunger getting stucked	Inhouse	
59			Incubator-1	thermostate faulty	Outsource	
60	26.6.2020	Microbiology	Hot air oven-2	coil, indicator & thermostate faulty	Outsource	
61	26.6.2020	Non-Covid ICU	Ventllator	Battery faulty	Outsource	
62	25.6.2020	CCL- Bio chem	Centrifudge	carbon brush faulty	Inhouse	
63	25.6.2020	CCL- Bio chem	Centrifudge	Lock problem	Inhouse	
64	22.6.2020	PNC-106	BP App	rubber bag	Inhouse	

65	22.6.2020	NICU	Multipara monitor	NIBP Problem	Inhouse	
66	19.6.2020	OT CSSD	Autoclave m/c	Gasket problem	Outsource	
67	17.6.2020	CCL- Bio chem	Centrifuge	carbon brush faulty	Inhouse	
68	16.6.2020	NICU	Nebulizer	vepour probem	Inhouse	
69	12.6.2020	OBS-108	NST Machine	Printing problem	Inhouse	
70	9.6.2020	ICU	Multipara monitor	BP Connection not found	Inhouse	
71	6.6.2020	Microbiology	Deep fridge	temp problem	Outsource	
72	6.6.2020	Respiratory ward	Nebulizer	not repairable	Inhouse	
73	6.6.2020	Casualty	Flow meter	Top glass broken	Inhouse	
74	5.6.2020	Casualty	BP App	Hinges broken	Inhouse	
75	5.6.2020	OBS-108	BP App	bp ballon faulty	Inhouse	
76	4.6.2020	OT	Defibrillator	Battery faulty	Outsource	
77	3.6.2020	OT CSSD	Autoclave m/c	Door gasket faulty	Outsource	
78	3.6.2020	FMW	BP App	BP Ballon, valve, rubber bag, cuff faulty	Inhouse	
79	2.6.2020	NICU	Multipara monitor	Not working	Inhouse	
80	1.6.2020	OBS-108	NST Machine	Record switch faulty	Inhouse	
81	1.6.2020	OBGY OPD	BP App	BP Ballon, valve, rubber bag, cuff faulty	Inhouse	
82	11.5.2020	PICU	Ventillator	O2 connection leakage	Inhouse	
83	30.5.2020	OBGY OPD	NST Machine	touch s/w faulty	Inhouse	
84	29.5.2020	OT-2,3,5	Multipara monitor	NIBP Cuff leakage-3	Inhouse	
85	28.5.2020	NICU	Multipara monitor	9-14 neonatal NIBP Cuff faulty connector broken	Inhouse	
86	27.5.2020	OT CSSD	Autoclave machine horizontal	one wire removed	outsource	
87	26.5.2020	OT No 6	Multipara monitor	SPO2 probe faulty	Inhouse	
88	25.5.2020	NICU	Multipara monitor	SPO2 probe faulty	Inhouse	
89	25.5.2020	NICU	Radiant warmer	coil faulty	Inhouse	
90	25.5.2020	NICU	Radiant warmer	coil faulty	Inhouse	
91	25.5.2020	NICU	Radiant warmer	coil faulty	Inhouse	
92	25.5.2020	Dialysis	Dialysis machine-2	conductivity problem	outsource	
93	23.5.2020	Dialysis	Dialysis machine	conductivity problem	outsource	
94	22.5.2020	ICU	ECG Machine	ECG Cable faulty	Inhouse	
95	21.5.2020	NICU	Radiant warmer	Not working	Inhouse	
96	19.5.2020	NICU	Syringe pump	plunger broken	Inhouse	
97	19.5.2020	NICU	Syringe pump	Not working	Inhouse	

98	19.5.2020	Blood bank	Digital weighing M/C	Battery faulty	Inhouse	
99	18.5.2020	OT CSSD	Autoclave machine	Heating machine	outsource	
100	16.5.2020	Casualty	Syringe pump	Battery faulty	Inhouse	
101	16.5.2020	Casualty	Syringe pump	Battery faulty	Inhouse	
102	11.5.2020	casualty B-1	BP App	BP Ballon and valve faulty	Inhouse	
103	15.5.2020	NICU	Radiant warmer	over heat	Inhouse	
104	15.5.2020	NICU	Radiant warmer	Not working	Inhouse	
105	14.5.2020	ICU	Multipara monitor	SPO2 probe faulty	Inhouse	
106	9.5.2020	FMW	F/A Valve	leakage	Outsource	
107	7.5.2020	ICU	BP App	Hinges broken	Inhouse	
108	7.5.2020	ICU	Ventilator	Regulator faulty	Outsource	
109	8.5.2020	Casualty	Central O2	leak	Outsource	
110	8.5.2020	Casualty	Central suction	leak	Outsource	
111	5.5.2020	MMW B-20	BP App	BP Ballon and valve faulty	Inhouse	
112	5.5.2020	MMW B-20	BP App	BP Ballon and valve faulty	Inhouse	
113	4.5.2020	PNC-106	BP App	Rubber bag and cuff faulty	Inhouse	
114	1.5.2020	NICU	Radiant warmer	Sensor connector	Outsource	
115	1.5.2020	NICU	Radiant warmer	Half heat	Outsource	
116	1.5.2020	NICU	Radiant warmer	coil problem	Inhouse	
117	1.5.2020	Blood Bank	Autoclave machine	digital temp error	Outsource	
118	27.4.2020	ICU	ECG Machine	ECG Cable faulty	Inhouse	
119	27.4.2020	ICU/FOW	X-Ray machine	3-PIN Top not found	Inhouse	
120	27.4.2020	ICU	X-Ray machine	not working	outsource	
121	22.4.2020	Respiratory ward/opthal	Nebulizer	Not working, not repairable	Inhouse	
122	21.4.2020	MMW B-20	Central suction	leakage	outsource	
123	21.4.2020	CCL-Bio chem	Trop-T analyzer	error- E-204	outsource	
124	5.4.2020	NICU	Radiant warmer	coil faulty	Inhouse	
125			Pulse oxymeter	spo2 probe faulty	Inhouse	
126	15.4.2020	ICU	Difibrillator-2	Battery faulty	Inhouse	
127	15.4.2020	MMW B-20	BP App-3	rubber bag	Inhouse	
128	14.4.2020	OT	Multipara Monitor	SPO2 Probe connector broken	Inhouse	
129	14.4.2020	OT	Ambu bag	leakage	Inhouse	
130	14.4.2020	OT	Laryngoscope	4 Blade bulb faulty	Inhouse	
131	14.4.2020	FSW 204	F/A Valve bottle	leakage	Inhouse	
132	13.4.2020	NICU	Radiant warmer	coil faulty	Inhouse	

133	13.4.2020	NICU	Syringe pump	Not working-2	Inhouse	
134	11.4.2020	NICU	Multipara Monitor	SPO2 Probe faulty-2 ADULT	Inhouse	
135	8.4.2020	FOW	BP App	rubber bag	Inhouse	
136	8.4.2020	FSW 204	BP App	Glass tube faulty	Inhouse	
137	6.4.2020	FMW B-22	Syringe pump	Battery, pump faulty	Inhouse	
138	6.4.2020	FMW B-22	O2 flow meter	leakage	Inhouse	
139	6.4.2020	NICU	Pulse oxymeter	SPO2 Probe faulty	Inhouse	
140	6.4.2020	NICU	Syringe pump	keypad problem	Inhouse	
141	2.4.2020	NICU/PICU	Multipara Monitor	2-NIBP Cuff leak	Inhouse	
142	2.4.2020	MSW B-205	BP App	BP Ballon, valve faulty	Inhouse	
143	2.4.2020	NICU	Multipara Monitor	SPO2 Probe faulty	Inhouse	
144	1.4.2020	Skin OPD	Microscope	need servicing	outsource	
145	31.3.2020	OT	Nitrous manifold	regulator of manifold crck	outsource	
146	30.3.2020	MMW B-20	Nebulizer	Vapour problem	inhouse	
147	27.3.2020	ICU	Ventillator	O2 pipe loose connection	inhouse	
148	27.3.2020	FSW	BP App	Hinges broken	inhouse	
149		OBGY OPD	BP App		inhouse	
150	27.3.2020	OBGY OPD	BP App		inhouse	
151	27.3.2020	ICU	2D Echo	software currepted	outsource	
152	16.3.2020	CCL-Bio Chem	Centrifuge-2	carbun brush faulty	inhouse	
153	24.3.2020	PICU	Multipara monitor	1-SPO2 Probe not working	inhouse	
154	23.3.2020	OBS 108	BP App		inhouse	
155	23.3.2020	Radiology	X-Ray machine		outsource	
156	21.3.2020	NICU	X-Ray machine	wheel broken	outsource	
157	21.3.2020	Medicine OPD-	BP App		inhouse	
158	20.3.2020	PNC-106	BP App		inhouse	
159	18.3.2020	Medicine OPD-25	BP App	BP ballon valve faulty	inhouse	
160	17.3.2020	ICU	Multipara monitor	4-SPO2,1-ECG Cable faulty	inhouse	
161	16.3.2020	NICU	Nebulizer	not working	inhouse	
162	11.3.2020	Medicine OPD-25	BP App		inhouse	
163	11.3.2020	OT	Multipara monitor	NIBP Cuff leak	inhouse	
164	11.3.2020	OBGY OPD	BP App	Rubber bag faulty	inhouse	
165	5.3.2020	UHTC	BP App	hinges,rubber bag,balloon,valve faulty	inhouse	
166	9.3.2020	casualty B-1	BP App	Bulb and valve faulty	inhouse	
167	9.3.2020	casualty B-1	Laryngoscope	4 bulb faulty	inhouse	

168	7.3.2020	NICU	Radiant wramer	coil faulty	inhouse	
169	5.3.2020	FOW FENT	BP App	BP Ballon Rubber bag leak, cuff, valve	inhouse	
170	5.3.2020	OBGY OPD	BP App	BP Ballon Rubber bag leak	inhouse	
171	5.3.2020	PNC106	entral O2 connector	Leakage	outsource	
172	5.3.2020	OT	Pulse Oxymeter	SPO2 Probe faulty	inhouse	
173	5.3.2020	OT	Multipara monitor	Adapter connectoe faulty	inhouse	
174	2.3.2020	PNC Ward	BP App	Leakage	inhouse	
175	2.3.2020	PSY Ward	BP App	BP Ballon Rubber bag leak	inhouse	
176	2.3.2020	Physiotherapy	Ultrasound	totally off	inhouse	
177	29.2.2020	ICU	Multipara monitor	SPO2 Probe faulty	Inhouse	
178	29.2.2020	ICU	BP app	Ballon faulty	Inhouse	
179	29.2.2020	OT	Foot suction m/c	motor problem	Inhouse	
180	29.2.2020	OT	Electrical saw	saw blade's movement stop	Inhouse	
181	26.2.2020	MMW-B-24	BP app		Inhouse	
182	25.2.2020	OT CSSD	Ultra sonic cleaner	water leakage	Inhouse	
183	25.2.2020	MOW	Suction machine	mains cable brunt, glass bottle broken	Inhouse	
184	24.2.2020	Paed ward	Nebulizer		Inhouse	
185	24.2.2020		cautery machine	not working	outsource	
186	24.2.2020	OT No-8	cautery machine	main bourd faulty	outsource	
187	24.2.2020	paeds	wepghing machine	batteries , touch s/w faulty	Inhouse	
188	20.2.2020	ICU	Ventillator	o2 connection leakage	outsource	
189	20.2.2020	Paed OPD	Stethoscope	ear piece faulty	Inhouse	
190	20.2.2020	Physiotherapy	IFT	black channel problem	Inhouse	
191	20.2.2020	Physiotherapy	IFT	Intensify knob problem	Inhouse	
192	19.2.2020	GBB	BP app	glass tube broken	Inhouse	
193	17.2.2020	GBB	BP app		Inhouse	
194	15.2.2020	OBGY OPD	BP app		Inhouse	
195	14.2.2020		Multipara monitor		Inhouse	
196	14.2.2020	NICU	Pulse oxymeter		Inhouse	
197	14.2.2020	Pysiotherapy	Ultra sound	leakage of probe	Inhouse	
198	15.2.2020	OBGY OPD	BP app		Inhouse	
199	14.2.2020	Dialysis	RO Plant	TDS High	outsource	
200	14.2.2020	Medicine OPD	BP app		Inhouse	
201	14.2.2020	Medicine OPD	BP app		Inhouse	
202	14.2.2020	NICU	Pulse oxymeter	SPO2 Probe faulty	Inhouse	

203	13.2.2020	MOW	BP app	Ballon faulty	Inhouse	
204	13.2.2020	OT CSSD	Sealing m/c	coil faulty	Inhouse	
205	12.2.2020	F-ENT, F Skin	Needle cutter	not burn	Inhouse	
206	13.2.2020	FMW B-22	BP app	Ballon faulty	Inhouse	
207	12.2.2020	Paed ward	Nebulizer	vapour problem	Inhouse	
208	12.2.2020	FMW B-22	BP app	Rubber bag leakage	Inhouse	
209	6.2.2020	Casualty	Multipara monitor	SPO2 Probe Clip broken	Inhouse	
210	6.2.2020	NICU	Pulse oxymeter	SPO2 Probe faulty	Inhouse	
211	5.2.2020	Gyn-108	NST Machine	US Probe faulty	Inhouse	
212	3.2.2020	GBB	BP app	leakage	Inhouse	
213	31.1.2020	Paed-B-18	nebulizer	vapour problem	Inhouse	
214	31.1.2020	NICU	Central suction	bottle cap broken	Inhouse	
215	29.1.2020	Radiology	X-ray machine	Fluro not working	outsource	
216	28.1.2020	obgy OPD	BP AP	Ballon leakage	Inhouse	
217	27.1.2020	PNC	BP AP	rubber bag faulty	Inhouse	
218	27.1.2020	OBS WD 108	NST Machine	US Probe problem	Inhouse	
219	24.1.2020	Physiotherapy	IFT M/C	Fuse faulty	Inhouse	
220	24.1.2020	Casualty	Central oxygen	FA valve leakage	Inhouse	
221	24.1.2020	Casualty	Central suction	gasket broken	Inhouse	
222	22.1.2020	OBS WD 108	BP AP	Leakage	Inhouse	
223	21.1.2020	FMW B-22	FA VALVE	Leakage	Inhouse	
224	21.1.2020	OT Ortho	C-arm	image problem	outsource	
225	21.1.2020	OT Ortho	Cautery Machine	cut,coag problem	Inhouse	
226	19.1.2020	OT	Laryngoscope	000 no. blade faulty	Inhouse	
227	16.1.2020	NICU	Radiant Warmer	FLT msg Coming	outsource	
228	16.1.2020	NICU	multipara monitor	SPO2 Probe Connector pin broken	Inhouse	
229	15.1.2020	obgy OPD	NST Machine	record switch faulty	Inhouse	
230	15.1.2020	ICU	Ventillator	P.Insp.Msg	outsource	
231	15.1.2020	ICU	Adult Laryngoscope	blade faulty	Inhouse	
232	15.1.2020	OBS WD 108	ped laryngoscope	totally rusted	Inhouse	
233	14.1.2020	ICU	multipara monitor	SPO2 Probe faulty	Inhouse	
234		MSW 202	BP AP	Leakage	Inhouse	
235	13.1.2020	OT Opthal	Microscope	vision not clear	outsource	
236	11.1.2020	Medicine OPD	BP AP	Leakage	Inhouse	
237	8.1.2020	MMW-20	nebulizer	vapour problem	Inhouse	

238	6.1.2020	ICU	o2 flowmeter	Leakage	Inhouse	
239	6.1.2020	M/F Opthal	nebulizer	vapour problem	Inhouse	
240	4.1.2020	Casualty	multipara monitor	NIBP Cuff leakage	Inhouse	
241	4.1.2020	Opthal ward	BP AP		Inhouse	
242	4.1.2020	OT CSSD	Autoclave machine	Water motor faulty	outsource	
243	3.1.2020	Blood Bank	BP AP	Leakage	Inhouse	
244	2.1.2020	ICU	FA VALVE	Guage faulty	Inhouse	

Biomedical maintenance details for - 2019

Sr.No	Date	Department	Equipment name	Breakdown	Action taken (Inhouse/ Outsource)	Remark
1	31.12.2019	ICU	Central Suction	Bottle Adaptor broken	outsource	
2	30.12.2019	ENT OT	Light Source	LED faulty	inhouse	
3	30.12.2019	NICU	Radiant Warmer	Error problem	outsource	
4	30.12.2019	OBGY B16	Multipara Monitor	NIBP Connector broken	inhouse	
5	30.12.2019	OBGY B16	FA Valve	Gauge Faulty	outsource	
6	30.12.2019	ICU	Central Suction	Adaptor broken	outsource	
7	20.12.2019	OT Recovery	Multipara Monitor	NIBP Cuff Leakage	inhouse	
8	18.12.2019	OT - Surgery	Cystoscopy Sheath	Tape broken	outsource	
9	02.12.2019	Ophthal OPD	Vision Drum	Two remote faulty	inhouse	
10	02.12.2019	NICU	Multipara Monitor	SPO2 probe faulty	inhouse	
11	02.12.2019	OT	Multipara Monitor	Mains cable burnt	inhouse	
12	30.11.2019	PNC 106	Baby weight machine	battery faulty	Inhouse	
13	29.11.2019	CSSD	Flash Autoclave	one heater faulty	outsource	
14	25.11.2019	NICU	Radiant Warmer	Fuse faulty	Inhouse	
15	18.11.2019	Psychiatry OPD	Bio feed back machine	function problem	outsource	
16	14.11.2019	Skin & VD (Minor OT)	Crayo Gun	Pressure problem	outsource	
17	14.11.2019	NICU	Radiant Warmer	Totally off	Inhouse	
18	11.11.2019	CCL	Centrifuge machine	Carbon brush, rotating switch faulty	Inhouse	
19	09.11.2019	NICU	Radiant Warmer	Heater Faulty	Inhouse	
20	08.11.2019	ICU	Ventilator Draeger	O2 Connection problem	outsource	
21	07.11.2019	PICU	Central O2 Point	04 point Faulty	outsource	changed O2 point (04 Nos.) by new one
22	06.11.2019	NICU	Radiant Warmer	Heater Faulty	Inhouse	
23	05.11.2019	MMW	Suction machine	not working properly	outsource	
24	01.11.2019	Plaster cutting room	Plaster cutter machine	Cable Faulty	Inhouse	
25	18.10.2019	NICU	Multipara Monitor	SPO2 Probe Faulty	Inhouse	
26	17.10.2019	OT	Suction Trolley	Regulator & Selector Switch Faulty	outsource	
27	12.10.2019	ECG OPD	ECG Machine	Electrode Faulty	Inhouse	

28	10.10.2019	OT - CSSD	Autoclave Machine	MCB Switch problem	outsource	
29	07.10.2019	Micro Dept	Hot Air Oven	SSR Faulty	Inhouse	
30	04.10.2019	ICU	Multipara Monitor	SPO2 Probe Faulty	Inhouse	
31	30.09.2019	ECG OPD	ECG Machine	Print button Faulty	Inhouse	
32	24.09.2019	ICU	Multipara Monitor	ECG cable Faulty	Inhouse	
33	24.09.2019	Dialysis	Dialysis Machine	Water Leakage	Outsource	
34	23.09.2019	Dialysis	Multipara Monitor	SPO2 Probe Faulty	Inhouse	Issued new SPO2 probe
35	21.09.2019	ECG OPD	ECG Machine	Electrode Faulty	Inhouse	
36	20.09.2019	OT	Nerve Stimulator	Main board faulty	Outsource	
37	20.09.2019	NICU	Radiant Warmer	Coil Faulty	Inhouse	
38	18.09.2019	Radiology	X-ray Machine 500mA	Short circuit	Outsource	Varoac knob changed, but problem in HT Transformer, HT given for repairing purpose
39	13.09.2019	OT - CSSD	Autoclave Machine	Nano Faulty	Outsource	
40	12.09.2019	NICU	Radiant Warmer	Coil Faulty	Inhouse	
41	12.09.2019	MSW B202	Pulse Oximeter	Battery Problem	Inhouse	
42	14.09.2019	ECG OPD	ECG Machine	Battery Problem	Inhouse	
43	09.09.2019	NICU	Multipara Monitor	SPO2 Probe Faulty	Inhouse	
44	06.09.2019	ICU	Pulse Oximeter	SPO2 Probe Faulty	Inhouse	
45	03.09.2019	ECG OPD	ECG Machine	Electrode Faulty	Inhouse	
46	30.08.2019	OT	Multipara Monitor	NIBP Cuff Leakage	Inhouse	
47	30.08.2019	OBGY OPD	NST Machine	Printer Faulty	Outsource	
48	26.08.2019	Casualty	Multipara Monitor	SMPS Board Faulty	Outsource	
49	24.08.2019	ECG OPD	ECG Machine	Electrode Faulty	Inhouse	
50	22.08.2019	Ophthal OPD	Auto refracto meter	needs servicing	Outsource	
51	22.08.2019	ENT - OT	Stryker Camera	Image not seen on monitor	Outsource	
52	22.08.2019	OBGY OPD	Video Endo Trainer	Camera Faulty	Outsource	
53	21.08.2019	OT - CSSD	Air Gun Unit	Water gun broken	Outsource	
54	19.08.2019	Ophthal OPD	Vision Drum	Belt broken	Inhouse	
55	11.08.2019	NICU	Syringe pump	Keypad faulty	Inhouse	
56	09.08.2019	RADIOLOGY	X-ray machine	stabilizer's board burnt	Outsource	
57	06.08.2019	OT	Cauty machine	Off intermediently	Outsource	
58	06.08.2019	OT	Cauty machine	cut and coag problem	Inhouse	
59	05.08.2019	NICU	Radiant warmer	coil faulty	Inhouse	

60	02.08.2019	NICU	Syringe pump	Mains cable faulty	Inhouse
61	02.08.2019	Casualty	Central suction	Bottle cap broken	Inhouse
62	31.07.2019	OT NO-2	OT lamp	5 patel lamp faulty	Outsource
63	29.07.2019	ICU	Multipara monitor	Display faulty	Inhouse
64	25.07.2019	PICU	Multipara monitor	SPO2 Probe faulty	Inhouse
65	23.07.2019	OT	Ortho driving unit	driving unit faulty	Outsource
66	23.07.2019	ECG ROOM	ECG Machine	Electrode faulty	Inhouse
67	23.07.2019	OT	Anaesthesia machine	O2 Housing faulty	Outsource
68	23.07.2019	OT	Anaesthesia machine	O2 sensor faulty	Outsource
69	23.07.2019	CCL	Microscope	Lamp holder faulty	Inhouse
70	22.07.2019	RADIOLOGY	X-ray machine	hand switch faulty	Outsource
71	19.07.2019	CCL	centrifuge	lock faulty	Inhouse
72	19.07.2019	GYN B-108	Multipara monitor	SPO2 Probe faulty	Inhouse
73	17.07.2019	PNC B-106	Multipara monitor	SPO2 Probe faulty	Inhouse
74	08.07.2019	NICU	Syringe pump	Board problem	Inhouse
75	08.07.2019	RADIOLOGY	X-ray Machine	stabilizer faulty	Outsource
76	08.07.2019	ICU	Ventillator	not working	Outsource
77	06.07.2019	OT	Instrument washer	pump assy. Faulty	Outsource
78	04.07.2019	OBGY B-16	Multipara monitor	SPO2 Probe faulty	Inhouse
79	01.07.2019	ICU	ECG Machine	ECG cable faulty	Inhouse
80	28.06.2019	OT (CSSD)	Air Gun unit	Air pressure not come	Outsource
81	27.06.2019	OT (CSSD)	Auto clave machine	solonoid valved faulty	Outsource
82	26.06.2019	NICU	Pluse oxymetter	SPO2 Probe faulty	Inhouse
83	26.06.2019	OBGY B-108	Radiant Warmer	Air & skin sensor faulty	Inhouse
84	24.06.2019	OT	Multipara monitor	SPO2 Probe faulty	Inhouse
85	20.06.2019	casualty	Multipara monitor	Hose pipe broken	Inhouse
86	19.06.2019	OBGY B-108	Multipara monitor	SPO2 Probe faulty	Inhouse
87	19.06.2019	NICU	Radiant Warmer	Heater wire disconnect	Inhouse
88	19.06.2019	NICU	Radiant Warmer	Coil faulty	Inhouse
89	18.06.2019	PICU	Ventillator	O2 Sensor expired	Outsource
90	17.06.2019	ICU	ECG Machine	Electrode faulty	Inhouse
91	15.06.2019	OPHTHAL	Indirect Ophthalmoscope	lamp not blown	Inhouse
92	11.06.2019	OBGY B-108	NST Machine	Printing problem	Inhouse
93	10.06.2019	OT	Multipara monitor	NIBP Cuff leakage	Inhouse
94	10.06.2019	OT	Multipara monitor	ECG cable faulty	Inhouse

95	05.06.2019	OBGY B-108	Multipara metter	SPO2 Probe faulty	Inhouse	
96	01.06.2019	ECG OPD	ECG Machine	Battrey faulty	Inhouse	
97	30.05.2019	NICU	Multipara monitor	SPO2 Probe faulty	Inhouse	
98	30.05.2019	Physiology	polyrite-D	some function not working	Outsource	
99	27.05.2019	OT (CSSD)	Auto clave machine	not working	Outsource	
100	23.05.2019	URO OT	Nephroscope	Bridge not working	Outsource	
101	23.05.2019	OT (CSSD)	Auto clave machine	Bellow plate faulty	Outsource	
102	21.05.2019	ECG OPD	ECG Machine	Battery faulty	Inhouse	
103	19.05.2019	NICU	Radiant warmer	skin temp. Sensor faulty	Inhouse	
104	17.05.2019	URO OT	lithoplast	hand piece faulty	Outsource	
105	16.05.2019	URO OT	Nephroscope	Vision poor, water leakage	Outsource	
106	16.05.2019	ORTHO OT	C- Arm	Foot pad & ON/OFF switch faulty	Outsource	
107	15.05.2019	BIO-CHEMISTRY	Fully auto analyser	Temp. Error	Outsource	
108	15.05.2019	OPHTHAL OT	Auto clave machine	leakage	Outsource	
109	08.05.2019	OPHTHAL OT	Phaco machine	not working	Outsource	
110	06.05.2019	PNC B-106	Pluse oxymetter	SPO2 not shown	Inhouse	
111	06.05.2019	PNC B-106	Multipara monitor	SPO2 Probe faulty	Inhouse	
112	30.04.2019	ENT OT	Electric drill	hand piece jamed	Outsource	
113	29.04.2019	OBS B-108	NST Machine	Printer faulty	Outsource	
114	26.04.2019	SKIN & VD	Dermatoscope	Battray faulty	Inhouse	
115	19.04.2019	OT RECOVERY	Pluse oxymetter	SMPS Board faulty	Outsource	
116	18.04.2019	OT RECOVERY	Multipara monitor	SMPS Board faulty	Outsource	
117	17.04.2019	OPHTHAL OT	Microscope	foot switch faulty	Outsource	
118	17.04.2019	OT	Syringe pump	Touch switch faulty	Inhouse	
119	15.04.2019	ENT OT	Cauty machine	Bipolar cable faulty	Inhouse	
120	11.04.2019	ECG ROOM	ECG Machine	Lead faulty	Inhouse	
121	10.04.2019	NICU	Radiant warmer	Board problem	Inhouse	
122	10.04.2019	FSW B-203	Suction Machine	LED faulty & wheel faulty	Outsource	
123	09.04.2019	Dialysis	Suction Machine	Press. Problem	Outsource	
124	08.04.2019	NICU	Multipara monitor	Mode Problem	Inhouse	
125	08.04.2019	Casualty	boyles machine	Needs serviceing	Outsource	
126	08.04.2019	MSW B-205	Suction Machine	Bottle cap faulty	Outsource	
127	08.04.2019	ECG OPD	ECG Machine	ECG cable faulty	Inhouse	
128	05.04.2019	Microbiology	Incubator	Digital controler faulty	Outsource	
129	05.04.2019	NICU	Multipara monitor	SPO2 Probe Faulty	Inhouse	

130	03.04.2019	OT (CSSD)	Sealing Machine	Coil broken	Inhouse
131	30.03.2019	Casualty	ot lamp	glass broken	Outsource
132	30.03.2019	NICU	Radiant warmer	skin tem. Sensor faulty	Outsource
133	29.03.2019	Casualty	Central suction	block	Outsource
134	27.03.2019	ORTHO OT	Electric drill	hand piece problem	Outsource
135	26.03.2019	RADIOLOGY	X- ray machine	form tube oil leakage	Outsource
136	26.03.2019	NICU	Syringe pump		Inhouse
137	22.03.2019	OPHTHAL OPD	Direct Ophthalmoscope	Illumination problem	Outsource
138	21.03.2019	FMW B-21	Multipara monitor	Board problem	Outsource
139	18.03.2019	CSSD	Sealing machine	Coil broken	Inhouse
140	13.03.2019	OBYG B-16	Multipara monitor	NIBP faulty	Inhouse
141	12.03.2019	ENDOSCOPY OT	Central suction	bottle cup broken	Inhouse
142	12.03.2019	Casualty	Pulse oxymeter	SPO2 not shown	Inhouse
143	11.03.2019	ORTHO OT	C- Arm	Monitor problem	Outsource
144	09.03.2019	ICU	Multipara monitor	NIBP CUFF leakage	Inhouse
145	05.03.2019	NICU	Suction Machine	Moter Problem	Outsource
146	01.03.2019	NICU	Radiant warmer	coil faulty	Inhouse
147	01.03.2019	NICU	Pulse oxymeter	SPO2 Probe faulty	Inhouse
148	26.02.2019	OBS WD B- 105	BP apprators	Rubber bag leakage	Inhouse
149	25.02.2019	Casualty	BP apprators	balloon faulty	Inhouse
150	19.02.2019	NICU	Radiant warmer	coil faulty	Inhouse
151	18.02.2019	NICU	Pulse oxymeter	SPO2 probe faulty	Inhouse
152	18.02.2019	ICU	Pulse oxymeter	SPO2 probe faulty	Inhouse
153	15.02.2019	Blood Bank	microscope	Cable faulty	Inhouse
154	15.02.2019	Blood Bank	microscope	coarse and find adjument problem	Inhouse
155	14.02.2019	OT (CSSD)	Flash autoclave	heater faulty	Outsource
156	13.02.2019	ICU	Multipara monitor	ECG cable faulty	Inhouse
157	12.02.2019	OT No-3/5	Celling Lamp	3 Patel lamp not working	Outsource
158	12.02.2019	ECG OPD	ECG Machine	Electrode faulty	Inhouse
159	06.02.2019	Bio- chemistry	centrifuge	carbon brush faulty	Inhouse
160	05.02.2019	OT	Electric tourniquate	battray faulty	Inhouse
161	04.02.2019	OT (CSSD)	Auto Clave	Startup problem	Outsource
162	31.02.2019	OT (CSSD)	sealing machine	Coil faulty	Inhouse
163	31.01.2019	OBS W B-108	baby warmer	main board problem	Outsource
164	30.01.2019	CSSD	Flash Autoclave	press switch faulty	Outsource

165	29.01.2019	ICU	Multipara monitor	SPO2 Faulty	Inhouse	
166	29.01.2019	FSW B-204	Suction machine	Press. Problem	Inhouse	
167	28.01.2019	Ortho OT	Electric drill	shaft cable faulty	Outsource	
168	25.01.2019	OT (CSSD)	Spray gun unit	Tube and nipple faulty	Outsource	
169	24.02.2019	F/M ophthal wd	BP apprators	mercury leakage	Inhouse	
170	16.01.2019	OT	C - Arm	X- ray off	Outsource	
171	15.01.2019	URO OT	Ceilling lamp	needs to be shorten height	Outsource	
172	14.01.2019	ENT OPD	Light source	lamp faulty	Inhouse	
173	14.01.2019	OT (CSSD)	Auto clave	Heater Faulty	Outsource	
174	11.01.2019	ENT OPD	Audio Metter	freq. not detect	Inhouse	
175	08.01.2019	Physiotheraphy college	ultra sound machine	Totally Off	Inhouse	repaired
176	02.01.2019	MMW 3	Suction machine		Outsource	repaired

Biomedical maintenance details for - 2018

	Date	Department	Equipment name	Breakdown	Action taken (Inhouse/ Outsource)	Remark
1	31.12.2018	OT (Endoscope)	Scopydoc software	software cable faulty	Outsource	
2	31.12.2018	OT ENT	Microscope	balance knob tighten	Inhouse	
3	27.12.2018	ICU (2D Echo)	2D Echo machine	clean fillter msg. coming	Outsource	
4	19.12.2018	CSSD	autoclave	gasket & knob faulty	Outsource	
5	19.12.2018	Casualty	Ot lamp	totally off	Outsource	
6	18.12.2018	ICU	Ventillator	O2 cell faulty	Inhouse	
7	18.12.2018	ICU	Ventillator	flow sensor faulty	Outsource	
8	14.12.2018	PICU	Multipara monitor	Spo2 probe not working	Inhouse	
9	14.12.2018	NICU	Radiant warmer	skin sensor faulty	Inhouse	
10	13.12.2018	NICU	Multipara monitor	Spo2 probe not working	Inhouse	
11	12.12.2018	NICU	Radiant warmer	heater coil faulty	Inhouse	
12	10.12.2018	ICU	Syringe pump	setting problem	Inhouse	
13	07.12.2018	Microbiology	VDRL Rotater	On Off switch faulty	Inhouse	
14	07.12.2018	PICU	Multipara monitor	Spo2 probe not working	Inhouse	
15	05.12.2018	Microbiology	autoclave	heater coil & guage faulty	Outsource	
16	03.12.2018	Ophthal Ot	phaco machine	need servicing	Outsource	
17	29.11.2018	ENT OPD	ABR Machine	Needs servicing	outsourcing	
18	27.11.2018	ENT OT	Debrider	hand piece faulty	outsourcing	
19	27.11.2018	OT.NO.3	Aneasthesia machine	O2 housing not working	outsourcing	
20	24.11.2018	ICU	Multipara monitor	SPO2 probe not working	inhouse	
21	23.11.2018	OT	Video Camera	Required S Vd. Cable	inhouse	
22	22.11.2018	ICU	Central Suction	Wall connection broken	inhouse	
23	22.11.2018	ENT OT	Camera	Image not clear	outsourcing	
24	22.11.2018	Ortho OT	Elec.drill machine	Footswitch not working	outsourcing	
25	22.11.2018	Ophthal OT	Autoclave Machine	Leakage	outsourcing	
26	21.11.2018	OT(CSSD)	Autoclave Machine	Connector faulty	outsourcing	
27	20.11.2018	NICU	Multipara monitor	SPO2 probe not working	inhouse	
28	19.11.2018	OT	Autoclave Machine	Leakage	outsourcing	
29	16.11.2018	OT-Gynac	TL band apliocator	broken	inhouse	

30	14.11.2018	NICU	Radiant warmer	coil faulty	inhouse	
31	14.11.2018	NICU	Pulse Oxymeter	SPO2 probe not working	inhouse	
32	02.11.2018	NICU	Syringe pump	Keypad faulty	inhouse	
33	02.11.2018	Ortho OPD	Plaster cutter	Mains cable broken	inhouse	
34	01.11.2018	OT	Central Suction	Regulator broken	outsource	
35	31.10.2018	pathology	Tissue processor	lock problem	Outsource	
36	31.10.2018	Gyn OT	OT lamp	Arm lock	Outsource	
37	31.10.2018	URO OT	camera	S-VD cable faulty	Inhouse	
38	25.10.2018	BLOOD BANK	centri fuge	making sound	Inhouse	
39	25.10.2018	NICU	Pulse oxymeter	Display faulty	Outsource	
40	25.10.2018	NICU	Radiant warmer	Coil faulty	Inhouse	
41	24.10.2018	ECG ROOM	ECG Machine	Electrode faulty	Inhouse	
42	22.10.2018	Ophthal OT	OT table	unbalanced	Outsource	
43	20.10.2018	Dialysis	dialysis machine	not working	Outsource	
44	19.10.2018	OBS WD 6	multipara monitor	NIBP not shown	Inhouse	
45	15.10.2018	Radiology	X-ray machine	tube head faulty	Outsource	
46	15.10.2018	Radiology	CR system	PSU fan not working	Outsource	
47	09.10.2018	ICU	Ventillator	not working	Inhouse	
48	09.10.2018	ICU	Ventillator	Reding problem	Outsource	
49	06.10.2018	ICU	Pulse oxymeter	spo2 probe not working	Inhouse	
50	06.10.2018	ICU	Pulse oxymeter	spo2 probe not working	Inhouse	
51	06.10.2018	pathology	Microscope	adapter faulty	Inhouse	
52	05.10.2018	OT	multipara monitor	ETCO2 faulty	Outsource	
53	05.10.2018	NICU	Pulse oxymeter	spo2 probe not working	Inhouse	
54	05.10.2018	NICU	Syringe pump	key pad faulty	Inhouse	
55	05.10.2018	OT	multipara monitor	ETCO2 not working	Outsource	
56	05.10.2018	OT	TD 20	Water leakage	Outsource	
57	27.09.2018	ORTHO OT	C Arm	not working properly	outsource	
58	26.09.2018	TB CHEST OPD	Spirometer	Setting problem	Inhouse	
59	25.09.2018	NICU	Multipara monitor	Nibp cuff leakage	Inhouse	
60	24.09.2018	NICU	Radiant warmer	coil faulty	Inhouse	
61	24.09.2018	PICU	Syringe pump	Setting problem	Inhouse	
62	21.09.2018	ICU	ECG Machine	Electrode faulty	Inhouse	
63	20.09.2018	OT CSSD	autoclave	filter broken	outsource	
64	19.09.2018	ORTHO OT	Drill machine	footh switch faulty	Inhouse	

65	18.09.2018	NICU	Multipara monitor	spo2 probe not working	Inhouse	
66	18.09.2018	ICU	Syringe pump	Alarm continues	Inhouse	
67	12.09.2018	OBS WD 6	NST machine	printer problem	Inhouse	
68	12.09.2018	OT URO	C Arm	KV inter lock	outsource	
69	12.09.2018	OT NO.-5	OT table	stucked	outsource	
70	12.09.2018	Gyn OT	Ot lamp	not working	outsource	
71	07.09.2018	NICU	Syringe pump	display faulty	Inhouse	
72	06.09.2018	ORTHO OT	elcetric turniquate	display faulty	outsource	
73	06.09.2018	OPHTHAL OT	Microscope	needs serviceing	outsource	
74	05.09.2018	ICU	Pulse oxymeter	spo2 probe not working	Inhouse	
75	05.09.2018	ICU	Multipara monitor	Nibp cuff faulty	Inhouse	
76	05.09.2018	OBS WD 6	NST machine	event marker faulty	Inhouse	
77	03.09.2018	Radiology	X- ray machine	stand by not working	outsource	
78	28.08.2018	OT CSSD	Flash autoclave	leakage	Outsource	
79	24.08.2018	SKIN & VD	Microdermatorader	needs tubeing	Inhouse	
80	24.08.2018	NICU	Radiant warmer	Coil faulty	Inhouse	
81	24.08.2018	SKIN & VD	Dermato scope	battery faulty	Inhouse	
82	21.08.2018	NICU	Pulse oxymeter	SPO2 probe not working	Inhouse	
83	21.08.2018	NICU	Ventillator	Compressor not working	Outsource	
84	20.08.2018	ORTHO OT	Shaver machine	stop after some time	Inhouse	
85	20.08.2018	OT NO.-4	Cautery machine	REM Error	Outsource	
86	16.08.2018	Gynac wd 11	Multipara monitor	SPO2 probe not working	Inhouse	
87	10.08.2018	ICU	Multipara monitor	ECG Cable & spo2 Probe faulty	Inhouse	
88	10.08.2018	ICU	syringe pump	Display not showing	Inhouse	
89	08.08.2018	ICU	Pulse oxymeter	SPO2 probe not working	Inhouse	
90	06.08.2018	ICU	ECG Machine	Vibration	Inhouse	
91	06.08.2018	ICU	Ventillator	Flow sensor faulty	Inhouse	
92	02.08.2018	ENT OT	Microdrill	Hand piece faulty	Outsource	
93	02.08.2018	URO OT	C Arm	Memory faulty	Outsource	
94	01.08.2018	ECG ROOM	ECG Machine	Electrode faulty	Inhouse	
95	31.07.2018	OT	Auto clave machine	leakage	outsource	
96	31.07.2018	OBS WD 6	multipara monitor	SPO2 Probe not working	Inhouse	
97	31.07.2018	OBS WD 6	NST machine	Event marker faulty	Inhouse	
98	27.07.2018	OT recovery	multipara monitor	capacitor faulty	Inhouse	
99	24.07.2018	NICU	Radiant warmer	coil problem	Inhouse	

100	24.07.2018	NICU	syringe pump	Setting problem	Inhouse
101	24.07.2018	Dialysis	multipara monitor	NIBP cuff leakage	Inhouse
102	23.07.2018	OT CSSD	Spary gun unit	Needs oil	Inhouse
103	21.07.2018	OT No.- 3	C Arm	X- ray off	outsource
104	20.07.2018	NICU	Pulse oxymetter	SPO2 Probe not working	Inhouse
105	20.07.2018	NICU	syringe pump	Key pad faulty	Inhouse
106	18.07.2018	OT	syringe pump	ML not shown	Inhouse
107	17.07.2018	ECG ROOM	ECG Machine	battery falulty	Inhouse
108	17.07.2018	ICU	Pulse oxymetter	SPO2 Probe not working	Inhouse
109	13.07.2018	physiology	Spirometer	sensor not working	outsource
110	13.07.2018	OT CSSD	Flash autoclave	press. & temp. problem	outsource
111	12.07.2018	ICU (stress test)	Stress test machine	Belt moving problem	outsource
112	12.07.2018	ICU	multipara monitor	SPO2 Probe not working	Inhouse
113	10.07.2018	OT No.- 2	multipara monitor	ECG cable not working	Inhouse
114	10.07.2018	NICU	Pulse oxymetter	SPO2 Probe not working	Inhouse
115	09.07.2018	Ortho OT	Ot lamp	blinking	outsource
116	09.07.2018	OT	multipara monitor	Cable faulty	Inhouse
117	09.07.2018	NICU	Pulse oxymetter	SPO2 Probe not working	Inhouse
118	07.07.2018	OT	Electronic Tourniquate	leakage	outsource
119	07.07.2018	OT	multipara monitor	SPO2 Probe not working	Inhouse
120	07.07.2018	OT CSSD	Auto clave machine	Nano not working	outsource
121	06.07.2018	NICU	Radiant warmer	coil faulty	Inhouse
122	05.07.2018	Pathology	hot air oven	heater faulty	Inhouse
123	03.07.2018	NICU	multipara monitor	SPO2 Probe not working	Inhouse
124	02.07.2018	OT	camera	image cut	outsource
125	02.07.2018	ICU	ventillator	Divice failure	outsource
126	02.07.2018	OT CSSD	Auto clave machine	leakage	outsource
127	27.06.18	NICU	Syring pump	not working properly	inhouse
128	26.06.18	ICU	Multipara monitor	NIBP cuff leakage	inhouse
129	25.06.18	OT-CSSD	Autoclave m/c	one heater coil faulty	outsource
130	22.06.18	OBS B-6	Multipara monitor	totally off	outsource
131	18.06.18	Pead B-4	Syring pump	Keypad faulty	inhouse
132	14.06.18	ophthal OPD	slit lamp	ON/OFF switch faulty	inhouse
133	13.06.18	OT	Multipara monitor	smpls board faulty	outsource
134	13.06.18	OT	Pulse oxymeter	totally off	inhouse

135	12.06.18	NICU	Pulse oxymeter	spo2 probe not working	inhouse	
136	09.06.18	OBS B-6	Multipara monitor	monitor off after some time	outsource	
137	01.06.18	NICU	Pulse oxymeter	probe faulty	inhouse	
138	01.06.18	NICU	Syring pump	touch switch faulty	inhouse	
139	01.06.18	NICU	Syring pump	ML not set	inhouse	
140	25.05.18	Micro	Autoclave m/c	Heater faulty	outsource	
141	23.05.18	Ophthal OPD	A-Scan m/c	probe not working	inhouse	
142	24.05.18	Ophthal OT	Autoclave m/c	needs servicing	outsource	
143	15.05.18	OT recorvery	Multipara Monitor	SPO2 probe faulty	inhouse	
144	11.05.18	Uro-OT	Stroze Camera	Image not seen	outsource	
145	10.05.18	OT recorvery	Multipara Monitor	keyboard faulty	inhouse	
146	08.05.18	OT	Multipara Monitor	ETCO2 faulty	outsource	
147	30.04.2018	OT	Ceiling Lamp	Balancing problem	outsource	
148	30.04.2018	OT	C-ARM	Connector cable faulty	outsource	
149	27.04.2018	OT-CSSD	Autoclave Big	Heater faulty	outsource	
150	25.04.2018	Uro-OT	Light source	Totally off	inhouse	
151	24.04.2018	Pead-4	Multipara monitor	SPO2 probe not working	inhouse	
152	24.04.2018	Radiology	X-ray m/c DX-525	Horizontal column welding separated	outsource	
153	23.4.2018	ICU	Stress test machine	not run smoothly	outsource	
154	18.04.2018	ICU	Multipara monitor	SPO2 probe not working	inhouse	
155	16.04.2018	NICU	Pulse oxymeter	SPO2 probe not working	inhouse	
156	12.04.2018	OBS - 6	Multipara monitor	SPO2 probe not working	inhouse	
157	10.04.2018	OT	Syring pump	touch switch faulty	inhouse	
158	06.04.2018	Radiology	X-ray m/c 60mA	X-ray not shoot	outsource	
159	03.04.2018	Gynac-OT	Central Suction - pead	regulator faulty	outsource	
160		OT-5	OT Table	Head low & head up problem	outsource	
161		OT-4	OT Table	Down suddenly	outsource	
162	03.04.2018	OT-3	OT Table	Head low & head up problem	outsource	
163	28.03.2018	NICU	Radiant Warmer	Coil not working	inhouse	
164	25.03.2018	OT-CSSD	Autoclave Big	Control panel box connector burnt	outsource	
165	22.03.2018	ICU	Multipara monitor	NIBP cuff leakage	inhouse	
166	19.03.2018	CCL	Centrifuge	Doork lock problem	inhouse	
167	15.03.2018	ENT-OT	Micro drill	hand piece jamed	outsource	
168	15.03.2018	NICU	Radiant Warmer	Coil not working	inhouse	
169	12.03.2018	Radiology	CR System	Totally shutdown	outsource	

170	10.03.2018	Ophthal-OT	OT Table	Remote faulty	outsource	
171	10.03.2018	ICU	Multipara monitor	SPO2 probe not working	inhouse	
172	07.03.2018	OT-4 & 7	OT Table	Up-down problem	outsource	
173	05.03.2018	OT	Bronchoscope	Leakage problem	outsource	
174	28.02.2018	Radiology	X-ray D525	Totally off	outsource	
175	26.02.2018	ECG Room	ECG Machine	Battery problem	inhouse	
176	23.02.2018	Recovery-OT	Pulse oxymeter	SPO2 probe not working	inhouse	
177	23.02.2018	Gynac-OT	Vacuum Unit	Regulator broken	inhouse	
178	20.02.2018	Ortho-OT	OT Table	Remote not working	outsource	
179	20.02.2018	Uro-OT	C-ARM	X-ray off	inhouse	
180	20.02.2018	OBS - 6	Multipara monitor	SPO2 probe not working	inhouse	
181	17.02.2018	ICU	Pulse oxymeter	SPO2 probe not working	inhouse	
182	16.02.2018	OBS - 6	NST Machine	US probe faulty	inhouse	
183	15.02.2018	OT-Surg	Visual Obturator	not working	outsource	
184	14.02.2018	ECG Room	ECG Machine	Paper printer lock problem	inhouse	
185	12.02.2018	NICU	Radiant Warmer	Lug broken & coil faulty	inhouse	
186	12.02.2018	NICU	Multipara monitor	SPO2 probe not working	inhouse	
187	06.02.2018	ICU	Multipara monitor	SPO2 probe connector broken	inhouse	
188	06.02.2018	ICU	ECG Machine	ECG cable faulty & printer lock problem	inhouse	
189			Pulse oxymeter	SPO2 probe not working	inhouse	
190			Pulse oxymeter	SPO2 probe not working	inhouse	
191			Multipara monitor	SPO2 probe not working	inhouse	
192	06.02.2018	ICU	Multipara monitor	ECG cable faulty	inhouse	
193	02.02.2018	OBGY OPD	LED Lamp	lamp faulty	inhouse	
194	30.01.2018	ICU	Defibrillator	Printer not working	inhouse	
195	23.01.2018	ENT -OT	Micro debrider	hand switch jamed	outsource	
196	23.01.2018	ICU	Ventilator	O2 cell faulty	outsource	
197	23.01.2018	ICU	Ventilator	flow sensor faulty	outsource	
198	22.01.2018	NICU	Pulse Oxymeter	SPO2 probe not working	inhouse	
199	13.01.2018	RO Plant (Dialysis)	RO Plant	needs servicing	outsource	
200	10.01.2018	Blood Bank	Refrigarator	Alarm problem & lock problem	inhouse	
201	08.01.2018	OT-CSSD	Autoclave	Leakage	outsource	
202	05.01.2018	OT-7 & 8	Ceiling Lamp	OT No. 7 ON/OFF problem, No. 8 - balancing problem	outsource	

203	05.01.2018	NICU	Pulse Oxymeter	Probe not working	inhouse	
204	04.01.2018	OT-9	Central Suction	Not working	inhouse	
205	04.01.2018	Pathology	Pentahead microscope	lamp holder faulty	inhouse	
206	02.01.2018	Dialysis	Dialysis Machine	Precipitation gear head faulty	outsource	
207	02.01.2018	OT-CSSD	ETO Machine	Mains cable & socket burnt	inhouse	
208	01.01.2018	Dialysis	Dialysis Machine	Photosensor board not working	outsource	

Biomedical maintenance details for - 2017

	Date	Department	Equipment name	Breakdown	Action taken (Inhouse/ Outsource)	Remark
1	29.12.2017	OT	Electronic Tourniquate	cuff not inflate	inhouse	
2	28.12.2017	ICU	Pulse oxymeter	SPO2 probe is not working	inhouse	
3	22.12.2017	PICU	Syringe pump	not working	inhouse	
4	22.12.2017	NICU	Radiant warmer	Coil problem	inhouse	
5	20.12.2017	ORTHO OT	Multipara monitor	Pulse oxymeter not working	inhouse	
6	20.12.2017	ORTHO OT	Multipara monitor	ETCO2 capnastats not working	outsource	
7	20.12.2017	ENT OT	Camera	not working	outsource	
8	16.12.2017	Casualty	Syringe pump	Totally off	inhouse	
9	14.12.2017	ICU	Syringe pump	Two syringe pump not working	inhouse	
10	12.12.2017	OT (CSSD)	Flash autoclave	contractor coil not working	outsource	
11	11.12.2017	PICU	Syringe pump	not working	inhouse	
12	08.12.2017	OPHTHALOLOGY	Indirect ophthalmoscope	Lamp not working	inhouse	
13	08.12.2017	OPHTHAL OPD	Ophthalmoscope	Lamp not working	inhouse	
14	07.12.2017	NICU	Warmer	Coil problem	inhouse	
15	07.12.2017	Radiology	LED View box	not working	inhouse	
16	27.11.2017	OT	Trolley suction M/C	Float broken	inhouse	
17	27.11.2017	ORTHO OT	Remer Hand piece	Not working	outsource	
18	24.11.2017	OT NO-4	Lamp	Not working	outsource	
19	23.11.2017	OT	Multipara monitor	NIBP cuff not working	inhouse	
20	17.11.2017	RHTC	Needle culter	Not working	inhouse	
21	16.11.2017	CCL (Pathology)	Auto analyzer	Machine pump not working	outsource	
22	09.11.2017	OPHTHAL OT	Autoclave	Not working	outsource	
23	08.11.2017	ICU	O2 line	One Pt leak	outsource	
24	07.11.2017	ICU	Ventillator	ventilator not working	outsource	
25	03.11.2017	ICU	Multipara monitor	Display problem	inhouse	
26	03.11.2017	ECG	Patient Cable	ECG cable not working	inhouse	
27	03.11.2017	Casualty	Multipara monitor	NIBP Cuff faulty	inhouse	
28	02.11.2017	ICU	Defibrillator	Printer assembly need to be changed	inhouse	

29	02.11.2017	ICU	O2 point	O2 pt mismatched	inhouse	
30	01.11.2017	NICU	Warmer	Coil faulty	inhouse	
31	01.11.2017	MMW-3	Suction machine	Not working	outsource	
32	31.10.2017	Casualty	Multipara monitor	Communication error	inhouse	
33	31.10.2017	ORTHO OT	Orthoscope	not working properly	outsource	
34	30.10.2017	MMW-1	O2 Meter	leakage	inhouse	
35	30.10.2017	OT (CSSD)	Horizontal autoclave	leakage form back side	outsource	
36	30.10.2017	ECG	ECG machine	Disturbance	inhouse	
37	29.10.2017	Dialysis Unit	RO Plant	one tube broken	inhouse	
38	25.10.2017	ICU	Syringe pump	giving alarm	inhouse	
39	14.10.2017	ICU	Covdien Spo2 machine	Spo2 probe faulty	inhouse	
40	12.10.2017	URO OT	OT Table	Remote not working	outsource	
41	12.10.2017	MMW-3	Humidifire bottle	bottle broken	inhouse	
42	10.10.2017	Ophthalmology	Fundoscope	Bulb faulty	inhouse	
43	09.10.2017	OT	C- Arm	X- Ray off	outsource	
44	04.10.2017	Dialysis Unit	Dialysis machine	Alarm E66	outsource	
45	04.10.2017	CCL	Nycocard reader	Needs calibration	outsource	
46	04.10.2017	Biochemistry	Elise reader	lamp not working	inhouse	
47	03.10.2017	ICU	ECG machine	printer problem	inhouse	
48	29.09.2017	ICU	Laryngoscope	blade no.4 not working	inhouse	
49	27.09.2017	NICU	Vision - 60 MA	Collimeter bulb not working	outsource	
50	27.09.2017	Casualty	X-ray machine	machine not working	outsource	
51	27.09.2017	ECG	Patient cable	cable not working	inhouse	
52	25.09.2017	OT (CSSD)	Flash autoclave	water heater not working	outsource	
53	25.09.2017	PAED's w	Monitor	Not working properly	inhouse	
54	23.09.2017	OT	Monitor	Four NIBP cuff leak	inhouse	
55	21.09.2017	OT	CO2 washer	need to new washer	inhouse	
56	21.09.2017	OT	Foot switch	Not working	inhouse	
57	19.09.2017	OT no-4	OT Table	heavy for up & down	outsource	
58	15.09.2017	OT	Microscope	needs servicing	outsource	
59	14.09.2017	Microbiology	Microscope	needs servicing	outsource	
60	14.09.2017	CCL	Centrifuge	lock need to change	inhouse	
61	14.09.2017	GEN. Surg. OT	URS (Urotroscope)	Image not clear	outsource	
62	13.09.2017	ICU	O2 connection	Two O2 connection loose	inhouse	
63	11.09.2017	OT	Fogging machine	not on	inhouse	

64	11.09.2017	OT	Monitor	on / off switch faulty	inhouse	
65	08.09.2017	NICU	Multiparar monitor	probe not repaired condition	inhouse	
66	08.09.2017	NICU	Pulse oxymeter	spo2 probe not working	inhouse	
67	08.09.2017	ICU	Syringe pump	Setting problem	inhouse	
68	08.09.2017	ICU	Syringe pump	fuse gone	inhouse	
69	07.09.2017	Genral surgery	stent removal forcep	Not working properly	inhouse	
70	05.09.2017	ICU	Monitor	Two spo2 probe not working	inhouse	
71	05.09.2017	ICU	Monitor	Display not working	inhouse	
72	04.09.2017	NICU	Pulse oxymeter	spo2 probe not working	inhouse	
73	01.09.2017	GYN W -11	Monitor	spo2 probe not working	inhouse	
74	29.08.2017	GYN OT	Camera	camera head faulty	Outsource	
75	29.08.2017	NICU	Radiant warmer	coil faulty	Inhouse	
76	29.08.2017	GYN OT	Camera	picture not clear	Outsource	
77	28.08.2017	ICU	ECG Machine	printer problem	Inhouse	
78	22.08.2017	URO Ot	C arm	cable removed	Inhouse	
79	22.08.2017	ORTHO OT	Electric Drill machine	shaft cable faulty	Outsource	
80	22.08.2017	OPHTHAL OPD	Slip lamp	illumination part jam	Outsource	
81	21.08.2017	GYN OT	Camera	camera head coupler problem	Outsource	
82	21.08.2017	OPHTHAL OT	OT table	up down problem	Outsource	
83	21.08.2017	ORTHO OT	celling Lamp	blingking	Outsource	
84	16.08.2017	OT	Cautery machine	cut & coag problem	Inhouse	
85	14.08.2017	NICU	Syringe pump			
86	11.08.2017	ICU	Syringe pump	not working	Inhouse	
87	08.08.2017	ICU	Multipara monitor	Display faulty	Outsource	
88	08.08.2017	ICU	Multipara monitor	BP Cuff leak	Inhouse	
89	07.08.2017	ORTHO OT	Ortho scope	not working		
90	07.08.2017	CCL	Semi auto analyser	zero reading	Outsource	
91	04.08.2017	OT CSSD	Autoclave	vaccume problem	Outsource	
92	03.08.2017	ICU	Multipara monitor	Spo2 probe faulty	Inhouse	
93	02.08.2017	OPHTHAL OPD	keratometer	not working	Outsource	
94	01.08.2017	Paed's w-4	Multipara monitor	Spo2 probe faulty	Inhouse	
95	01.08.2017	OT	Cautery machine	foot switch faulty	Inhouse	
96	01.08.2017	ENT OT	Anaesthesia machine	O2 sensor expried	Outsource	
97	01.08.2017	OBS W-6	Multipara monitor	NIBP Cuff leakage	Inhouse	
98	31.07.2017	GYN OT	Fabius plus	O2 flow continous	Outsource	

99	28.07.2017	NICU	Radiant warmer	coil faulty	Inhouse
100	28.07.2017	OPHTHAL OPD	Slit lamp	foot switch faulty	Outsource
101	27.07.2017	psy OPD	ECT Machine	Borad problem	Outsource
102	25.07.2017	ECG ROOM	ECG machine	battery faulty	Inhouse
103	24.07.2017	ICU	Stress test machine	setting problem	Inhouse
104	21.07.2017	ECG ROOM	ECG machine	electrode faulty	Inhouse
105	20.07.2017	NICU	Syringe pump	Not working	Inhouse
106	20.07.2017	NICU	Pulse oxymeter	spo2 probe faulty	Inhouse
107	20.07.2017	Casualty	Defibrillapor	battery faulty	Inhouse
108	18.07.2017	ICU	Multipara monitor	NIBP leak	Inhouse
109	15.07.2017	OBS w-6	NST Machine	US Probe faulty	Inhouse
110	14.07.2017	Casualty	Multipara monitor	spo2 probe faulty	Inhouse
111	13.07.2017	ENT OPD	Impedance audio meter	needs servicing	Outsource
112	08.07.2017	PICU	Syringe pump	setting problem	Inhouse
113	07.07.2017	ICU	Pulse oxymeter	spo2 probe faulty	Inhouse
114	07.07.2017	NICU	Radiant warmer	coil faulty	Inhouse
115	07.07.2017	NICU	Syringe pump	Key pad faulty	Inhouse
116	07.07.2017	NICU	Syringe pump	Touch switch faulty	Inhouse
117	05.07.2017	OPHTHAL OT	OT Table	foot switch faulty	Outsource
118	04.07.2017	Casualty	Pulse oxymeter	Spring loose	Inhouse
119	01.07.2017	Radiology	X- ray machine (525MA)	X-ray not shoot	Outsource
120	01.07.2017	Radiology	X- ray machine (800MA)	X-ray not shoot	Outsource
121	29.06.2017	URO OT	cystoscopy	inlet tap broken	Outsource
122	29.06.2017	Paed w-4	Syringe pump	touch switch faulty	Inhouse
123	28.06.2017	Casualty	hydrolic trolly	up down problem	Outsource
124	28.06.2017	OT	Syringe pump	touch switch faulty	Inhouse
125	27.06.2017	OBS W-6	NST machine	printing problem	Inhouse
126	27.06.2017	NICU	radiant warmer	skin temp. sensor faulty	Inhouse
127	22.06.2017	TB & Chest	spirometer	Sowftware problem	Inhouse
128	19.06.2017	ECG OPD	ECG machine	electrode faulty	Inhouse
129	19.06.2017	CCL	5 part machine	press. Error	Outsource
130	16.06.2017	Radiology	X- ray machine	shoot button faulty	Outsource
131	16.06.2017	NICU	Syringe pump	not working	Inhouse
132	12.06.2017	OT	Camera	image not clear	Outsource
133	10.06.2017	ICU	Multipara monitor	hose pipe broken	Inhouse

134	07.06.2017	OT CSSD	Autoclave	heater coil faulty	Outsource
135	07.06.2017	MMW-1	Multipara monitor	mains cable problem	Inhouse
136	07.06.2017	OBS W-6	NST machine	printing problem	Inhouse
137	05.06.2017	NICU	Syringe pump	Key pad faulty	Inhouse
138	05.06.2017	ICU	Ventillator	Measurement inop	Outsource
139	05.06.2017	ICU	Ventillator	Flow sensor inop	Outsource
140	02.06.2017	ICU	Ventillator	mains cable problem	Inhouse
141	02.06.2017	ICU	Multipara monitor	hose pipe broken	Inhouse
142	31.05.2017	OT CSSD	autoclave	press. Problem	Outsource
143	30.05.2017	NICU	Radiant warmer	coil faulty	Inhouse
144	30.05.2017	OT -3	Celling lamp	balancing problem	Outsource
145	26.05.2017	CCL (patho)	5 Part cell counter	WBC Chamber error	Outsource
146	23.05.2017	OT CSSD	Flash autoclave	Not working	Outsource
147	23.05.2017	CCL	Alere-380	Press. Error	Outsource
148	19.05.2017	NICU	Syringe pump	moter trouble msg.	Inhouse
149	19.05.2017	NICU	Syringe pump	key pad faulty	Inhouse
150	19.05.2017	PICU	Multipara monitor	SPO2 probe not working	Inhouse
151	15.05.2017	ENT OT	Microscope	vision not clear	Outsource
152	15.05.2017	sury. OT	Celling lamp	balancing problem	Outsource
153	04.05.2017	ICU	Multipara monitor	Cable connector faulty	Inhouse
154	04.05.2017	ICU	Multipara monitor	SPO2 probe not working	Inhouse
155	04.05.2017	ICU	Multipara monitor	NIBP conncter broken	Inhouse
156	04.05.2017	TB & Chest OPD	Spirometer	Reding not shown	Outsource
157	04.05.2017	URO OT	OT Table	remote faulty	Outsource
158	03.05.2017	ICU	Multipara monitor	ECG cable faulty	Inhouse
159	27.04.2017	NICU	Pulse oxymetter	spo2 probe not working	Inhouse
160	24.04.2017	ICU	multipara monitor	NIBP Cuff leakage	Inhouse
161	24.04.2017	Sury. OT	Celling lamp	balancing problem	Outsource
162	24.04.2017	Sury. OT	OT table	remote problem	Outsource
163	24.04.2017	ECG OPD	ECG Machine	electrode faulty	Inhouse
164	24.04.2017	NICU	Ventillator	O2 sensor & Humidifire not working	Outsource
165	24.04.2017	NICU	Pulse oxymetter	spo2 probe not working	Inhouse
166	22.04.2017	OBS w-6	Nst machine	setting problem	Inhouse
167	17.04.2017	Gyn OT	Celling lamp	Not working	Outsource
168	13.04.2017	CCL	Easylyte	Sample error	Inhouse

169	10.04.2017	CCL (patho)	Sysmex 5 part	not getting print out	Outsource	
170	10.04.2017	ENT OT	Debrider	voice problem	Outsource	
171	08.04.2017	ICU	multipara monitor	spo2 probe not working	Inhouse	
172	08.04.2017	ICU	Syringe pump	touch switch faulty	Inhouse	
173	06.04.2017	NICU	Radiant warmer	Skin temp. sensor faulty	Inhouse	
174	05.04.2017	ICU	Suction machine	bottle cap broken	Outsource	
175	01.04.2017	OT OPHTHAL	OT table	up down problem	Outsource	
176	01.04.2017	NICU	Ventillator	setting problem	Inhouse	
177	30.03.2017	OT CSSD	Flash autoclave	contractor faulty	outsource	
178	29.03.2017	OPHTHAL OPD	Vision drum	belt broken	inhouse	
179	26.03.2017	OT	Floor lamp	glass broken	outsource	
180	25.03.2017	OT	Celling lamp	not working	outsource	
181	23.03.2017	NICU	Central O2	leakage	outsource	
182	21.03.2017	NICU	Radiant warmer	SMPS board faulty	inhouse	
183	21.03.2017	OT CSSD	Flash autoclave	temp. down	outsource	
184	21.03.2017	NICU	Radiant warmer	SMPS board faulty	inhouse	
185	21.03.2017	NICU	Radiant warmer	coil faulty	inhouse	
186	20.03.2017	ORTHO OT	Celling lamp	Spark suddenly	outsource	
187	14.03.2017	ICU	Multipara monitor	SPO2 probe not working	inhouse	
188	10.03.2017	DIALYSIS UNIT	R.O. PLANT	Needs servicing	outsource	
189	10.03.2017	CCL	Easylyt analyzer	machine not working	inhouse	
190	10.03.2017	ICU	all Monitor	monitor checked	inhouse	
191	07.03.2017	OT	Emco monitor	NIBP Cuff Faulty	inhouse	
192	07.03.2017	OT	Celling lamp	one head of the lamp not working	outsource	
193	07.03.2017	URO OT	Stroz camera	camera connector not working	outsource	
194	07.03.2017	SKIN OPD	microscope	focus light not clear	outsource	
195	27.02.2017	Ophthal Ward	Slit lamp	Not working	inhouse	
196	25.02.2017	MMW-1	Laryngoscope	cell jam	inhouse	
197	23.02.2017	URO OT	C- Arm machine	image suddenly changed	outsource	
198	23.02.2017	MMW-3	Suction machine	Not working	outsource	
199	18.02.2017	OT	Vista I20	ON/off switch faulty	outsource	
200	18.02.2017	OT	Multipara monitor	NIBF cuff faulty	inhouse	
201	17.02.2017	ICU	Central O2 pt	O2 PT. need to be repaire	outsource	
202	16.02.2017	W-7	F/A Valve	O2 meter broken	outsource	
203	15.02.2017	OT	Celling lamp	Most of the LED is not working	outsource	

204	15.02.2017	ICU	Pulse oxymeter	sop2 probe not working	inhouse	
205	14.02.2017	Sury. Ot	Boyles machine	O2 leakage	outsource	
206	14.02.2017	NICU	syringe pump	Not working	inhouse	
207	14.02.2017	NICU	Central suction	Not working	outsource	
208	14.02.2017	NICU	Central O2	leakage	outsource	
209	14.02.2017	NICU	Radiant room heater	display not working	outsource	
210	08.02.2017	OBS W- 6	NST machine Probe	not getting cardio reading	inhouse	
211	07.02.2017	OT	Dragger monitor	spo2 connector missing	outsource	
212	07.02.2017	GYN OT	EMCO monitor	NIBP CUFF not working	inhouse	
213	07.02.2017	URO OT	Lithoplast foot pad	foot pad not working	outsource	
214	06.02.2017	Blood Bank	Autoclave	press.not set	outsource	
215	06.02.2017	Dental OPD	Dental chair	suction not working	inhouse	
216	06.02.2017	OPHTHAL OPD	Vision drum	remote switch & vision drum belt faulty	inhouse	
217	04.02.2017	Sury. Mino. OT	Old Boyles	O2 leakage	outsource	
218	02.02.2017	ICU	Smith Syringe pump	Not working	inhouse	
219	02.02.2017	ICU	Globel Syringe pump	touch switch faulty	inhouse	
220	28.01.2017	paeds wd	pulse oxymeter	spot probe faulty	inhouse	
221	20.01.2017	ECG	Patient cable	lead faulty	inhouse	
222	19.01.2017	CCL	Easylyte Analyrer	K+ error	outsource	
223	17.01.2017	CCL	Easylyte	K' electrode not working	outsource	
224	17.01.2017	ORTHO OT	Monitor	NIBP CUFF leakage	inhouse	
225	17.01.2017	Gyn Ot	Monitor	ETCO2 connetor faulty	outsource	
226	17.01.2017	Surg. OT	Fabius plus	display faulty	outsource	
227	17.01.2017	OT	Monitor	scroll button is faulty	inhouse	
228	17.01.2017	ORTHO OT	Multipara monitor	NIBP CUFF faulty	inhouse	
229	16.01.2017	PICU	Radiant warmer	power conral board not working	outsource	
230	16.01.2017	PICU	Radiant warmer	warmer coil not working	inhouse	
231	16.01.2017	Microbiology	Binocular microscope	need servicing	outsource	
232	16.01.2017	Microbiology	PH Metter	ph electrode faulty	outsource	
233	16.01.2017	Microbiology	Incubator	indicator problem	outsource	
234	16.01.2017	OBS W - 6	Spot light	One spot light is not working	outsource	
235	16.01.2017	OBS W - 6	Spot light	Three spot light basement is loose	inhouse	
236	13.01.2017	OBS W - 6	Spot light	spot light cable is short not working	inhouse	
237	10.01.2017	ICU	Defibrillator	defibrillator battery faulty	inhouse	

238	09.01.2017	ICU	EMCO monitor	Ecg cable broken	inhouse	
239	07.01.2017	ICU	Multipara monitor	ECG cable totally broken needs to be changed by new one	inhouse	
240	05.01.2017	ICU	Ventillator	continues alarm given	outsource	
241	05.01.2017	ICU	Ventillator	Press. Meas inop	outsource	
242	04.01.2017	RICU	Resmed ventillator	O2 cell replace Msg. coming	inhouse	
243	04.01.2017	OPHTHAL OT	Microscope	need servicing	outsource	
244	04.01.2017	OT	Ot table hydrolic	up & down funtion problem	outsource	
245	04.01.2017	MMW-1	Monitor	Switch on/ off not working	inhouse	
246	03.01.2017	OT	Multipara monitor	spo2 probe not working	inhouse	
247	03.01.2017	ICU	Monitor	spo2 probe not working	inhouse	
248	02.01.2017	BLOOD BANK	Cell counter	not working prorperly	outsource	

Biomedical maintenance details for - 2016

Sr.no	Date	Department	Equipment name	Breakdown	Action taken (Inhouse/ Outsource)	Remark
1	27.12.2016	OPHAL OT	OT Table	foot switch faulty	Outsource	
2	20.12.2016	Biochemistry	PH meter	PH electrode faulty	Inhouse	
3	13.12.2016	ENT OPD	Suction machine	Bottle broken	Inhouse	
4	13.12.2016	NICU	Radiant warmer	Heater coil faulty	Inhouse	
5	13.12.2016	ENT OPD	Suction machine	Bottle broken	Inhouse	
6	09.12.2016	OT	Syringe pump	touch switch faulty	Inhouse	
7	09.12.2016	OT	Syringe pump	touch switch faulty	Inhouse	
8	09.12.2016	NICU	Syringe pump	Not working	Inhouse	
9	07.12.2016	ICU	Multipara monitor	SPO2 Probe faulty	Inhouse	
10	07.12.2016	Biochemistry	Electronic balance	Not working	Inhouse	
11	06.12.2016	OPHAL OPD	Slit lamp	Cable broken	Inhouse	
12	05.12.2016	PICU	Radiant warmer	Coil faulty	Inhouse	
13	01.12.2016	OT	Multipara monitor	SPO2 Probe faulty	Inhouse	
14	01.12.2016	URO OT	Cystoscopy sheath	RT. Side tap broken	Outsource	
15	26.11.2016	GYN OT	Multipara monitor	Spo2 probe faulty	Inhouse	
16	24.11.2016	Dialysis	Dialysis machine	spring broken	Inhouse	
17	22.11.2016	ENDOSCOPY	Endoscopy unit	Foot switch faulty	Inhouse	
18	22.11.2016	OPHAL OT	Phaco machine	Not working	Outsource	
19	19.11.2016	CCL	RO plant	TDS High	Inhouse	
20	19.11.2016	NICU	Radiant warmer	coil faulty	Inhouse	
21	19.11.2016	NICU	Syringe lamp	Touch switch faulty	Inhouse	
22	19.11.2016	Biochemistry	Elisa reader	Not working	Inhouse	
23	19.11.2016	Septic OT	Ceiling lamp	lamp faulty	Inhouse	
24	18.11.2016	OT (CSSD)	Autoclave machine	Leakage	Outsource	
25	09.11.2016	ORTHO OT	Syringe lamp	Not working	Outsource	
26	05.11.2016	OT	Autoclave	Door screw broken	Outsource	
27	03.11.2016	ECG ROOM	ECG Machine	2 Electrode faulty	Inhouse	
28	25.10.2016	Septic OT	Ceiling lamp	not working	Outsource	
29	18.10.2016	OT	Syringe pump	display faulty	Inhouse	

30	15.10.2016	OT	Gastroscope	Air leak	Outsource
31	13.10.2016	OT	Urotroscope	vision not clear	Outsource
32	06.10.2016	ECG ROOM	ECG machine	ECG Cable faulty	Outsource
33	05.10.2016	NICU	Syringe pump	display faulty	Outsource
34	03.10.2016	OPHTHAL OT	OT Table	up/ down key faulty	Outsource
35	03.10.2016	OPHTHAL OT	Microscope	vision not clear	Outsource
36	27.09.2016	OT	Multipara monitor	NIBP cuff leak	Inhouse
37	27.09.2016	URO OT	Lithotripsy	Hand piece faulty	Outsource
38	26.09.2016	NICU	Pulse oxymeter	Spo2 probe not working	Inhouse
39	23.09.2016	OBS W-6	NST Machine	US probe faulty	Outsource
40	20.09.2016	PICU	Multipara monitor	Spo2 probe not working	Inhouse
41	16.09.2016	GYN W-11	Suction machine	not working	Outsource
42	12.09.2016	PEADS W	Suction machine	not working	Outsource
43	12.09.2016	PEADS W	Syngine pump	Motor trouble	Outsource
44	12.09.2016	OT	Pulse oxymeter	Spo2 probe faulty	Inhouse
45	07.09.2016	PICU	Syngine pump	bolus problem	Inhouse
46	07.09.2016	NICU	Pulse oxymeter	Spo2 probe faulty	Outsource
47	03.09.2016	OT	Multipara monitor	NIBP cuff leak	Inhouse
48	31.08.2016	OT	Syringe pump	Display faulty	Inhouse
49	22.08.2016	ORTHO OT	Ceilling lamp	Power supply board faulty	Outsource
50	19.08.2016	OT (CSSD)	Autoclave	Not working	Outsource
51	19.08.2016	PATHOLOGY	Microtome	Stage problem	Outsource
52	16.08.2016	OPHTHAL OPD	Keratometer	Not working	Outsource
53	05.08.2016	Radiology	X-Ray machine (DX525)	Not working	Outsource
54	04.08.2016	Minor OT	Ceilling lamp	Balancing problem	Outsource
55	04.08.2016	OT (Endoscopy)	Endoscopy unit	Air and water channel not working	Outsource
56	04.08.2016	OT (CSSD)	Autoclave	Not working	Outsource
57	02.08.2016	OT	Camera (styker)	Monitor not working	Outsource
58	02.08.2016	NICU	Syringe pump	Tottaly Off	Outsource
59	01.08.2016	Dialysis	Dialysis machine	Conductivity problem	Outsource
60	30.07.2016	GYN W-6	Multipara monitor	Power cord faulty	Outsource
61	29.07.2016	PEADS W	Multipara monitor	NIBP Cuff faulty	Outsource
62	22.07.2016	OT	Endoscope	S Vedio cable faulty	Inhouse
63	22.07.2016	OT	Cautery machine	Foot switch faulty	Inhouse
64	22.07.2016	OPHTHAL OT	Microscope	Foot switch faulty	Inhouse

65	21.07.2016	Dialysis	Multipara monitor	NIBP Module faulty	Outsource	
66	20.07.2016	NICU	Ventillator	Compressor faulty	Outsource	
67	20.07.2016	OPHTHAL OPD	Auto refractometer	System error	Outsource	
68	19.07.2016	ECG ROOM	ECG Machine	RA Electrode faulty	Inhouse	
69	07.07.2016	ICU	Multipara monitor	Spo2 probes connector broken	Inhouse	
70	04.07.2016	OT	Camera (Stroze)	Vision not clear	Outsource	
71	04.07.2016	NICU	Syngie pump	Setting problem	Inhouse	
72	04.07.2016	ICU	Multipara monitor	Battery faulty	Inhouse	
73	30.06.2016	ECG ROOM	ECG machine	connector broken	Inhouse	
74	28.06.2016	ENT OT	Micorscope	Fogging	Outsource	
75	27.06.2016	OPHTHAL OT	Micorscope	Halogen bulb faulty	Inhouse	
76	22.06.2016	OPHTHAL OT	Autoclave	Not working	Outsource	
77	21.06.2016	GEN. OT	Nephroscope	scope inlet viser broken	Outsource	
78	20.06.2016	ENT OT	Anaesthesia machine	Flow sensor faulty	Inhouse	
79	15.06.2016	OPHTHAL OPD	A-Scan Machine	Probe faulty	Inhouse	
80	08.06.2016	ENT OT	Anaesthesia machine	O2 sensor expired	Outsource	
81	08.06.2016	Emergency OT	Anaesthesia machine	O2 calibration fail	Inhouse	
82	08.06.2016	OPHTHAL OT	Phaco machine	Sowftware root back up	Inhouse	
83	07.06.2016	OPHTHAL OPD	Slit lamp	Merror borken	Outsource	
84	02.06.2016	OT	Pulse oxymeter	Adapter faulty	Inhouse	
85	01.06.2016	Emergency OT	Multipara monitor	ETCO2 Module faulty	Outsource	
86	01.06.2016	Surg. OT	Anaesthesia machine	System leak test fail	Inhouse	
87	31.05.2016	OT	Cautery machine	display faulty	Outsource	
88	24.05.2016	Dialysis	Multipara monitor	SPo2 probe faulty	Inhouse	
89	19.05.2016	OPHTHAL OPD	A- Scan machine	Probe faulty	Inhouse	
90	13.05.2016	PEADs w	Syringe pump	Touch switch faulty	Inhouse	
91	12.05.2016	ENT OPD	Audio meter	needs servicing	Outsource	
92	11.05.2016	OPHTHAL OT	Autoclave machine	Not working properly	Outsource	
93	11.05.2016	NICU	Pulse oxymeter	SPo2 probe faulty	Inhouse	
94	11.05.2016	ORTHO OT	Anaesthesia mahine	display faulty	Outsource	
95	07.05.2016	OT	ECT Machine	Not working properly	Inhouse	
96	07.05.2016	Surg. OT	Multipara monitor	SPo2 probe faulty	Inhouse	
97	06.05.2016	GYN OT	Lithotripsy	Hand piece faulty	Outsource	
98	05.05.2016	GYN OT	Anaesthesia mahine	leak test fail	Outsource	
99	05.05.2016	OT	CO2	Leakage	Inhouse	

100	05.05.2016	Dialysis	Dialysis machine	Not working properly	Outsource
101	05.05.2016	OT	Monitor	Screen not seen properly	Outsource
102	04.05.2016	NICU	Pulse oxymeter	SPo2 probe faulty	Inhouse
103	02.05.2016	ENT OT	Microscope	needs servicing	Outsource
104	30.04.2016	Ophthal OPD	Slit lamp	Lamp faulty	Outsource
105	28.04.2016	Biochemistry	Electrophoresis	Power pack faulty	Inhouse
106	27.04.2016	ICU	ECG Machine	ECG Cable faulty	Inhouse
107	27.04.2016	NICU	Radiant warmer	Coil faulty	Inhouse
108	25.04.2016	OT	Multipara monitor	setting problem	Inhouse
109	25.04.2016	NICU	Radiant warmer	Coil faulty	Inhouse
110	23.04.2016	NICU	Syringe pump	clear switch faulty	Inhouse
111	21.04.2016	ICU	Multipara monitor	ECG Cable faulty	Inhouse
112	20.4.2016	ICU	Multipara monitor	Spo2 probe faulty	Inhouse
113	11.04.2016	Bood Bank	PH meter	Display faulty	Outsource
114	11.04.2016	OT	Pulse oxymeter	totally off	Inhouse
115	11.04.2016	OT ORTHO	Celling lamp	5 in 1 bulb gone	Outsource
116	09.04.2016	OT (CSSD)	Horizontal autoclave machine	heater coil not working	Outsource
117	06.04.2016	OT (CSSD)	Horizontal autoclave	wire burn	Outsource
118	30.03.2016	CCL Biochemistry	Centrifuge	carbon brush faulty	Inhouse
119	28.03.2016	ICU	Central suction	suction problem	Outsource
120	28.03.2016	FSW	Laryngoscope	Bulb problem	Inhouse
121	28.03.2016	OT (GYN)	Cautery machine	Cutting problem	Inhouse
122	28.03.2016	ORHTO OT	Electric tourniquate	Not working	Inhouse
123	23.03.2016	OT SURG	Fabius pluse	close Ckt broken	Outsource
124	23.03.2016	OT ENT	Micro debrider	Hand piece getting hot	Outsource
125	22.03.2016	ICU	Spo2 probe	spring broken	Inhouse
126	22.03.2016	ICU	O2 Pt	O2 PT leakage	Outsource
127	21.03.2016	ECG ROOM	ECG Cable	one lead not working	Inhouse
128	16.03.2016	Peads w	syringe pump	Not off	Inhouse
129	10.03.2016	NICU	Old warmer meditrin	Coil faulty	Inhouse
130	09.03.2016	Peads w	Pulse oxymeter	SPo2 probe faulty	Inhouse
131	05.03.2016	Biochemistry CCL	Easylyte	Y/N button faulty	Outsource
132	03.03.2016	OPHTHAL OPD	Slit lamp	Wire burn	Inhouse
133	23.02.2016	NICU	Pulse oxymeter	Spo2 probe faulty	Inhouse
134	23.02.2016	NICU	C-PAP Machine	totally off	Outsource

135	23.02.2016	Biochemistry	Chem 5X	Temp. raise	Outsource	
136	22.02.2016	ICU	Multipara monitor	Spo2 probe faulty	Inhouse	
137	22.02.2016	ICU	Multipara monitor	Spo2 probe faulty	Inhouse	
138	16.02.2016	Biochemistry	PH meter	Electrode faulty	Inhouse	
139	15.02.2016	OT	Endoscope system	Vision not clear	Outsource	
140	05.02.2016	OPHTHAL OT	Autoclave machine	Press. Problem	Outsource	
141	05.02.2016	OT	Anaesthesia Machine	O2 sensor expired	Outsource	
142	05.02.2016	OT	Anaesthesia Machine	Ventilator leak test fail	Inhouse	
143	11.01.2016	Casualty	Multipara monitor	SPO2 Probe faulty	Inhouse	
144	09.01.2016	OT	Boyles machine	Leakage	Outsource	
145	07.01.2016	NICU	Multipara monitor	SPO2 Probe faulty	Inhouse	
146	07.01.2016	ICU	Oxygen manifold	Tail pipe broken	Outsource	
147	07.01.2016	OT	Anaesthesia Machine	O2 sensor Expired	Outsource	
148	04.01.2016	CCL	Chem 5X	Machine stop automatic	Outsource	
149	02.01.2016	OT	Pulse oxymeter	showing error	Inhouse	
150	02.01.2016	CCL	Analyser	Electrode faulty	Outsource	
151	02.01.2016	CCL	XI -640 (Auto analyser)	Showing minus value	Outsource	

MIMER Medical College, Talegaon (D)

ICT Department Log Book

Year 2021

Date	Department	Machine Name	Breakdown	Action Taken
1/1/2021	Biochemistry	CPU	Internet issue	Drivers installed
27/1/2021	Ophthalmology	CPU	Operating system	Repair with chkdsk /r
3/2/2021	Central store	CPU	Operating system	Repair with chkdsk /r
15/2/2021	Biochemistry	CPU	Operating system	Repair with last restore point
24/2/2021	Cash Counter	CPU	Restarting after sometime	After maintenance of CPU working ok
17/3/2021	MRD	CPU fan	CPU fan Error	Replace the fan
7/4/2021	Casualty	SMPS	Power supply issue	SMPS changed
27/4/2021	OBGY	CPU	Internet issue & slow machine	Extra RAM installed
5/5/2021	Ortho OPD	CPU	Internet not working	After maintenance of CPU working ok
26/5/2021	CCL collection	CPU	Slow machine	Extra RAM installed
3/6/2021	Paediatric OPD	CPU Fan	CPU fan Error	Replace the fan
28/6/2021	Accounts Hospital	Operating system	Continuous restarting	After maintenance & Extra RAM installation machine working
16/7/2021	PG Section	Operating system	Windows update problem	After uninstalling recent update woking
17/8/2021	Purchase	Operating system	Operating system corrupted	Installed fresh copy of Win 10
30/8/2021	Research lab	Operating system	After login System hang	Installed fresh copy of Win 10
2/9/2021	Anatomy	CPU fan	CPU fan Error	Replace the fan
11/9/2021	Pharmacology	Printer	Paper stuck in printer	After removing paper working
23/9/2021	Central Store	CPU	Continuous restarting	Repair with chkdsk /r

Year 2020

Date	Department	Machine Name	Breakdown	Action Taken
13/1/2020	Hospital & college building	Purchasing of Router (J.S.ENT)		Router installed in various department
20/1/2020	Admin Office	2 Desktop computer purchasing (K.N.ENT)		Handover :- 1) computer for PA to Principal 2) Admin Office clerk
3/2/2020	College	5 Pendrive purchasing (K.N.ENT)		for various departments
3/2/2020	Admin Office	Switch - digisol giga	Admin office network down due to switch problem	Replace switch with new digisol switch
4/2/2020	Admin Office	CPU problem	Motherboard problem	Repaired
7/2/2020	Hospital	Router purchase		Installed in Hospital department
16/3/2020	Hospital	Wireless camera		Installtion of 2 camera in new ward building
13/4/2020	Microbiology	Motherboard problem	Motherboard and cabinet	Replaced with new motherboard and cabinet
20/4/2020	Casualty and MRD	Dlink switch	Switch showing H02 error	Replaced with new switch
5/5/2020	Registration counter	CCTV camera	Camera at registration counter and physiology department not working	BMC and power connector changed
31/5/2020	Cash counter hospital	HDD	HDD corrupted	Replaced HDD with new HDD
11/6/2020	Opthal OPD	CPU problem	Operating system corrupted	Repair with CD
21/7/2020	Biochemistry - CCL	Computer	SMPS (Power Supply)	Replace smps with new SMPS
2/9/2020	Accounts Hospital	CPU	Continue restarting problem	Repair with CD
15/9/2020	Surgery OPD	CPU	Display problem	RAM changed
21/9/2020	Admin Office	CPU	Motherboard sound continuously	RAM changed

21/9/2020	Dental	CPU	Internet not working	Drivers installed
2/10/2020	ICTC	RAM	RAM damaged	RAM changed
3/10/2020	Community Medicine	CPU	Slow machine	Formatted machine with Win 7
12/10/2020	Microbiology	CPU	Continuous restarting	Refresh machine with OS CD
12/10/2020	Medical Store	HDD	Corrupted HDD	New HDD installed
21/10/2020	Ortho department	CPU	Continupus restarting	Repair with chkdsk /r
21/10/2020	MS office	RAM	RAM damaged	RAM changed
22/10/2020	Central Store	CPU	Operating system corrupted	Repair with chkdsk /r
24/11/2020	Research Lab	CPU	Operating system corrupted	Formatted machine with Win 10
25/11/2020	Biochemistry - CCL	CPU	Operating system corrupted	Formatted machine with Win 7
30/11/2020	Assistant Registrar	CPU	Operating system corrupted	Formatted machine with Win 7
10/12/2020	Accounts officer	Laptop	Slow machine	Formatted and handover to HR Head
Year 2019				
Date	Department	Machine Name	Breakdown	Action Taken
7/1/2019	OPD building	Media-pair	Media for OPD building id damaged (one side OPD network is down)	Media pair changed
15/1/2019	OBGY department	CPU	CPU fan has to be replaced	CPU - Fan is replaced with new fan
18/11/2019	Computer lab	Switch 24 - port	Switch problem	Switch 24 - port new installed in computer lab
21/1/2019	Sever room (G.K. network)	CCTV cameras networking		New network cables & switch installed for MCI CCTV camera
23/1/2019	Sever room	Hipath 3800 sever		AMC renewal for hipath 3800 communication sever maintenance from 1/1/2019 to 30/6/2019
21/2/2019		CCTV AMC (techbean)		AMC renewal for CCTV period 1/10/2018 to 31/3/2019
11/3/2019		Purchase of pendrive 16 4 B HP (KN Ent)		for inspection purpose
11/3/2019		HP desktop PC - 190 13 89 N/ 4GB RAM 11 TB HDD / 19.5 monitor		HR sir
23/4/2019	For plexus photos	Purchase of 2 TB HDD		HDD for plexus
27/6/2019	Telephone operator	DVR	DVR damaged	Replace with new DVR
1/7/2019	Internet lab	Asco switch	Switch configuration problem	online support for ciscoswitch
3/7/2019	AMC renewal techmerge	hipath sever		Renewal of AMC fpr period 1/7/2019 to 31/12/2019
13/7/2019	Ortho department	Lenova desktop canon printer pendrive - 16 GB		Purchase of computer for ortho department
7/8/2019	Computer lab	Exide batteries	UPS battery damaged	Changed battery with new exide battery
13/8/2019		Purchase of telephone cord & repairing of IP phone		Purchase of IP phone cord & repaired phone of ward
29/8/2019	Operater	IP phone	Network card, interal keypad & BLF part problem	Repaired
4/9/2019	Naac	lenova computer I 38100 4GB 1 TB HDD		Purchase
9/9/2019	Internet lab	Color ribbon for I card printer		Purchase of fargo eco Ymcko ribbon 45515 PVC card & card holder
24/9/2019	MPJY department	HDD (External)		HDD (TB) for rajiv gandhi dept.
30/9/2019	OT	CCTV camera		Installation of CCTV camera in operation theater
5/10/2019		UPS IKVA		Purchase of UPS for Hospital & college
18/10/2019	Shushrut Hall	VGA cable & HDMI cable	VGA cable pronlem	Sushrut hall VGA & HDMI cable changed
21/10/2019	Patho, community medicine	Projeter		4 new casio projector purchased for departments

23/10/2019		Pendrive		16 GB pendrive purchased for inspection
11/12/2019		Keyboard, Mouse Battery		10 Keyboard, 10 Mouse & 10 Battery purchased
16/12/2019		Pendrive sandise 16 GB		New 4 Pendrive purchased
3/12/2019	MSW department	CPU	SMPS problem	SMPS of computer is changed
4/12/2019	Internet Lab	Media convertor	Damage media converter	New media convertor pair installed
31/12/2019	Media store	CPU	Motherboard problem	Repaired
Year 2018				
Date	Department	Machine Name	Breakdown	Action Taken
3/1/2018	ICT Department	Fortigate 100d renewal	Renewal of firewall	Renewal firewall for next 3 years and also AMC firewall renewed
9/1/2018	Blood Bank	Canon LBP 2900 Printer	Printer working stopped taflon & presher roller problem	Change taflon & preshr roller of printer working ok.
12/1/2018	Physiology Department	HP 1020 printer	Printer working stopped taflon & presher roller problem	Change taflon & preshr roller of printer working ok.
02/02/218	Radiology Department	CPU	Computer is not working motherbord chip issue	Repaired motherboard chip
21/2/2018	Purchase Department	HP monitor	Power panel problem	Change power panel of HP U 185E
6/4/2018	Anatomy Department	HP 1020 printer	Power supply of printer is damage	Changed power supply by HP 1020 printer
16/5/2018	Cash counter hospital	Canon MF3010 Printer	Taflon sleeve / presher roller & Seving of printer	Changed taflon & presher roller of printer
31/5/2018	Microbiology Department	Canon LBP 2900 Printer	Taflon & presher roller problem	Changed taflon & presher roller of printer working ok
8/6/2018	Pathology Department	CPU hard disk problem	HDD is damaged	Change HDD with new HDD
8/6/2018	ICT Department	SMPS of CPU problem	SMPS stopped working	Change SMPS & cabinet of CPU
27/6/2018	Principal Office	Canon LBP 2900	Taflon & sleeve presher	Changed taflon sleeve & presher roller
10/7/2018	Admin office hospital	Canon LBP 2900	Taflon & sleeve presher roller	Changed taflon sleeve & presher roller
20/7/2018	Admin department	Laptop vostro	Heatsink problem	Repaired heatsink IC
1/8/2018	Physiotherapy college (library)	motherboard	Motherboard	Repaired motherboard (dell machine)
1/8/2018	Physiotherapy college(OPD)	CPU	Fan of CPU	Changed fan of CPU
8/9/2018	Pathology Department	Printer LBP 2900	Sleeve & presher roller	Changed sleeve & roller
11/10/2018	Micro & admin	D - link switch & LAN card HDD	D - link switch of civil engineer damaged, LAN card of micro dept. HDD of admin lohkare	switch changed LAN card changed HDD changed
28/12/2018	Firewall	Online support for 3 years		Renewal of online support AMC till 2020